



**SCHWEITZER ENGINEERING LABORATORIES, INC.**

2350 NE Hopkins Court • Pullman, WA 99163-5603 USA

Phone: 509.332.1890 • Fax: 509.332.7990

www.selinc.com • info@selinc.com

February 2, 2007

## **SEL-8310 Remote Fault Reader Attestation**

The SEL-8310 is a wireless Remote Fault Reader handheld device that retrieves fault location information from the SEL-8300 wireless interface.

In conjunction with the SEL-8300, the SEL-8310 allows the operator to identify the phase and location of underground fault. A red LED and audible annunciation indicate the presence of a faulted phase of the power system.

The SEL-8310 will operate in the 902-928 MHz ISM band in compliance with section 15.249 of Chapter 47 of the Federal Communications Rules and Regulations

Don MacArthur

A handwritten signature in black ink that reads "Don macarthur". The signature is written in a cursive, lowercase style.

Compliance Engineer

Schweitzer Engineering Laboratories, Inc.

***Making Electric Power Safer, More Reliable, and More Economical®***