



Emissions Testing
Performed
on the
Abiomed
AbioCor™ Implantable Replacement Heart
To

FCC Part 15, Subpart C, Section 15.249

Date(s) of Test: April 30 and May 21, 2004

Page 1 of 22

Report Number: 3058793

Contact: Mr. Charles Kolifrath

All services undertaken are subject to the following general policy: Reports are submitted for exclusive use of the client to whom they are addressed. Their significance is subject to the adequacy and representative character of the samples and to the comprehensiveness of the tests, examinations or surveys made. No quotations from reports or use of Intertek Testing Services NA Inc. name is permitted except as expressly authorized by Intertek Testing Services NA Inc. in writing. This report must not be used to claim product endorsement by NVLAP, NIST or any other agency of the U.S. Government.

Table of Contents

TABLE OF CONTENTS.....	2
I – INTRODUCTION AND SUMMARY	3
II – TECHNICAL REQUIREMENTS.....	4
15.1 SCOPE.....	4
15.15 GENERAL TECHNICAL REQUIREMENTS.....	4
15.27 SPECIAL ACCESSORIES.....	4
15.31 MEASUREMENT STANDARDS	4
15.33 FREQUENCY RANGE OF MEASUREMENT	4
15.35 MEASUREMENT DETECTOR FUNCTIONS AND BANDWIDTH	4
15.37 TRANSITION PROVISIONS	5
15.105 INFORMATION TO THE USER.....	5
15.107 CONDUCTED LIMITS.	6
15.109 RADIATED EMISSION LIMITS.	7
15.111 ANTENNA POWER CONDUCTION LIMITS FOR RECEIVERS.	8
15.201 CERTIFICATION	8
15.203 ANTENNA REQUIREMENTS	8
15.204 EXTERNAL RADIO AMPLIFIER.....	9
15.205 RESTRICTED BANDS OF OPERATION	9
15.207 CONDUCTED LIMITS	9
15.209 RADIATED EMISSION LIMITS; GENERAL REQUIREMENTS.....	9
15.249 OPERATION WITHIN THE BANDS 902-928MHZ, 2400-2483.5MHZ, 5725-5875, AND 24.0-24.25GHZ	10
III - ATTESTATION	11
IV - SITE DESCRIPTION.....	12
V - MEASUREMENT EQUIPMENT	13
VI - CONFIGURATION INFORMATION.....	14
VII - CONFIGURATION PHOTOGRAPHS	15
VIII - SAMPLE CALCULATION	17
IX - DATA TABLES.....	18
X - DUTY CYCLE (AVERAGE FACTOR).....	21
XI - BANDWIDTH	22

Intertek Testing Services NA, Inc.

I – Introduction and Summary

TO: Mr. Charles Kolifrath
FROM: Kouma Sinn, Senior Project Engineer
DATE: June 9, 2004
Project #: 3058793

RE: Emissions Testing Performed on the AbioCor™ Implantable Replacement Heart

On April 30 and May 21, 2004, we tested the AbioCor™ Implantable Replacement Heart to determine if it was in compliance with the FCC Part 15, Subpart C, Section 15.249. A Prototype version of the sample was received on April 27, 2004 in good condition. We found that the unit met the Part 15, Subpart C requirements when tested as received.

The following Table summarizes the results of testing.

Test	Frequency (MHz)	Measurement	Requirement	Pass/Fail	Section of FCC Rules	Section of Test Report
Fundamental Field Strength	916.600	84.7 dBμV/m	94 dBμV/m	Pass	15.249	Table 1
Restricted Band & Spurious Emissions	1833	30.8 dBμV/m	54 dBμV/m	Pass	15.209	Table 1
Line-Conducted Emissions	0.170	53.6	55.0	Pass	15.107	Table 2

In summary, this report confirms that the AbioCor™ Implantable Replacement Heart is compliant with the FCC Part 15, Subpart C Section 15.249 requirements when production units conform the sample tested. Please address all questions and comments concerning this report to Scott M. Lambert, Operations Manager.

II – Technical Requirements

15.1 Scope

The device is an intentional radiator intended to operate in accordance with 15. 249 - Operation within the bands 902-928 MHz, 2400-2483.5 MHz, 5725-5875 MHz, and 24.0-24.25 GHz. This device operates at 916.6 MHz.

15.15 General Technical Requirements

There are no controls accessible to the user that would cause the device to operate in violation of the FCC rules.

15.27 Special Accessories

No special accessories are necessary to meet compliance requirements.

15.31 Measurement Standards

The measurement procedures specified by ANSI C63.4:2001 were used to setup and test the device. See Section IV of this test report for detailed description of the test procedure.

The device was tested as a system.

15.33 Frequency range of measurement

The device was scanned for spurious and harmonic emissions from 30 MHz to the 10th harmonic of the fundamental frequency. The spurious emission scan from 30-1000MHz is addressed in a separate report.

15.35 Measurement detector functions and bandwidth

The following table illustrates the detector functions and bandwidth used to test the device.

No deviations to the following were made.

Intertek Testing Services NA, Inc.

Frequency Range	Measurement Detector	Measurement Bandwidth
30 MHz - 1 GHz	Quasi-peak	120kHz
916.6 MHz	Peak	120kHz
1 GHz to 10 th harmonic	Peak	1 MHz

An averaging factor was not used for the device because peak measurements passed the specified limits.

15.37 Transition Provisions

Transition provisions were not applied to the device.

15.105 Information to the user

- (b) For a Class B digital device peripheral, the instructions furnished the user shall include the following or similar statement, placed in a prominent location in the text of the manual:

NOTE: This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to Part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference in a residential installation. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and receiver
- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.
- Consult the dealer or an experienced radio/TV technician for help.

Intertek Testing Services NA, Inc.

15.107 Conducted limits.

(a) Except for Class A digital devices, for equipment that is designed to be connected to the public utility (AC) power line, the radio frequency voltage that is conducted back onto the AC power line shall not exceed the following. Compliance with this provision shall be based on the measurement of the radio frequency voltage between each power line and ground at the power terminals.

Frequency of Conducted Emission Limit – Class B

Frequency (MHz)	Limits (dB μ V)	
	Quasi-peak	Average
0.15 to 0.50	66 to 56*	56 to 46*
0.5 to 5	56	46
5 to 30	60	50

*Limits decrease linearly with the logarithm of the frequency.

(b) For a Class A digital device that is designed to be connected to the public utility (AC) power line, the radio frequency voltage that is conducted back onto the AC power line on any frequency or frequencies within the band 150 KHz to 30 MHz shall not exceed the limits in the following table. Compliance with this provision shall be based on the measurement of the radio frequency voltage between each power line and ground at the power terminals. The lower limit applies at the band edges.

Frequency of Conducted Emission Limit – Class A

Frequency (MHz)	Limits (dB μ V)	
	Quasi-peak	Average
0.15 to 0.50	79	66
0.5 to 30	73	60

The following option may be employed if the conducted emissions exceed the limits in paragraph (a) or (b) of this Section, as appropriate, when measured using instrumentation employing a quasi-peak detector function: if the level of the emission measured using the quasi-peak instrumentation is 6 dB, or more, higher than the level of the same emission measured with

instrumentation having an average detector and a 9 kHz minimum bandwidth, that emission is considered broadband and the level obtained with the quasi-peak detector may be reduced by 13 dB for comparison to the limits. When employing this option, the following conditions shall be observed:

- (1) The measuring instrumentation with the average detector shall employ a linear IF amplifier.
- (2) Care must be taken not to exceed the dynamic range of the measuring instrument when measuring an emission with a low duty cycle.
- (3) The test report required for verification or for an application for a grant of equipment authorization shall contain all details supporting the use of this option.

Intertek Testing Services NA, Inc.

Summary of Test Results

Quasi-peak readings compare to quasi-peak limits					
Frequency (MHz)	Reading Line (dB μ V)	Reading Neutral (dB μ V)	Net Reading (dB μ V)	Limits (dB μ V)	Margin (dB)
0.170	39.3	40.0	61.2	65.0	-3.7
0.226	32.4	34.0	54.3	62.6	-8.3
0.327	26.5	28.0	48.3	59.5	-11.2
0.568	17.7	18.2	38.6	56.0	-17.4
1.964	17.8	17.7	38.5	56.0	-17.5
2.618	15.7	16.6	37.1	56.0	-18.9
8.507	24.9	26.3	47	60.0	-13

Average readings compare to average limits					
Frequency (MHz)	Reading Line (dB μ V)	Reading Neutral (dB μ V)	Net Reading (dB μ V)	Limits (dB μ V)	Margin (dB)
0.170	31.4	31.4	53.3	55.0	-1.6
0.226	24.8	26.4	46.7	52.6	-5.9
0.327	25.3	26.7	47.0	49.5	-2.5
0.568	12.3	15.2	35.5	46.0	-10.5
1.964	12.8	12.4	33.5	46.0	-12.5
2.618	13.8	13.8	34.5	46.0	-11.5
8.507	21.2	22.6	43.3	50.0	-6.7

Notes: Net readings include cable loss, insertion loss, and 20 dB attenuator. Test was performed on the patient console as the AbioCor™ Implantable Replacement Heart is powered from it.

15.109 Radiated emission limits.

Except for Class A digital devices, the field strength of radiated emissions from unintentional radiators at a distance of 3 meters shall not exceed the following values:

Frequency of Emission Radiated Limit – Class B		
Frequency (MHz)	Limit (μ V/m)	Limit (dB μ V/m)
30 to 88	100	40.0
88 to 216	150	43.5
216 to 960	200	46.0
Above 960	500	54.0

Intertek Testing Services NA, Inc.

The field strength of radiated in the emission tables above, the tighter limit applies at the band edges. Sections 15.33 and 15.35 which specify the frequency range over which radiated emissions are to be measured and the detector functions and other measurement standards apply.

For a receiver which employs terminals for the connection of an external receiving antenna, the receiver shall be tested to demonstrate compliance with the provisions of this Section with an antenna connected to the antenna terminals unless the antenna conducted power is measured as specified in Section 15.111(a). If a permanently attached receiving antenna is used, the receiver shall be tested to demonstrate compliance with the provisions of this Section.

Summary of Test Results

Class	Configuration	Frequency (MHz)	Measurement (dBμV)	Measurement (μV)	Limit (μV)	Pass/Fail
The device is not a receiver						

15.111 Antenna power conduction limits for receivers.

In addition to the radiated emission limits, receivers that operate (tune) in the frequency range 30 to 960 MHz and CB receivers that provide terminals for the connection of an external receiving antenna may be tested to demonstrate compliance with the provisions of Section 15.109 with the antenna terminals shielded and terminated with a resistive termination equal to the impedance specified for the antenna, provided these receivers also comply with the following: with the receiver antenna terminal connected to a resistive termination equal to the impedance specified or employed for the antenna, the power at the antenna terminal at any frequency within the range of measurements specified in Section 15.33 shall not exceed 2.0 nanowatts.

Summary of Test Results

Configuration	Frequency (MHz)	Measurement (dBμV)	Measurement (μV)	Limit (μV)	Pass/Fail
The device does not have the ability to connect to an external antenna. Measurements were not performed.					

15.201 Certification

The device is required to be certified in accordance with Part 2 of the FCC rules, Subpart J.

15.203 Antenna Requirements

The antennas are soldered to the PC board and cannot be readily removed from the device.

15.204 External Radio Amplifier

The device is not an amplifier.

15.205 Restricted bands of operation

The attenuation required by 15.249 is greater than the general requirements of 15.209. All un-wanted emissions, from the transmitter, were compared to the general limits which are the requirement for restricted band emissions.

Below 1000 MHz a quasi peak detector was employed to measure all un-wanted emissions.

No emission was detected beyond the second harmonic.

15.207 Conducted limits

The device was powered from the console.

15.209 Radiated emission limits, general requirements

All un-wanted emissions from the device were compared to the general requirements.

Detailed Description of Operation

The device communicated with external RF communication module at 916.6MHz during testing.

Test Method Justifications

For maximizing emissions, the system was rotated through 360 degrees, the antenna height was varied from 1 meter to 4 meters above the ground plane, and the antenna polarization was changed.

The EUT was mounted on a non-conductive box to allow the engineer to manipulate the EUT in the three orthogonal axes.

The system was configured for testing in a typical fashion (as a customer would normally use it), and in the confines as outlined in C63.4 (2001).

The arrangement of the cables dangling from the rear of the table was varied to the extent possible to produce

Intertek Testing Services NA, Inc.

the maximum emissions.

15.249 Operation within the bands 902-928 MHz, 2400-2483.5 MHz, 5725-5875MHz, and 24.0-24.25 GHz

The field strength of emissions from this device shall comply with following:

Fundamental Frequency (MHz)	Fundamental Field Strength		Harmonics Field Strength	
	(mV)/m	(dBμV)/m	(μV)/m	(dBμV)/m
902-928	50	94	500	54

The emission requirement for harmonic emission is identical to the general requirement of 15.209. Spurious emission measurements were compared to the general requirement of 15.209.

The fundamental emission was measured with a peak detector. For above 1000 MHz, measurements were made with a peak detector.

Intertek Testing Services NA, Inc.

III - Attestation

LABORATORY MEASUREMENTS

**Pursuant To
Part 15, Subpart C
For
Intentional Radiators**

Company Name: Abiomed
Address: 22 Cherry Hill Drive
Danvers, MA 01923

Model No.: See Test Configuration

Date(s) of Test: April 29 and May 21, 2004

Test Site Location: INTERTEK TESTING SERVICES NA INC.
70 Codman Hill Road
Boxborough, MA 01719

Site(s): 2C

We attest to the accuracy of this report:

Signature

Kouma Sinn

Testing Performed By:

Senior Project Engineer

Title

Signature

Michael F. Murphy

Reviewer

Staff Engineer/EMC

Title

IV - Site Description

Introduction

The following is a description of the test procedure used by Intertek Testing Services in the measurements of transmitters operating under Part 15, Subpart C, General Requirements.

- A. **Test Set-Up:** The test set-up and procedures described below are designed to meet the requirements of ANSI C63.4 (2001).
1. The test site is a Plastic/Fiberglass structure with a groundplane. The site has attenuation characteristics which meet the requirements of ANSI C63.4 (2001). Information on the site has been filed with the FCC as required by Rule 2.948. The address of the site is 70 Codman Hill Road, Boxborough, MA 01719.
 2. Power to the site is nominal line voltage of 117 V_{AC} and 230 V_{AC}, 60 Hz.
 3. The equipment under test (EUT) is placed on a wooden turntable which is four feet in diameter and 80cm high above the groundplane. During the radiated emissions test, the turntable is rotated 360 degrees and any cables leaving the EUT are manipulated to find the configuration resulting in maximum emissions. The antenna height and polarization are also varied during the search for maximum signal levels. The height of the antenna is varied from one meter to four meters. Body-worn, hand-held and small portable devices are mounted on a non-conductive box and emissions are investigated on three orthogonal axis.
 4. Detector function for radiated emissions is in peak or quasi-peak mode. Average readings, when required, are taken by measuring the duty cycle of the equipment under test and subtracting the corresponding amount in dB from the measured peak readings according to the following formula:

$$\text{Averaging Factor in dB} = 20 \text{ LOG (duty cycle)}$$

The time period over which the duty cycle is measured is 100 msec. The worst-case (highest percentage on) duty cycle is used and described specifically in the data section. The duty cycle is measured by placing the spectrum analyzer in zero scan (receiver mode) and linear mode at maximum bandwidth (3 MHz at 3 dB down) and viewing the resulting time domain signal output from the analyzer on a Tektronix 465 Oscilloscope. The oscilloscope is used because of its superior time base and triggering facilities.
 5. Antennas used below 1000 MHz was EMCO Model 3142 Biconolog Antennas. For measurements between 1000 MHz and 18000 MHz, an EMCO Model: 3115 Horn Antenna is used. The Antennas used are listed in the Test Equipment Summary in Section 5
 6. The field strength measuring equipment used included:

Intertek Testing Services NA, Inc.

V - Measurement Equipment

The following equipment was used to make measurements for emissions testing:

Description	Manufacturer	Model	Serial #	Cal Due
Spectrum Analyzer	Agilent	E7405A	US40240205	07/02/2004
Antenna	EMCO	3142	9711-1116	10/17/2004
Horn Antenna	EMCO	3115	9602-4675	09/03/2004
High Frequency cable	Megaphase	PM40 K1K1 197	CBL028	11/11/2004
EMI Receiver	Hewlett Packard	85420E	3427A00126	12/08/2004
30' BNC Cable	Alpha Wire (ITS)	RG 58A/U	CBL10MS3	07/15/2004
10M In Floor Cable	Alpha Wire (ITS)	RG 214/U	10M In Floor	09/22/2004
Antenna	EMCO	3142	9711-1223	11/05/2004
20 dB Attenuator	Mini-Circuit	CAT-20	DS22A	07/08/2004
LISN	Solar Electronics	9252-50-R-24-BNC	941714	07/22/2004
LISN	Solar Electronics	8012-50-R-24-BNC	934612	07/22/2004

7. The frequency range to be scanned is from the lowest radio frequency signal generated in the device which is greater than 9 kHz to the tenth harmonic of the highest fundamental frequency, or 40 GHz, whichever is lower. For line-conducted emissions, the range scanned is 150 kHz to 30 MHz.
8. The EUT is warmed up for 15 minutes prior to the test. If battery powered, a new battery is used.
9. Conducted measurements were made as described in ANSI C63.4 (2001). An IF bandwidth of 9 kHz is used, and peak or quasi-peak detection is employed.
10. The IF bandwidth used for measurement of radiated signal strength was 100 kHz or greater below 1000 MHz. Where pulsed transmissions of short enough pulse duration warrant, a greater bandwidth is selected according to the recommendations of Hewlett Packard Application No. 150-2. A discussion of whether pulse desensitivity is applicable to this unit is included in this report. Above 1000 MHz, a bandwidth of 1 MHz is used.
11. Transmitter measurements are normally conducted at a measurement distance of three meters. However, to assure low enough noise floor in the forbidden bands and above 1 GHz (where no preamplifier is used), signals are acquired at a distance of one meter or less. All measurements are extrapolated to three meters using inverse scaling, but those measurements taken at a closer distance are so marked.
12. For measurements made in the 9 kHz to 30 MHz range, a distance of 30 meters was used unless a good signal-to-noise ratio could not be obtained. In that case, a closer distance was used and that distance is so marked in the data table.

Intertek Testing Services NA, Inc.

VI - Configuration Information

Equipment Under Test: AbioCor™ Implantable Replacement Heart

Model No.: See Test Configuration

Serial No.: See Test Configuration

FCC Identifier: Not Labeled

EUT Test Configuration:

Blue Bucket (Implantable System) - AbioCor™ Implantable Replacement Heart		
Description	Model No.	Serial No.
Thoracic Unit	0034-6000-50H02	T27185-002
iController	0034-3340	HU082602007
iCable	0034-3450	1364
iBattery	0034-3707	EE031003013
iTET	0034-3207	HU090401001

Support Equipment:

Description	Model No.	Serial No.
AbioCor™ Patient Console	0034-4430	AC7002

Cables:

QTY	Description	Shield Description	Hood Description	Length (m)
1	Physiological	Foil Shield	Metal hood	7.5
1	RF Com. Module	Unshielded	Plastic	3.0
1	Signal Interface	Unshielded	Plastic	3.0
1	TET	Unshielded	Plastic	3.4
1	AC Mains	Copper Shield	Hospital Grade	2.4
1	AC Mains	Copper Shield	Hospital Grade	3.0

VII - Configuration Photographs

Worst-Case Radiated Emissions



Intertek Testing Services NA, Inc.

Worst-Case Line-Conducted Emissions



VIII - Sample Calculation

The following is how net field strength readings were determined:

$$NF = RF + AF + CF + PF + DF$$

Where,

NF = Net Reading in dB μ V/m

RF = Reading from receiver in dB μ V/m

AF = Antenna Correction Factor in dB

CF = Cable Correction Factor in dB

PF = Preamplifier Correction Factor in dB

DF = Distance Factor in dB (using 20 dB/decade), from 3 to 1 meters 10.5 dB was added for measurements performed at 1 meter

AVF = Average Factor derived from the Duty Cycle

To convert from dB μ V/m to μ V/m or mV/m the following was used:

$$UF = 10^{(NF / 20)}$$

Where,

UF = Net Reading in μ V/m

Example:

For the fundamental field strength measurement at 906.0 (distance = 3 meters) see table [1].

$$NF = RF + AF + CF + PF + DF = 57.5 + 24.0 + 4.0 + 0.0 + AVF = 81.3$$

$$UF = 10^{(81.3 \text{ dB}\mu\text{V} / 20)} = 11,614.5 \mu\text{V/m}$$

Intertek Testing Services NA, Inc.

IX - Data Tables

Table 1

Radiated Emissions / Interference

Company: Abiomed, Inc. Model #: See Test Configuration
Engineer: Kouma Sinn Location: 2C Serial #: See Test Configuration
Project #: 3058793 Pressure: 1013 mbar Receiver: HP 8542E & Agilent
Date: 04/30/04 Temp: 21 Antenna: LOG 2 and HORN1
Standard: FCC Part 15.249 Humidity: 42% PreAmp: None
Class: None Group: None Cable(s): Site2, 3M Floor 9-22-04.cbl & CBL028
Limit Distance: 3 meters Test Distance: 3 meters
Voltage/Frequency: See notes in table Frequency Range: Fundamental and spurious from 1-9.166GHz

Notes: AbioCor Implantable Replacement Heart in air

Test Distance (meters)	Ant. Pol. (V/H)	Frequency MHz	Reading dB(uV)	Antenna Factor dB(1/m)	Cable Loss dB	Pre-amp Factor dB	Distance Factor dB	Net dB(uV/m)	Limit dB(uV/m)	Margin dB	Notes
3	V	916.600	58.7	23.9	1.2	0.0	0.0	83.8	94.0	-10.2	1
3	V	916.600	58.6	23.9	1.2	0.0	0.0	83.7	94.0	-10.3	2
3	V	916.600	59.6	23.9	1.2	0.0	0.0	84.7	94.0	-9.3	3
0.5	V	1833.200	17.0	26.8	2.5	0.0	15.6	30.8	54.0	-23.2	
No other emisisions were detected above 1833.2MHz at 10cm. The noise floor readings were at least 6 dB below the limits											

Notes: AbioCor Implantable Replacement Heart in phantom material

Test Distance (meters)	Ant. Pol. (V/H)	Frequency MHz	Reading dB(uV)	Antenna Factor dB(1/m)	Cable Loss dB	Pre-amp Factor dB	Distance Factor dB	Net dB(uV/m)	Limit dB(uV/m)	Margin dB	Notes
3	V	916.600	39.1	23.9	1.2	0.0	0.0	64.2	94.0	-29.8	1
3	V	916.600	39.1	23.9	1.2	0.0	0.0	64.2	94.0	-29.8	2
3	V	916.600	39.1	23.9	1.2	0.0	0.0	64.2	94.0	-29.8	3
No other emisisions were detected above 1GHz at 10cm. The noise floor readings were at least 6 dB below the limits											

1. Device powered from console while console powered from AC mains.
2. Device powered from console while console powered from battery.
3. Device powered from its battery

Intertek Testing Services NA, Inc.

Table 2

Conducted Emissions / Interference On Console With 8' Copper Shield Power Cable)

Company: Abiomed, Inc. Description: Patient Console
 Engineer: Kouma Sinn Model #: 0034-4430
 Project #: 3058793 Location: 2C Serial #: AC7002
 Date: 05/21/04 Pressure: 1006 mbar Receiver: HP 8542E
 Temp: 19 deg. C Cable: CBL10MS3 7-15-04.cbl
 Standard: FCC Part 15.249 Humidity: 64% LISN 1, 2: LISN12 [1] 7-22-04.lsn LISN12 [2] 7-22-04.lsn
 Class: None Group: None LISN 3, N: None
 Preamp: None Attenuator: DS22A 7-08-04.att
 Voltage/Frequency: 120V/60Hz Frequency Range: 150kHz-30MHz
 Notes: Test was performed on Patient Console
 Net is the sum of worst-case lsn, cable, & attenuator losses, preamp gain, and initial reading
 Used absorbing clamp on LISN power cable

Frequency MHz	Reading Line 1 dB(uV)	Reading Line 2 dB(uV)	Reading Line 3 dB(uV)	Reading Neutral dB(uV)	Quasi-Peak		
					Net dB(uV)	Limit dB(uV)	Margin dB
1.964	27.5	N/A	N/A	27.4	48.2	56.0	-7.8
7.527	20.6	N/A	N/A	21.0	41.7	60.0	-18.3
7.854	25.2	N/A	N/A	25.9	46.6	60.0	-13.4
0.170	39.5	N/A	N/A	39.7	61.4	65.0	-3.5
0.226	34.0	N/A	N/A	32.7	55.4	62.6	-7.1
0.327	24.6	N/A	N/A	23.0	45.8	59.5	-13.7
0.568	18.5	N/A	N/A	18.6	39.4	56.0	-16.6
1.964	27.6	N/A	N/A	27.2	48.3	56.0	-7.7
2.292	24.6	N/A	N/A	24.7	45.3	56.0	-10.7
2.618	22.5	N/A	N/A	22.2	43.2	56.0	-12.8
2.944	20.5	N/A	N/A	20.5	41.2	56.0	-14.8
8.507	25.0	N/A	N/A	25.6	46.3	60.0	-13.7

Frequency MHz	Reading Line 1 dB(uV)	Reading Line 2 dB(uV)	Reading Line 3 dB(uV)	Reading Neutral dB(uV)	Average		
					Net dB(uV)	Limit dB(uV)	Margin dB
0.196	21.9	N/A	N/A	22.1	43.5	53.8	-10.3
7.527	16.8	N/A	N/A	17.3	38.0	50.0	-12.0
7.854	21.0	N/A	N/A	21.8	42.5	50.0	-7.5
0.170	31.7	N/A	N/A	31.6	53.6	55.0	-1.3
0.226	26.6	N/A	N/A	25.0	48.0	52.6	-4.5
0.327	23.2	N/A	N/A	22.1	44.4	49.5	-5.1
0.568	15.4	N/A	N/A	13.3	36.3	46.0	-9.7
1.964	22.0	N/A	N/A	21.9	42.7	46.0	-3.3
2.292	22.8	N/A	N/A	22.8	43.5	46.0	-2.5
2.618	21.4	N/A	N/A	21.0	42.1	46.0	-3.9
2.944	17.6	N/A	N/A	17.7	38.3	46.0	-7.7
8.507	21.3	N/A	N/A	21.9	42.6	50.0	-7.4

Table 2A

Intertek Testing Services NA, Inc.

Conducted Emissions / Interference On Console With 10' Copper Shield Power Cable)

Company: Abiomed, Inc.	Description: Patient Console	Model #: 0034-4430
Engineer: Kouma Sinn	Location: 2C	Serial #: AC7002
Project #: 3058793	Pressure: 1006 mbar	Receiver: HP 8542E
Date: 05/21/04	Temp: 19 deg. C	Cable: CBL10MS3 7-15-04.cbl
Standard: FCC Part 15.249	Humidity: 64%	LISN 1, 2: LISN12 [1] 7-22-04.lsn LISN12 [2] 7-22-04.lsn
Class: None	Group: NOne	LISN 3, N: None
Preamp: None	Attenuator: DS22A 7-08-04.att	
Voltage/Frequency: 120V/60Hz	Frequency Range: 150kHz-30MHz	
Notes: Test was performed on patient console		

Net is the sum of worst-case lsn, cable, & attenuator losses, preamp gain, and initial reading

Used absorbing clamp on LISN power cable

Frequency MHz	Reading Line 1 dB(uV)	Reading Line 2 dB(uV)	Reading Line 3 dB(uV)	Reading Neutral dB(uV)	Quasi-Peak		
					Net dB(uV)	Limit dB(uV)	Margin dB
1.964	17.9	N/A	N/A	17.7	38.6	56.0	-17.4
7.527	15.3	N/A	N/A	20.4	41.1	60.0	-18.9
7.854	23.0	N/A	N/A	27.4	48.1	60.0	-11.9
0.170	39.3	N/A	N/A	40.0	61.2	65.0	-3.7
0.226	32.4	N/A	N/A	34.0	54.3	62.6	-8.3
0.327	26.5	N/A	N/A	28.0	48.3	59.5	-11.2
0.568	17.7	N/A	N/A	18.2	38.6	56.0	-17.4
1.964	17.8	N/A	N/A	17.7	38.5	56.0	-17.5
2.292	15.7	N/A	N/A	16.1	36.6	56.0	-19.4
2.618	15.7	N/A	N/A	16.6	37.1	56.0	-18.9
2.944	13.5	N/A	N/A	13.7	34.2	56.0	-21.8
8.507	24.9	N/A	N/A	26.3	47.0	60.0	-13.0

Frequency MHz	Reading Line 1 dB(uV)	Reading Line 2 dB(uV)	Reading Line 3 dB(uV)	Reading Neutral dB(uV)	Average		
					Net dB(uV)	Limit dB(uV)	Margin dB
0.196	12.6	N/A	N/A	12.6	34.2	53.8	-19.6
7.527	11.3	N/A	N/A	16.6	37.3	50.0	-12.7
7.854	18.9	N/A	N/A	23.4	44.1	50.0	-5.9
0.170	31.4	N/A	N/A	31.4	53.3	55.0	-1.6
0.226	24.8	N/A	N/A	26.4	46.7	52.6	-5.9
0.327	25.3	N/A	N/A	26.7	47.0	49.5	-2.5
0.568	12.3	N/A	N/A	15.2	35.5	46.0	-10.5
1.964	12.8	N/A	N/A	12.4	33.5	46.0	-12.5
2.292	14.1	N/A	N/A	14.3	34.8	46.0	-11.2
2.618	13.8	N/A	N/A	13.8	34.5	46.0	-11.5
2.944	10.1	N/A	N/A	10.3	30.8	46.0	-15.2
8.507	21.2	N/A	N/A	22.6	43.3	50.0	-6.7

X - Duty Cycle (Average Factor)

Average factor is subtracted from peak readings to compare emissions readings to average limits. The average factor is calculated from duty cycle measurements from the following plots.

N/A-Average factor was not used since peak measurements passed the specified limits.

Intertek Testing Services NA, Inc.

XI - Bandwidth

The following plot(s) show bandwidth measurements made. The Bandwidth is the 99% power.

Not Applicable