

MT-9100CTM Cellular Tank Monitor - Enclosure Labeling

Model MT-9100CTM

Revision P2 (Scale = 2:1) - Page 1 of 2

Identification Label

INDEPENDENT TECHNOLOGIES, INC. OMAHA, NE - www.IndependentTech.com - PATENTS PENDING	
CELLULAR TANK MONITOR: MT-9100CTM S10 IMSI: 0000000000000000; H/W: 5; F/W: 3-2; T/C: 001821	S/N: 00008005 

0.50in.

3.50in.

Safety Certification Label

TANK MONITORING EQUIPMENT FOR USE IN CLASS I, DIVISION 1, GROUPS C&D HAZARDOUS (CLASSIFIED) LOCATIONS PER ANSI/UL 913 AND CAN/CSA C22.2 NO. 157; NO USER MAINTENANCE OR REPAIR - SEE DATA SHEET; TEMP CODE T4; $-40^{\circ}\text{C} \leq T_{\text{amb}} \leq +60^{\circ}\text{C}$; INTRINSICALLY SAFE DEVICE - SECURITE INTRINSEQUE - Exia	 LISTED 19WU
--	--

0.50in.

3.50in.

Print on Brady B486 metalized polyester label stock.


Print using Brady 4300 Series thermal transfer ribbon.

MT-9100CTM Cellular Tank Monitor - Enclosure Labeling

Model MT-9100CTM

Revision P2 (Scale = 2:1) - Page 2 of 2

Battery Pack and FCC/IC ID Label



Print on Brady B486 metalized polyester label stock.
Print using Brady 4300 Series thermal transfer ribbon.

Label Location

