

SMOKE ALARM: 3 Long beeps, repeating.

STANDBY: green LED blink every 60s.

FAULT: Amber LED blink every 5s, chirp every 30s.

LOW BATTERY: Amber LED blink every 5s, chirp every 60s.

END OF LIFE: Amber LED blink every 5s, chirp twice every 30s.

FREEZE WARNING: Red LED blink every 20 min.

Push button to test weekly.

See user guide for more information

Clean alarm openings annually
using vacuum or compressed air.

Product is sealed with no
serviceable parts.

Do not use where
ambient temp exceeds
100° F (37.8° C).

Constant exposure to
high/low temps or
high humidity may
lower battery life.
Power up time 15 sec.
Heat sensor rating:
Fixed 135° F (57° C).
Rate of rise
>15 °F/min (8.3 °C/min)
(after 85 °F/29.4 °C).
41°F freeze warning
notification to panel.



Model/Modèle SDX-135Z

DC Photoelectric Smoke/Fixed & Rate of Rise Heat
/Freeze Detector, with Wireless

Fumée photoélectrique CC / fixe et taux de
chaleur de montée / Freeze Detector, sans fil

SIGNALING

S1816

SIGNALISATION



LISTED

LISTED
HOMOLOGUE

SINGLE AND / OR MULTIPLE
STATION SMOKE ALARM.

AVERTISSEUR DE FUMÉE AUTONOME ET /
OU MULTIPONCTUEL.

ISSUE NO. 00000X

Smoke sensitivity : 2.32±1.35 %/ft OBS

YYYY, MMM, DD

0318-7101-00

For service return to:
UTC Fire & Security Americas
Corporation, Inc.
3211 Progress Drive,
Lincolnton, NC, 28092,
USA

10 year warranty.
Made in China.
0318-7101-00

ON

PERMANENTLY
DISABLE and
DISCHARGE
alarm

If unit chirps for
LOW BATTERY
or END OF LIFE:

- (1) Push in the dashed
area to break tab
- (2) Rotate slotted arrow
clockwise to PERMANENTLY
DISABLE and DISCHARGE
alarm location (necessary to
avoid lithium battery fire
hazard).
- (3) Install new alarm.



FCC ID: SAK25609702
IC: 7145A-25609702

SENSOR ID

0318-7101-00_SDx-135Z