

12 RF EXPOSURE COMPLIANCE

12.1LIMIT

Systems operating under the provisions of this section shall be operated in a manner that ensures that the public is not exposed to radio frequency energy levels in excess limit for maximum permissible exposure. In accordance with 47 CFR FCC Part 2 Subpart J, section 2.1091 this device has been defined as a mobile device whereby a distance of 0.2 m normally can be maintained between the user and the device.

(A) Limits for Occupational / Controlled Exposure

Frequency Range (MHz)		Magnetic Field Strength (H) (A/m)	Power Density (5)	Averaging Time E ², H ²or S (minutes)
0.3-3.0	614	1.63	(100)*	6
3.0-30	1842 / f	4.89 / f	(900 / f)*	6
30-300	61.4	0.163	1.0	6
300-1500			F/300	6
1500-100,000			5	6

(B) Limits for General Population / Uncontrolled Exposure

Frequency Range (MHz)		Magnetic Field Strength (H) (A/m)	Power Delisity (3)	Averaging Time $ E ^2$, $ H ^2$ or S (minutes)
0.3-1.34	614	1.63	(100)*	30
1.34-30	824/f	2.19/f	(180/f)*	30
30-300	27.5	0.073	0.2	30
300-1500			F/1500	30
1500-100,000			1.0	30

NOTE: f = frequency in MHz; *Plane-wave equivalent power density.

12.2MEASUREMENT INSTRUMENTS LIST

Item	Kind of Equipment	Manufacturer	Type No.	Serial No.	Calibrated until
1	Power Meter	Anritsu	ML2495A	1128008	Feb,20,2013
2	Power Meter Sensor	Anritsu	MA2411B	1126001	Feb,20,2013

NOTE: N/A: denotes No Model Name, No Serial No. or No Calibration specified.

12.3MPE CALCULATION METHOD

E (V/m)
$$=\frac{\sqrt{30\times P\times G}}{d}$$
 Power Density: Pd (W/m²) $=\frac{E^2}{377}$

 $\mathbf{E} = \text{Electric field (V/m)}$

P = Peak RF output power (W)

G = EUT Antenna numeric gain (numeric)

d = Separation distance between radiator and human body (m)

The formula can be changed to

$$Pd = \frac{30 \times P \times G}{377 \times d^2}$$

From the peak EUT RF output power, the minimum mobile separation distance, d=0.2m, as well as the gain of the used antenna, the RF power density can be obtained

Report No.: NEI-FCCP-1-1207196 Page 103 of 107



12.4TEST SETUP LAYOUT

EUT	Power Meter
EUI	Fower Meter

12.5 DEVIATION FROM TEST STANDARD

No deviation

12.6EUT OPERATING CONDITIONS

The EUT tested system was configured as the statements of 4.6 Unless otherwise a special operating condition is specified in the follows during the testing.

12.7TEST RESULTS

The power is so low so there is no need for RF calculations.

Report No.: NEI-FCCP-1-1207196 Page 104 of 107