

Test Report for FCC

FCC ID:TKWBIOSTATIONRHOC

Report Number		ESTF150711-007		
Applicant	Company name	Suprema Inc.		
	Address	16F Parkview Office Tower, Jeongja-dong, Bundang-gu, Seongnam, Gyeonggi, 463-863 Korea		
	Telephone	82-31-783-4505		
Product	Product name	FINGERPRINT SYSTEM		
	Model No.	BioStation (BSH-OC)	Manufacturer	Suprema Inc.
	Serial No.	NONE	Country of origin	Korea
Test date	21-Nov-07		Date of issue	6-Dec-07
Testing location	ESTECH. Co., Ltd. 97-1 Hoiuk-Ri Majang-Myon, Icheon-city, KyungKi-Do, Korea			
Standard	FCC Part 15 Subpart C , ANSI C 63.4 2003			
Measurement facility registration number	94696			
Tested by	Engineer J.H.Kim 			
Reviewed by	Engineering Manager J.M.Yang 			
Abbreviation	OK, Pass = Passed, Fail = Failed, N/A = not applicable			
<p>* Note</p> <ul style="list-style-type: none"> - This test report is not permitted to copy partly without our permission - This test result is dependent on only equipment to be used - This test result based on a single evaluation of one sample of the above mentioned 				

Contents

1. Laboratory Information	3
2. Description of EUT	4
3. Test Standards	5
4. Measurement condition	6
5. Measurement of radiated emission	8
5.1 Radiated emission limits, general requirements	8
5.2 Measurement equipment	8
5.3 Environmental conditions	8
5.4 Test data	9
6. Measurement of conducted emission	10
6.1 Measurement equipment	10
6.2 Environmental conditions	10
6.3 Test data	11
7. Photographs of test setup	12
8. Photographs of EUT	14

Appendix 1. Spectral diagram



1. Laboratory Information

1.1 General

This EUT (Equipment Under Test) has been shown to be capable of compliance with the applicable technical standards and is tested in accordance with the measurement procedures as indicated in this report. ESTECH Lab attests to accuracy of test data. All measurement reported herein were performed by ESTECH Co., Ltd.

ESTECH Lab assume full responsibility for the completeness of these measurements and vouch for the qualifications of all persons taking them.

1.2 Test Lab.

Corporation Name : ESTECH Co. Ltd

Head Office : Rm 1015, World Venture Center II, 426-5, Gasan-dong, Geumcheon-gu, Seoul, Korea
(Safety & Telecom. Test Lab)

EMC Test Lab : 58-1 Osan-Ri, GaNam-Myon, YeoJoo-Gun, KyungKi-Do, Korea
97-1 Hoiuk-Ri Majang-Myon, Icheon-city, KyungKi-Do, Korea

1.3 Official Qualification(s)

MIC : Granted Accreditation from Ministry of Information & Communication for EMC, Safety and Telecommunication

KOLAS : Accredited Lab By Korea Laboratory Accreditation Schema base on CENELEC requirements

FCC : Filed Laboratory at Federal Communications Commission

VCCI : Granted Accreditation from Voluntary Control Council for Interference from ITE

2. Description of EUT

2.1 Summary of Equipment Under Test

Product : FINGERPRINT SYSTEM
 Model Number : BioStation (BSH-OC)
 Serial Number : NONE
 Manufacturer : Suprema Inc.
 Country of origin : Korea
 Operating Frequency : 126KHz
 Antenna Type : Loop Coil
 Modulation Type : FSK
 Channel Spacing : 1
 Rating : AC input 100 ~ 240 VAC, 1.0A, 50/60Hz, DC output 12V - - 2.5A
 Receipt Date : 8-Oct-07
 X-tail lists : 12.5MHz, 16MHz, 20MHz, 5MHz

2.2 General descriptions of EUT

Specifications

- CPU : Dual CPU (32bit RISC + 400MHz DSP)
- Memory : 34MB flash + 34MB RAM
- Display : 2.5" QVGA 16M Color LCD
- Fingerprint identification speed : 3,000 match in 1 second
- Fingerprint capacity : 50,000 fingerprint templates
- Log capacity : 500,000 events
- Network interface : Wireless LAN (optional), TCP/IP, RS485
- PC interface : USB, RS232
- USB memory slot : USB Host
- Output relay : Deadbolt, EM lock, door strike, automatic door
- Wiegand I/O, 4 TTL I/O
- Microphone and speaker for door phone
- Navigation key for menu movement
- 4 Function keys for user-defined functions
- Operation modes : Fingerprint, PIN, PIN + Fingerprint
- Size: 135 x 128 x 50mm (W x H x D)

3. Test Standards

Test Standard : FCC PART 15 (2007)

This Standard sets out the regulations under which an intentional, unintentional, or incidental radiator may be operated without an individual license. It also contains the technical specifications, administrative requirements and other conditions relating to the marketing of Part 15 devices.

Test Method : ANSI C 63.4 (2003)

This standard sets forth uniform methods of measurement of radio -frequency (RF) signals and noise emitted from both unintentional and intentional emitters of RF energy in the frequency range 9 kHz to 40 GHz. Methods for the measurement of radiated and AC power-line conducted radio noise are covered and may be applied to any such equipment unless otherwise specified by individual equipment requirements. These methods cover measurement of certain devices that deliberately radiate energy, such as intentional emitters, but does not cover licensed transmitters. This standard is not intended for certification/approval of avionic equipment or for industrial, scientific, and medical (ISM) equipment. These methods apply to the measurement of individual units or systems comprised of multiple units.

Summary of Test Results


Applied Standard : 47 CFR Part 15, Subpart C				
Standard	Test Type	Result	Remark	Limit
15.207	AC Power Conducted Emission	Pass	Meet the requirement	
15.205	Restricted bands	Pass	Meet the requirement	
15.209	Radiated Emission	Pass	Meet the requirement	

4. Measurement Condition

4.1 EUT Operation.

The EUT was measured by transmitter mode continuously.

4.2 Configuration and Peripherals



4.3 EUT and Support equipment

Equipment Name	Model Name	S/N	Manufacturer	Remark (FCC ID)
FINGERPRINT SYSTEM	BioStation (BSH-OC)	NONE	Suprema Inc.	EUT
Adapter	JPW128	NONE	AULT Korea Corp.	

4.4 Cable Connecting

Start Equipment		End Equipment		Cable Standard		Remark
Name	I/O port	Name	I/O port	Length	Shielded	
FINGERPRINT SYSTEM	Power	Adapter	-	2	No	

5. Measurement of radiated disturbance

The EUT was placed on the top of a rotating table 0.8 meters above the ground at a 3 meter Open test site. The table was rotated 360 degrees to determine the position of the highest radiation. Then antenna is a loop antenna is fixed at one meter above the ground to determine the maximum value of the field strength. Both parallel and perpendicular of the antenna are set to make the measurement. For each suspected emission, the EUT was arranged to its worst case and then the table was turned from 0 degrees to 360 degrees to find the maximum reading. The test-receiver system was set to Peak Detect Function and Specified Bandwidth with Maximum Hold Mode.

5.1 Radiated emission limits, general requirements

Except as provided elsewhere in this Subpart, the emissions from an intentional radiator shall not exceed the field strength levels specified in the following table:

Frequency	Field Strength(microvolt/meter)	Distance(meter)
0.009 - 0.490	2400/F(KHz)	300
0.490 - 1.705	24000/F(KHz)	30
1.705 - 30	30	30
30 - 88	100**	3
88 - 216	150**	3
216 - 960	200**	3
Above 960	500	3

** Except as provided in paragraph (g), fundamental emissions from intentional radiators operating under this Section shall not be located in the frequency bands 54-72 MHz, 76-88 MHz, 174-216 MHz or 470-806 MHz. However, operation within these frequency bands is permitted under other sections of this Part, e.g., Sections 15.231 and 15.241

5.2 Measurement equipments

Equipment Name	Type	Manufacturer	Serial No.	Next Calibration date
Test Receive	ESPI7	Rohde & Schwarz	100005	2008. 01. 12
Loop Antenna	HFH2-Z2	Rohde & Schwarz	893103/024	2008. 10. 12
Turn Table	2087	EMCO	2129	-
Antenna Mast	2070-01	EMCO	9702-203	-
ANT Mast Controller	2090	EMCO	1535	-
Turn Table Controller	2090	EMCO	1535	-

5.3 Environmental Condition

Test Place : Open site(3m)
 Temperature (°C) : 12
 Humidity (%) : 46 %

5.4 Test data

Test Date : 21-Nov-07

Measurement Distance : 3 m

Frequency (MHz)	Reading (dBμV)	Position (V/H)	Height (m)	Correction Factor		Result Value		
				Ant Factor (dB)	Cable (dB)	Limit (dBμV/m)	Result (dBμV/m)	Margin (dB)
Emissions(Peak Detector)								
0.126	40.10	H	1.0	19.25	0.1	105.6	59.45	-46.15
0.378	20.90	V	1.0	19.19	0.1	96.1	40.22	-55.83
Remark	<p>H : Horizontal, V : Vertical *Below 30Mhz was applied Average Detector. *There was no detected Restricted bands. *The 300m limit was converted to 3m Limit using square factor(x) as it was found by measurements as follows; 3 m Limit(dBuV/m) = 20log(2400/F(KHz))+40log(300/3)= 20log(2400/125)+40log(300/3)</p>							

6. Measurement of conducted disturbance

The continuous disturbance voltage of AC Mains in the frequency from 0.15 to 30 MHz was measured in accordance to FCC Part 15 (2007). The test setup was made according to ANSI C 63.4 (2003) in a shielded. The EUT was placed on a non-conductive table at least 80 above the ground plan. A grounded vertical reference plane was positioned in a distance of 40cm from the EUT. The distance from the EUT to other metal surfaces was at least 0.8m. The EUT was only earthen by its power cord through the line impedance stabilizing network. The power cord has been bundled to a length of 1.0m.. The test receiver with Quasi Peak detector complies with CISPR 16.

6.1 Measurement equipments

Equipment Name	Type	Manufacturer	Serial No.	Next Calibration date
LISN	ESH3-Z5	Rohde & Schwarz	838979/010	2008. 2. 28
LISN	NNLA8120A	Schwarzbeck	8120161	2008. 2. 28
TEST Receiver	ESPI7	Rohde & Schwarz	100185	2008. 8. 27
Pulse Limiter	ESH3Z2	Rohde & Schwarz	NONE	-

6.2 Environmental Condition

Test Place : Shield Room
 Temperature (°C) : 21
 Humidity (%) : 41 %

6.3 Test data

Test Date : 21-Nov-07

Frequency (MHz)	Correction Factor		Line (H/N)	Quasi-peak Value			Average Value		
	Lisn (dB)	Cable (dB)		Limit (dB μ V)	Reading (dB μ V)	Result (dB μ V)	Limit (dB μ V)	Reading (dB μ V)	Result (dB)
0.16	0.10	0.0	H	65.26	24.75	24.86	55.26	19.63	19.74
0.19	0.10	0.0	H	63.86	35.15	35.28	53.86	27.23	27.36
0.20	0.10	0.0	N	63.74	38.02	38.15	53.74	30.27	30.40
0.26	0.10	0.1	H	61.37	34.96	35.13	51.37	25.35	25.52
0.33	0.10	0.1	N	59.53	28.11	28.32	49.53	21.54	21.75
0.39	0.10	0.1	H	57.98	28.57	28.82	47.98	20.95	21.20
0.59	0.10	0.2	H	56.00	27.65	27.95	46.00	23.11	23.41
0.65	0.10	0.2	H	56.00	31.61	31.91	46.00	24.62	24.92
0.85	0.10	0.2	N	56.00	28.08	28.38	46.00	24.25	24.55
0.98	0.10	0.2	H	56.00	25.62	25.92	46.00	19.90	20.20
1.38	0.10	0.2	N	56.00	24.53	24.87	46.00	19.12	19.46
1.57	0.10	0.3	H	56.00	23.92	24.28	46.00	18.49	18.85
15.32	0.43	0.8	H	60.00	29.03	30.26	50.00	9.72	10.95
16.42	0.49	0.8	N	60.00	28.47	29.76	50.00	20.89	22.18
20.04	0.80	0.8	H	60.00	30.95	32.55	50.00	17.07	18.67
22.05	0.80	0.8	N	60.00	32.69	34.33	50.00	27.06	28.70
26.04	1.00	0.9	N	60.00	32.10	34.00	50.00	18.65	20.55
26.26	1.11	0.9	H	60.00	30.33	32.34	50.00	18.81	20.82
Remark	H : Hot Line, N : Neutral Line								

7. Photographs of test setup

7.1 Setup for Radiated Test (below 30MHz)

[Front]



[Rear]



7.2 Setup for Conducted Test : 0.15 ~ 30 MHz

[Front]



[Rear]





ESTECH Co., Ltd.

Rm 1015, World Venture Center II,
426-5 Gasan-dong, Guncheon-gu,
Seoul, 158-803, Korea



**Electromagnetic
Interference
Test Report**

8.0 Photographs of EUT

[Front]



[Rear]





ESTECH Co., Ltd.

Rm 1015, World Venture Center II,
426-5 Gasan-dong, Guncheon-gu,
Seoul, 158-803, Korea



**Electromagnetic
Interference
Test Report**

8.1 Photographs of EUT

[Front]



[Rear]




Appendix 1. Spectral diagram

*HOT



RBW 9 kHz
MT 1 s

Att 10 dB AUTO PREAMP OFF




Comment: BioStation(BHS-OC) HOT
Date: 21.NOV.2007 13:00:22

*NEUTRAL



RBW 9 kHz
MT 1 s

Att 10 dB AUTO PREAMP OFF



Comment: BioStation(BHS-OC) NEUTRAL
Date: 21.NOV.2007 13:05:36

Appendix 2. Photographs of EUT in side PCB

