

| | |
|------------|------------------------|
| Applicant: | Kyocera |
| FCC ID: | V65E4255 |
| Report #: | CT-E4277-20RFC-0412-R0 |

Exhibit 12 Appendix C: HAC RF Data Plot

CELL – BC10

CDMA 835 BC-10 Channel 476

Date: 05/02/2012

Communication System: CDMA_Tri_BC0&10, Frequency: 817.9 MHz, Duty Cycle: 1:1
 Medium: Air, Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 1000$ kg/m³ Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 1$ kg/m³
 Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

DASY4 Configuration:

Probe: ER3DV6 - SN2341 Probe: H3DV5 - SN6029, ConvF(1, 1, 1), Calibrated: 7/12/2011 Calibrated: 7/20/2011

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/13/2011

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

Temperature: Room T = 21.8 +/- 1 deg C, Liquid T = 22.0 +/- 1 deg C

CELL_476/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 37.4 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 49.6 V/m; Power Drift = -0.349 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak E-field in V/m

| | | |
|--------------------------|--------------------------|--------------------------|
| Grid 1 31.9 M4 | Grid 2 32.9 M4 | Grid 3 31.2 M4 |
| Grid 4 37.7 M4 | Grid 5 37.4 M4 | Grid 6 33.4 M4 |
| Grid 7 35.0 M4 | Grid 8 35.7 M4 | Grid 9 33.1 M4 |

CELL_476/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.080 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.072 A/m; Power Drift = -0.245 dB


Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak H-field in A/m

| | | |
|---------------------------|---------------------------|---------------------------|
| Grid 1 0.102 M4 | Grid 2 0.079 M4 | Grid 3 0.058 M4 |
| Grid 4 0.104 M4 | Grid 5 0.080 M4 | Grid 6 0.059 M4 |
| Grid 7 0.104 M4 | Grid 8 0.079 M4 | Grid 9 0.058 M4 |



| | |
|------------|------------------------|
| Applicant: | Kyocera |
| FCC ID: | V65E4255 |
| Report #: | CT-E4277-20RFC-0412-R0 |



0 dB = 37.7V/m

CDMA 835 BC-10 Channel 580

Date: 05/02/2012

Communication System: CDMA_Tri_BC0&10, Frequency: 820.5 MHz, Duty Cycle: 1:1
 Medium: Air, Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 1000$ kg/m³ Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 1$ kg/m³
 Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

DASY4 Configuration:

Probe: ER3DV6 - SN2341 Probe: H3DV5 - SN6029, ConvF(1, 1, 1), Calibrated: 7/12/2011 Calibrated: 7/20/2011

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/13/2011

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

Temperature: Room T = 21.8 +/- 1 deg C, Liquid T = 22.0 +/- 1 deg C

CELL_580/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 39.4 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 55.2 V/m; Power Drift = -0.610 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak E-field in V/m

| | | |
|--------------------------|--------------------------|--------------------------|
| Grid 1 35.2 M4 | Grid 2 36.3 M4 | Grid 3 33.7 M4 |
| Grid 4 38.1 M4 | Grid 5 39.4 M4 | Grid 6 36.6 M4 |
| Grid 7 37.9 M4 | Grid 8 39.0 M4 | Grid 9 36.1 M4 |

CELL_580/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.082 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.073 A/m; Power Drift = -0.183 dB


Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak H-field in A/m

| | | |
|---------------------------|---------------------------|---------------------------|
| Grid 1 0.108 M4 | Grid 2 0.082 M4 | Grid 3 0.060 M4 |
| Grid 4 0.112 M4 | Grid 5 0.082 M4 | Grid 6 0.060 M4 |
| Grid 7 0.112 M4 | Grid 8 0.081 M4 | Grid 9 0.060 M4 |



| | |
|------------|------------------------|
| Applicant: | Kyocera |
| FCC ID: | V65E4255 |
| Report #: | CT-E4277-20RFC-0412-R0 |



0 dB = 39.4V/m

CDMA 835 BC-10 Channel 684

Date: 05/02/2012

Communication System: CDMA_Tri_BC0&10, Frequency: 823.1 MHz, Duty Cycle: 1:1
 Medium: Air, Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 1000$ kg/m³ Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 1$ kg/m³
 Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

DASY4 Configuration:

Probe: ER3DV6 - SN2341 Probe: H3DV5 - SN6029, ConvF(1, 1, 1), Calibrated: 7/12/2011 Calibrated: 7/20/2011

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/13/2011

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

Temperature: Room T = 21.8 +/- 1 deg C, Liquid T = 22.0 +/- 1 deg C

CELL_684/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 40.8 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 53.7 V/m; Power Drift = -0.234 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak E-field in V/m

| | | |
|--------------------------|--------------------------|--------------------------|
| Grid 1 35.2 M4 | Grid 2 37.5 M4 | Grid 3 33.9 M4 |
| Grid 4 37.9 M4 | Grid 5 40.8 M4 | Grid 6 35.8 M4 |
| Grid 7 37.9 M4 | Grid 8 40.0 M4 | Grid 9 34.8 M4 |

CELL_684/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.080 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.070 A/m; Power Drift = 0.025 dB


Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak H-field in A/m

| | | |
|---------------------------|---------------------------|---------------------------|
| Grid 1 0.102 M4 | Grid 2 0.078 M4 | Grid 3 0.057 M4 |
| Grid 4 0.106 M4 | Grid 5 0.080 M4 | Grid 6 0.059 M4 |
| Grid 7 0.107 M4 | Grid 8 0.080 M4 | Grid 9 0.059 M4 |




| | |
|------------|------------------------|
| Applicant: | Kyocera |
| FCC ID: | V65E4255 |
| Report #: | CT-E4277-20RFC-0412-R0 |



0 dB = 40.8V/m

CDMA 835 Channel 684 (360) E roll



| | |
|------------|------------------------|
| Applicant: | Kyocera |
| FCC ID: | V65E4255 |
| Report #: | CT-E4277-20RFC-0412-R0 |

CELL – BC0

CDMA 835 BC-0 Channel 1013

Date: 05/02/2012

Communication System: CDMA_Tri_BC0&10, Frequency: 824.7 MHz, Duty Cycle: 1:1
 Medium: Air, Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 1000$ kg/m³ Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 1$ kg/m³
 Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

DASY4 Configuration:

Probe: ER3DV6 - SN2341 Probe: H3DV5 - SN6029, ConvF(1, 1, 1), Calibrated: 7/12/2011 Calibrated: 7/20/2011

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/13/2011

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

Temperature: Room T = 21.8 +/- 1 deg C, Liquid T = 22.0 +/- 1 deg C

CELL_1013/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 40.3 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 53.2 V/m; Power Drift = -0.148 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak E-field in V/m

| | | |
|--------------------------|--------------------------|--------------------------|
| Grid 1 36.0 M4 | Grid 2 37.4 M4 | Grid 3 34.7 M4 |
| Grid 4 38.7 M4 | Grid 5 40.3 M4 | Grid 6 37.2 M4 |
| Grid 7 38.3 M4 | Grid 8 39.6 M4 | Grid 9 36.6 M4 |

CELL_1013/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.082 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.072 A/m; Power Drift = -0.109 dB


Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak H-field in A/m

| | | |
|---------------------------|---------------------------|---------------------------|
| Grid 1 0.103 M4 | Grid 2 0.080 M4 | Grid 3 0.059 M4 |
| Grid 4 0.107 M4 | Grid 5 0.081 M4 | Grid 6 0.061 M4 |
| Grid 7 0.108 M4 | Grid 8 0.082 M4 | Grid 9 0.061 M4 |



| | |
|------------|------------------------|
| Applicant: | Kyocera |
| FCC ID: | V65E4255 |
| Report #: | CT-E4277-20RFC-0412-R0 |



0 dB = 40.3V/m

CDMA 835 BC-0 Channel 384

Date: 05/02/2012

Communication System: CDMA_Tri_BC0&10, Frequency: 836.52 MHz, Duty Cycle: 1:1

Medium: Air, Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 1000$ kg/m³ Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 1$ kg/m³

Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

DASY4 Configuration:

Probe: ER3DV6 - SN2341 Probe: H3DV5 - SN6029, ConvF(1, 1, 1), Calibrated: 7/12/2011 Calibrated: 7/20/2011

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/13/2011

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

Temperature: Room T = 21.8 +/- 1 deg C, Liquid T = 22.0 +/- 1 deg C

CELL_384/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 44.8 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 58.6 V/m; Power Drift = -0.011 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak E-field in V/m

| | | |
|--------------------------|--------------------------|--------------------------|
| Grid 1 36.8 M4 | Grid 2 40.0 M4 | Grid 3 38.6 M4 |
| Grid 4 41.3 M4 | Grid 5 44.8 M4 | Grid 6 43.0 M4 |
| Grid 7 41.8 M4 | Grid 8 44.8 M4 | Grid 9 42.7 M4 |

CELL_384/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.089 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.078 A/m; Power Drift = 0.119 dB


Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak H-field in A/m

| | | |
|---------------------------|---------------------------|---------------------------|
| Grid 1 0.114 M4 | Grid 2 0.089 M4 | Grid 3 0.062 M4 |
| Grid 4 0.122 M4 | Grid 5 0.089 M4 | Grid 6 0.062 M4 |
| Grid 7 0.124 M4 | Grid 8 0.089 M4 | Grid 9 0.061 M4 |



| | |
|------------|------------------------|
| Applicant: | Kyocera |
| FCC ID: | V65E4255 |
| Report #: | CT-E4277-20RFC-0412-R0 |



0 dB = 44.8V/m

CDMA 835 BC-0 Channel 777

Date: 05/02/2012

Communication System: CDMA_Tri_BC0&10, Frequency: 848.31 MHz, Duty Cycle: 1:1
 Medium: Air, Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 1000$ kg/m³ Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 1$ kg/m³
 Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

DASY4 Configuration:

Probe: ER3DV6 - SN2341 Probe: H3DV5 - SN6029, ConvF(1, 1, 1), Calibrated: 7/12/2011 Calibrated: 7/20/2011

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/13/2011

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

Temperature: Room T = 21.8 +/- 1 deg C, Liquid T = 22.0 +/- 1 deg C

CELL_777/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 46.0 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 60.1 V/m; Power Drift = -0.056 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak E-field in V/m

| | | |
|--------------------------|--------------------------|--------------------------|
| Grid 1 38.6 M4 | Grid 2 42.0 M4 | Grid 3 41.3 M4 |
| Grid 4 42.1 M4 | Grid 5 46.0 M4 | Grid 6 45.0 M4 |
| Grid 7 42.1 M4 | Grid 8 45.8 M4 | Grid 9 44.7 M4 |

CELL_777/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.082 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.067 A/m; Power Drift = 0.163 dB


Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak H-field in A/m

| | | |
|---------------------------|---------------------------|---------------------------|
| Grid 1 0.099 M4 | Grid 2 0.075 M4 | Grid 3 0.050 M4 |
| Grid 4 0.109 M4 | Grid 5 0.079 M4 | Grid 6 0.054 M4 |
| Grid 7 0.112 M4 | Grid 8 0.082 M4 | Grid 9 0.058 M4 |




| | |
|------------|------------------------|
| Applicant: | Kyocera |
| FCC ID: | V65E4255 |
| Report #: | CT-E4277-20RFC-0412-R0 |



0 dB = 46.0V/m

CDMA 835 Channel 777 (360) E roll





| | |
|------------|------------------------|
| Applicant: | Kyocera |
| FCC ID: | V65E4255 |
| Report #: | CT-E4277-20RFC-0412-R0 |

PCS

CDMA 1900 Channel 25

Date: 05/02/2012

Communication System: CDMA_Tri_BC0&10, Frequency: 1850 MHz, Duty Cycle: 1:1
 Medium: Air, Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 1000$ kg/m³ Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 1$ kg/m³
 Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

DASY4 Configuration:

Probe: ER3DV6 - SN2341 Probe: H3DV5 - SN6029, ConvF(1, 1, 1), Calibrated: 7/12/2011 Calibrated: 7/20/2011

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/13/2011

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

Temperature: Room T = 21.8 +/- 1 deg C, Liquid T = 22.0 +/- 1 deg C

PCS_25/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 41.2 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 54.9 V/m; Power Drift = -0.437 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak E-field in V/m

| | | |
|----------------|----------------|----------------|
| Grid 1 | Grid 2 | Grid 3 |
| 29.0 M4 | 39.0 M4 | 39.0 M4 |
| Grid 4 | Grid 5 | Grid 6 |
| 30.5 M4 | 41.2 M4 | 41.2 M4 |
| Grid 7 | Grid 8 | Grid 9 |
| 29.8 M4 | 40.1 M4 | 39.9 M4 |

PCS_25/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.151 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.141 A/m; Power Drift = -0.085 dB


Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak H-field in A/m

| | | |
|-----------------|-----------------|-----------------|
| Grid 1 | Grid 2 | Grid 3 |
| 0.166 M4 | 0.151 M4 | 0.112 M4 |
| Grid 4 | Grid 5 | Grid 6 |
| 0.165 M4 | 0.151 M4 | 0.112 M4 |
| Grid 7 | Grid 8 | Grid 9 |
| 0.161 M4 | 0.146 M4 | 0.106 M4 |



| | |
|------------|------------------------|
| Applicant: | Kyocera |
| FCC ID: | V65E4255 |
| Report #: | CT-E4277-20RFC-0412-R0 |



CDMA 1900 Channel 600

Date: 05/02/2012

Communication System: CDMA_Tri_BC0&10, Frequency: 1880 MHz, Duty Cycle: 1:1
 Medium: Air, Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 1000$ kg/m³ Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 1$ kg/m³
 Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

DASY4 Configuration:

Probe: ER3DV6 - SN2341 Probe: H3DV5 - SN6029, ConvF(1, 1, 1), Calibrated: 7/12/2011 Calibrated: 7/20/2011

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/13/2011

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

Temperature: Room T = 21.8 +/- 1 deg C, Liquid T = 22.0 +/- 1 deg C

PCS_600/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 46.7 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 56.8 V/m; Power Drift = 0.081 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak E-field in V/m

| | | |
|--------------------------|--------------------------|--------------------------|
| Grid 1 33.3 M4 | Grid 2 43.2 M4 | Grid 3 43.2 M4 |
| Grid 4 35.5 M4 | Grid 5 46.7 M4 | Grid 6 46.7 M4 |
| Grid 7 34.9 M4 | Grid 8 46.4 M4 | Grid 9 46.4 M4 |

PCS_600/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.154 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.134 A/m; Power Drift = 0.291 dB


Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak H-field in A/m

| | | |
|---------------------------|---------------------------|---------------------------|
| Grid 1 0.157 M4 | Grid 2 0.138 M4 | Grid 3 0.099 M4 |
| Grid 4 0.165 M4 | Grid 5 0.152 M4 | Grid 6 0.106 M4 |
| Grid 7 0.168 M4 | Grid 8 0.154 M4 | Grid 9 0.111 M4 |



| | |
|------------|------------------------|
| Applicant: | Kyocera |
| FCC ID: | V65E4255 |
| Report #: | CT-E4277-20RFC-0412-R0 |



0 dB = 46.7V/m

CDMA 1900 Channel 1175

Date: 05/02/2012

Communication System: CDMA_Tri_BC0&10, Frequency: 1910 MHz, Duty Cycle: 1:1
 Medium: Air, Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 1000$ kg/m³ Medium parameters used: $\sigma = 0$ mho/m, $\epsilon_r = 1$; $\rho = 1$ kg/m³
 Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

DASY4 Configuration:

Probe: ER3DV6 - SN2341 Probe: H3DV5 - SN6029, ConvF(1, 1, 1), Calibrated: 7/12/2011 Calibrated: 7/20/2011

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/13/2011

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

Temperature: Room T = 21.8 +/- 1 deg C, Liquid T = 22.0 +/- 1 deg C

PCS_1175/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 45.8 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 57.5 V/m; Power Drift = 0.056 dB

Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak E-field in V/m

| | | |
|----------------|----------------|----------------|
| Grid 1 | Grid 2 | Grid 3 |
| 34.5 M4 | 44.3 M4 | 44.2 M4 |
| Grid 4 | Grid 5 | Grid 6 |
| 34.9 M4 | 45.8 M4 | 45.7 M4 |
| Grid 7 | Grid 8 | Grid 9 |
| 32.9 M4 | 44.0 M4 | 44.0 M4 |

PCS_1175/Hearing Aid Compatibility Test (101x101x1): Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.175 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.166 A/m; Power Drift = -0.033 dB


Hearing Aid Near-Field Category: M4 (AWF 0 dB)

Peak H-field in A/m

| | | |
|-----------------|-----------------|-----------------|
| Grid 1 | Grid 2 | Grid 3 |
| 0.182 M4 | 0.168 M4 | 0.126 M4 |
| Grid 4 | Grid 5 | Grid 6 |
| 0.188 M4 | 0.175 M4 | 0.132 M4 |
| Grid 7 | Grid 8 | Grid 9 |
| 0.187 M4 | 0.175 M4 | 0.131 M4 |



| | |
|------------|------------------------|
| Applicant: | Kyocera |
| FCC ID: | V65E4255 |
| Report #: | CT-E4277-20RFC-0412-R0 |



0 dB = 45.8V/m

CDMA 1900 Channel 600 (360) E roll

