



Applicant:	Kyocera
FCC ID:	V65S2150
Report #:	CT-S2150-20RFC-1112-R0

# CELL

**CDMA 835 Channel 1013**

Date: 11/07/2012

Communication System: CDMA\_Tri\_BC0&10, Frequency: 824.7 MHz, Duty Cycle: 1:1  
 Medium: Air, Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup> Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>

Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

**DASY4 Configuration:**

Probe: ER3DV6 - SN2282 Probe: H3DV6 - SN6123, ConvF(1, 1, 1), Calibrated: 2/17/2012

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/30/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

**Temperature:**

Room T = 21.8 °C, Liquid T = 22.0 °C

**CELL\_1013/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 72.3 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 94.4 V/m; Power Drift = -0.096 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak E-field in V/m

Grid 1 <b>65.0 M4</b>	Grid 2 <b>67.7 M4</b>	Grid 3 <b>62.7 M4</b>
Grid 4 <b>69.0 M4</b>	Grid 5 <b>72.3 M4</b>	Grid 6 <b>65.7 M4</b>
Grid 7 <b>68.6 M4</b>	Grid 8 <b>70.9 M4</b>	Grid 9 <b>64.8 M4</b>

**CELL\_1013/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.106 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.090 A/m; Power Drift = -0.021 dB


**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak H-field in A/m

Grid 1 <b>0.151 M4</b>	Grid 2 <b>0.106 M4</b>	Grid 3 <b>0.069 M4</b>
Grid 4 <b>0.147 M4</b>	Grid 5 <b>0.105 M4</b>	Grid 6 <b>0.071 M4</b>
Grid 7 <b>0.142 M4</b>	Grid 8 <b>0.104 M4</b>	Grid 9 <b>0.072 M4</b>



Applicant:	Kyocera
FCC ID:	V65S2150
Report #:	CT-S2150-20RFC-1112-R0



0 dB = 72.3V/m

**CDMA 835 Channel 384**

Date: 11/07/2012

Communication System: CDMA\_Tri\_BC0&10, Frequency: 836.52 MHz, Duty Cycle: 1:1  
 Medium: Air, Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup> Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>  
 Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

**DASY4 Configuration:**

Probe: ER3DV6 - SN2282 Probe: H3DV6 - SN6123, ConvF(1, 1, 1), Calibrated: 2/17/2012

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/30/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

**Temperature:**

Room T = 21.8 °C, Liquid T = 22.0 °C

**CELL\_384/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 67.6 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 85.5 V/m; Power Drift = 0.024 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak E-field in V/m

Grid 1	Grid 2	Grid 3
<b>58.8 M4</b>	<b>61.9 M4</b>	<b>58.7 M4</b>
Grid 4	Grid 5	Grid 6
<b>64.3 M4</b>	<b>67.6 M4</b>	<b>63.4 M4</b>
Grid 7	Grid 8	Grid 9
<b>64.6 M4</b>	<b>67.7 M4</b>	<b>62.3 M4</b>

**CELL\_384/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.093 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.079 A/m; Power Drift = -0.061 dB


**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak H-field in A/m

Grid 1	Grid 2	Grid 3
<b>0.131 M4</b>	<b>0.093 M4</b>	<b>0.061 M4</b>
Grid 4	Grid 5	Grid 6
<b>0.128 M4</b>	<b>0.092 M4</b>	<b>0.061 M4</b>
Grid 7	Grid 8	Grid 9
<b>0.128 M4</b>	<b>0.093 M4</b>	<b>0.063 M4</b>



Applicant:	Kyocera
FCC ID:	V65S2150
Report #:	CT-S2150-20RFC-1112-R0



**CDMA 835 Channel 777**

Date: 11/07/2012

Communication System: CDMA\_Tri\_BC0&10, Frequency: 848.31 MHz, Duty Cycle: 1:1  
 Medium: Air, Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup> Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>  
 Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

**DASY4 Configuration:**

Probe: ER3DV6 - SN2282 Probe: H3DV6 - SN6123, ConvF(1, 1, 1), Calibrated: 2/17/2012  
 Sensor-Surface: (Fix Surface),  
 Electronics: DAE4 Sn527, Calibrated: 7/30/2012  
 Measurement SW: DASY4, V4.7 Build 80  
 Postprocessing SW: SEMCAD, V1.8 Build 186

**Temperature:**

Room T = 21.8  $\square\square\square$  1 deg C, Liquid T = 22.0  $\square\square\square$  1 deg C

**CELL\_777/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 77.2 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 100.4 V/m; Power Drift = -0.098 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak E-field in V/m

Grid 1 <b>67.2 M4</b>	Grid 2 <b>71.6 M4</b>	Grid 3 <b>67.3 M4</b>
Grid 4 <b>73.9 M4</b>	Grid 5 <b>77.2 M4</b>	Grid 6 <b>73.4 M4</b>
Grid 7 <b>74.0 M4</b>	Grid 8 <b>77.2 M4</b>	Grid 9 <b>72.7 M4</b>

**CELL\_777/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.084 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.067 A/m; Power Drift = -0.084 dB


**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak H-field in A/m

Grid 1 <b>0.116 M4</b>	Grid 2 <b>0.082 M4</b>	Grid 3 <b>0.057 M4</b>
Grid 4 <b>0.110 M4</b>	Grid 5 <b>0.078 M4</b>	Grid 6 <b>0.054 M4</b>
Grid 7 <b>0.114 M4</b>	Grid 8 <b>0.084 M4</b>	Grid 9 <b>0.060 M4</b>




Applicant:	Kyocera
FCC ID:	V65S2150
Report #:	CT-S2150-20RFC-1112-R0





Applicant:	Kyocera
FCC ID:	V65S2150
Report #:	CT-S2150-20RFC-1112-R0

**CDMA 835 Channel 777 (360) E roll**







Applicant:	Kyocera
FCC ID:	V65S2150
Report #:	CT-S2150-20RFC-1112-R0

**AWS**

**CDMA 1700 Channel 25**

Date: 11/07/2012

Communication System: CDMA\_Tri\_BC0&10, Frequency: 1711.25 MHz, Duty Cycle: 1:1  
 Medium: Air, Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup> Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>

Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

**DASY4 Configuration:**

Probe: ER3DV6 - SN2282 Probe: H3DV6 - SN6123, ConvF(1, 1, 1), Calibrated: 2/17/2012

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/30/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

**Temperature:**

Room T = 21.8 °C ± 1 deg C, Liquid T = 22.0 °C ± 1 deg C

**AWS\_25/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 14.9 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 20.2 V/m; Power Drift = 0.110 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak E-field in V/m

Grid 1 <b>10.4 M4</b>	Grid 2 <b>13.2 M4</b>	Grid 3 <b>13.4 M4</b>
Grid 4 <b>14.0 M4</b>	Grid 5 <b>14.9 M4</b>	Grid 6 <b>14.8 M4</b>
Grid 7 <b>14.1 M4</b>	Grid 8 <b>14.7 M4</b>	Grid 9 <b>14.6 M4</b>

**AWS\_25/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.046 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.037 A/m; Power Drift = 0.069 dB


**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak H-field in A/m

Grid 1 <b>0.053 M4</b>	Grid 2 <b>0.046 M4</b>	Grid 3 <b>0.035 M4</b>
Grid 4 <b>0.055 M4</b>	Grid 5 <b>0.042 M4</b>	Grid 6 <b>0.030 M4</b>
Grid 7 <b>0.056 M4</b>	Grid 8 <b>0.042 M4</b>	Grid 9 <b>0.029 M4</b>



Applicant:	Kyocera
FCC ID:	V65S2150
Report #:	CT-S2150-20RFC-1112-R0



**CDMA 1700 Channel 450**

Date: 11/07/2012

Communication System: CDMA\_Tri\_BC0&10, Frequency: 1732.5 MHz, Duty Cycle: 1:1  
 Medium: Air, Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup> Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>  
 Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

**DASY4 Configuration:**

Probe: ER3DV6 - SN2282 Probe: H3DV6 - SN6123, ConvF(1, 1, 1), Calibrated: 2/17/2012  
 Sensor-Surface: (Fix Surface),  
 Electronics: DAE4 Sn527, Calibrated: 7/30/2012  
 Measurement SW: DASY4, V4.7 Build 80  
 Postprocessing SW: SEMCAD, V1.8 Build 186

**Temperature:**

Room T = 21.8 °C ± 1 deg C, Liquid T = 22.0 °C ± 1 deg C

**AWS\_450/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 17.1 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 20.8 V/m; Power Drift = -0.135 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak E-field in V/m

Grid 1 <b>13.3 M4</b>	Grid 2 <b>13.9 M4</b>	Grid 3 <b>14.2 M4</b>
Grid 4 <b>14.0 M4</b>	Grid 5 <b>17.0 M4</b>	Grid 6 <b>17.1 M4</b>
Grid 7 <b>15.4 M4</b>	Grid 8 <b>17.0 M4</b>	Grid 9 <b>17.1 M4</b>

**AWS\_450/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.048 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.040 A/m; Power Drift = -0.137 dB


**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak H-field in A/m

Grid 1 <b>0.055 M4</b>	Grid 2 <b>0.048 M4</b>	Grid 3 <b>0.043 M4</b>
Grid 4 <b>0.055 M4</b>	Grid 5 <b>0.045 M4</b>	Grid 6 <b>0.039 M4</b>
Grid 7 <b>0.055 M4</b>	Grid 8 <b>0.040 M4</b>	Grid 9 <b>0.028 M4</b>



Applicant:	Kyocera
FCC ID:	V65S2150
Report #:	CT-S2150-20RFC-1112-R0



Applicant:	Kyocera
FCC ID:	V65S2150
Report #:	CT-S2150-20RFC-1112-R0

**CDMA 1700 Channel 875**

Date: 11/07/2012

Communication System: CDMA\_Tri\_BC0&10, Frequency: 1753.75 MHz, Duty Cycle: 1:1  
 Medium: Air, Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup> Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>  
 Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

**DASY4 Configuration:**

Probe: ER3DV6 - SN2282 Probe: H3DV6 - SN6123, ConvF(1, 1, 1), Calibrated: 2/17/2012  
 Sensor-Surface: (Fix Surface),  
 Electronics: DAE4 Sn527, Calibrated: 7/30/2012  
 Measurement SW: DASY4, V4.7 Build 80  
 Postprocessing SW: SEMCAD, V1.8 Build 186

**Temperature:**

Room T = 21.8 +/- 1 deg C, Liquid T = 22.0 +/- 1 deg C

**AWS\_875/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 17.1 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 22.2 V/m; Power Drift = 0.021 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak E-field in V/m

Grid 1 <b>10.8 M4</b>	Grid 2 <b>13.0 M4</b>	Grid 3 <b>13.2 M4</b>
Grid 4 <b>14.6 M4</b>	Grid 5 <b>17.1 M4</b>	Grid 6 <b>17.0 M4</b>
Grid 7 <b>15.3 M4</b>	Grid 8 <b>17.3 M4</b>	Grid 9 <b>17.1 M4</b>

**AWS\_875/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.054 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.045 A/m; Power Drift = 0.102 dB


**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak H-field in A/m

Grid 1 <b>0.059 M4</b>	Grid 2 <b>0.054 M4</b>	Grid 3 <b>0.046 M4</b>
Grid 4 <b>0.055 M4</b>	Grid 5 <b>0.051 M4</b>	Grid 6 <b>0.042 M4</b>
Grid 7 <b>0.050 M4</b>	Grid 8 <b>0.041 M4</b>	Grid 9 <b>0.032 M4</b>




Applicant:	Kyocera
FCC ID:	V65S2150
Report #:	CT-S2150-20RFC-1112-R0





Applicant:	Kyocera
FCC ID:	V65S2150
Report #:	CT-S2150-20RFC-1112-R0

**CDMA 1700 Channel 875 (360) E roll**







Applicant:	Kyocera
FCC ID:	V65S2150
Report #:	CT-S2150-20RFC-1112-R0

## PCS

Applicant:	Kyocera
FCC ID:	V65S2150
Report #:	CT-S2150-20RFC-1112-R0

**CDMA 1900 Channel 25**

Date: 11/07/2012

Communication System: CDMA\_Tri\_BC0&10, Frequency: 1850 MHz, Duty Cycle: 1:1  
 Medium: Air, Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup> Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>  
 Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

**DASY4 Configuration:**

Probe: ER3DV6 - SN2282 Probe: H3DV6 - SN6123, ConvF(1, 1, 1), Calibrated: 2/17/2012

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/30/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

**Temperature:**

Room T = 21.8 +/- 1 deg C, Liquid T = 22.0 +/- 1 deg C

**PCS\_25/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 15.3 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 18.8 V/m; Power Drift = 0.056 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak E-field in V/m

Grid 1	Grid 2	Grid 3
<b>13.9 M4</b>	<b>13.1 M4</b>	<b>14.2 M4</b>
Grid 4	Grid 5	Grid 6
<b>13.4 M4</b>	<b>15.3 M4</b>	<b>14.8 M4</b>
Grid 7	Grid 8	Grid 9
<b>14.4 M4</b>	<b>15.8 M4</b>	<b>15.0 M4</b>

**PCS\_25/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.072 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.061 A/m; Power Drift = -0.002 dB


**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak H-field in A/m

Grid 1	Grid 2	Grid 3
<b>0.075 M4</b>	<b>0.072 M4</b>	<b>0.059 M4</b>
Grid 4	Grid 5	Grid 6
<b>0.069 M4</b>	<b>0.068 M4</b>	<b>0.057 M4</b>
Grid 7	Grid 8	Grid 9
<b>0.057 M4</b>	<b>0.056 M4</b>	<b>0.047 M4</b>



Applicant:	Kyocera
FCC ID:	V65S2150
Report #:	CT-S2150-20RFC-1112-R0



**CDMA 1900 Channel 600**

Date: 11/07/2012

Communication System: CDMA\_Tri\_BC0&10, Frequency: 1880 MHz, Duty Cycle: 1:1  
 Medium: Air, Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup> Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>  
 Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

**DASY4 Configuration:**

Probe: ER3DV6 - SN2282 Probe: H3DV6 - SN6123, ConvF(1, 1, 1), Calibrated: 2/17/2012

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/30/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

**Temperature:**

Room T = 21.8 +/- 1 deg C, Liquid T = 22.0 +/- 1 deg C

**PCS\_600/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 20.0 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 19.3 V/m; Power Drift = -0.016 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak E-field in V/m

Grid 1 <b>20.0 M4</b>	Grid 2 <b>17.0 M4</b>	Grid 3 <b>14.2 M4</b>
Grid 4 <b>17.1 M4</b>	Grid 5 <b>19.2 M4</b>	Grid 6 <b>19.2 M4</b>
Grid 7 <b>19.8 M4</b>	Grid 8 <b>20.8 M4</b>	Grid 9 <b>20.3 M4</b>

**PCS\_600/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.072 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.069 A/m; Power Drift = -0.079 dB


**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak H-field in A/m

Grid 1 <b>0.072 M4</b>	Grid 2 <b>0.072 M4</b>	Grid 3 <b>0.066 M4</b>
Grid 4 <b>0.072 M4</b>	Grid 5 <b>0.071 M4</b>	Grid 6 <b>0.065 M4</b>
Grid 7 <b>0.062 M4</b>	Grid 8 <b>0.059 M4</b>	Grid 9 <b>0.050 M4</b>



Applicant:	Kyocera
FCC ID:	V65S2150
Report #:	CT-S2150-20RFC-1112-R0



**CDMA 1900 Channel 1175**

Date: 11/07/2012

Communication System: CDMA\_Tri\_BC0&10, Frequency: 1910 MHz, Duty Cycle: 1:1  
 Medium: Air, Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1000$  kg/m<sup>3</sup> Medium parameters used:  $\sigma = 0$  mho/m,  $\epsilon_r = 1$ ;  $\rho = 1$  kg/m<sup>3</sup>  
 Phantom: HAC Test Arch with AMCC, Phantom section: RF Section

**DASY4 Configuration:**

Probe: ER3DV6 - SN2282 Probe: H3DV6 - SN6123, ConvF(1, 1, 1), Calibrated: 2/17/2012

Sensor-Surface: (Fix Surface),

Electronics: DAE4 Sn527, Calibrated: 7/30/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

**Temperature:**

Room T = 21.8 +/- 1 deg C, Liquid T = 22.0 +/- 1 deg C

**PCS\_1175/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 13.4 V/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 13.8 V/m; Power Drift = -0.079 dB

**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak E-field in V/m

Grid 1 <b>19.4 M4</b>	Grid 2 <b>19.4 M4</b>	Grid 3 <b>15.9 M4</b>
Grid 4 <b>13.3 M4</b>	Grid 5 <b>13.4 M4</b>	Grid 6 <b>13.0 M4</b>
Grid 7 <b>12.9 M4</b>	Grid 8 <b>12.8 M4</b>	Grid 9 <b>12.8 M4</b>

**PCS\_1175/Hearing Aid Compatibility Test (101x101x1):** Measurement grid: dx=5mm, dy=5mm

Maximum value of peak Total field = 0.051 A/m

Probe Modulation Factor = 1.00

Device Reference Point: 0.000, 0.000, -6.30 mm

Reference Value = 0.051 A/m; Power Drift = -0.004 dB


**Hearing Aid Near-Field Category: M4 (AWF 0 dB)**

Peak H-field in A/m

Grid 1 <b>0.065 M4</b>	Grid 2 <b>0.052 M4</b>	Grid 3 <b>0.044 M4</b>
Grid 4 <b>0.059 M4</b>	Grid 5 <b>0.051 M4</b>	Grid 6 <b>0.044 M4</b>
Grid 7 <b>0.048 M4</b>	Grid 8 <b>0.045 M4</b>	Grid 9 <b>0.038 M4</b>



Applicant:	Kyocera
FCC ID:	V65S2150
Report #:	CT-S2150-20RFC-1112-R0





Applicant:	Kyocera
FCC ID:	V65S2150
Report #:	CT-S2150-20RFC-1112-R0

**CDMA 1900 Channel 600 (360) E roll**

