



Applicant:	Kyocera
FCC ID:	V65S2150A1
Report #:	CT- S2150-9A-0213_Rev1

**EXHIBIT 9 APPENDIX A: SAR VALIDATION PLOTS**

## **Validation for HEAD**

Applicant:	Kyocera
FCC ID:	V65S2150A1
Report #:	CT- S2150-9A-0213_Rev1

Test Laboratory: Comptest/Kyocera

Date: 02/20/2013

**835MHz Validation, Probe #3035, DAE #530, Dipole #467**

Communication System: CW, Frequency: 835 MHz, Duty Cycle: 1:1

Medium: Head 835 MHz, Medium parameters used (interpolated):  $f = 835 \text{ MHz}$ ;  $\sigma = 0.91 \text{ mho/m}$ ;  $\epsilon_r = 40.5$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom: SAM 12, Phantom section: Flat Section

**DASY4 Configuration:**

Probe: ES3DV3 - SN3035, ConvF(6.04, 6.04, 6.04), Calibrated: 2/22/2012

Sensor-Surface: 4mm (Mechanical Surface Detection),

Electronics: DAE4 Sn530, Calibrated: 5/30/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

**Temperature:** Room T = 21.8  $\square\square\square 1 \text{ deg C}$ , Liquid T = 22.0  $\square\square\square 1 \text{ deg C}$

**835MHz/Area Scan (51x121x1):** Measurement grid:  $dx=15\text{mm}$ ,  $dy=15\text{mm}$

Maximum value of SAR (interpolated) = 1.03 mW/g


**835MHz/Zoom Scan (7x7x7)/Cube 0:** Measurement grid:  $dx=5\text{mm}$ ,  $dy=5\text{mm}$ ,  $dz=5\text{mm}$

Reference Value = 34.3 V/m; Power Drift = -0.103 dB

Peak SAR (extrapolated) = 1.44 W/kg

**SAR(1 g) = 0.962 mW/g; SAR(10 g) = 0.628 mW/g**


Maximum value of SAR (measured) = 1.04 mW/g





Applicant:	Kyocera
FCC ID:	V65S2150A1
Report #:	CT- S2150-9A-0213_Rev1

**Interpolated SAR(x,y,z,f0)**  
SAR; Z Scan: Value Along Z, X=0, Y=0



Applicant:	Kyocera
FCC ID:	V65S2150A1
Report #:	CT- S2150-9A-0213_Rev1

Test Laboratory: Comptest/Kyocera

Date: 02/18/2013

**1900Mhz Validation @ 20dBm Probe 1618, DAE 675 and Dipole 5d016**

Communication System: CW; Frequency: 1900 MHz; Duty Cycle: 1:1  
Medium parameters used (interpolated):  $f = 1900$  MHz;  $\sigma = 1.45$  S/m;  $\epsilon_r = 38.45$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section

Meas. Ambient Temp(celsius) = 22.10 ; Tissue Temp(celsius) = 21.40

**DASY Configuration:**

Probe: ET3DV6 - SN1618; ConvF(5.17, 5.17, 5.17); Calibrated: 9/13/2012;

Modulation Compensation:

Sensor-Surface: 4mm (Mechanical Surface Detection),  $z = 2.7, 32.7$

Electronics: DAE4 Sn675; Calibrated: 5/23/2012

Phantom: SAM; Type: SAM; Serial: TP-1152

DASY52 52.8.5(1059); SEMCAD X 14.6.8(7028)

**1900 MHz Head Validation, 021813/1900MHz Validation @20dBm/Area Scan (61x61x1):** Interpolated grid:

$dx=1.500$  mm,  $dy=1.500$  mm

Maximum value of SAR (interpolated) = 4.47 W/kg

**1900 MHz Head Validation, 021813/1900MHz Validation @20dBm/Zoom Scan (7x7x7)/Cube 0:** Measurement


grid:  $dx=5$ mm,  $dy=5$ mm,  $dz=5$ mm

Reference Value = 53.697 V/m; Power Drift = -0.03 dB

Peak SAR (extrapolated) = 6.28 W/kg

**SAR(1 g) = 3.74 W/kg; SAR(10 g) = 1.98 W/kg**

Maximum value of SAR (measured) = 4.24 W/kg



0 dB = 4.47 W/kg = 6.50 dBW/kg

Applicant:	Kyocera
FCC ID:	V65S2150A1
Report #:	CT- S2150-9A-0213_Rev1

Date: 4/15/2013

Test Laboratory: Comptest/Kyocera

**1900Mhz Validation @ 20dBm Probe 1618, DAE 530 and Dipole 5d016, 041513**

Communication System: CW, Frequency: 1900 MHz, Duty Cycle: 1:1

Medium: HSL1900,Medium parameters used (interpolated):  $f = 1900$  MHz;  $\sigma = 1.43$  mho/m;  $\epsilon_r = 38.7$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom: SAM\_4,Phantom section: Flat Section

**DASY4 Configuration:**

Probe: ET3DV6 - SN1618, ConvF(5.17, 5.17, 5.17), Calibrated: 9/13/2012

Sensor-Surface: 4mm (Mechanical Surface Detection),

Electronics: DAE4 Sn530,Calibrated: 5/30/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

**Temperature:**Room T = 21.8 +/- 1 deg C, Liquid T = 22.0 +/- 1 deg C

**1900MHz Validation @20dBm/Area Scan (61x61x1):** Measurement grid: dx=15mm, dy=15mm

Maximum value of SAR (interpolated) = 4.77 mW/g


**1900MHz Validation @20dBm/Zoom Scan (7x7x7)/Cube 0:** Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 56.7 V/m; Power Drift = -0.011 dB

Peak SAR (extrapolated) = 6.33 W/kg

**SAR(1 g) = 3.88 mW/g; SAR(10 g) = 2.09 mW/g**

Maximum value of SAR (measured) = 4.42 mW/g



Applicant:	Kyocera
FCC ID:	V65S2150A1
Report #:	CT- S2150-9A-0213_Rev1

## Validation for BODY

Applicant:	Kyocera
FCC ID:	V65S2150A1
Report #:	CT- S2150-9A-0213_Rev1

Test Laboratory: Comptest/Kyocera

Date: 03/14/2013

**835MHz Validation (Muscle), Probe #3036, DAE #603, Dipole #5d016**

Communication System: CW, Frequency: 835 MHz, Duty Cycle: 1:1

Medium: M800, Medium parameters used:  $f = 835 \text{ MHz}$ ;  $\sigma = 0.95 \text{ mho/m}$ ;  $\epsilon_r = 54.1$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom: SAM 12, Phantom section: Flat Section

**DASY4 Configuration:**

Probe: ES3DV3 - SN3036, ConvF(5.83, 5.83, 5.83), Calibrated: 5/29/2012

Sensor-Surface: 4mm (Mechanical Surface Detection),

Electronics: DAE4 Sn603, Calibrated: 9/12/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

**Temperature:** Room T = 21.8  $\pm$  1 deg C, Liquid T = 22.0  $\pm$  1 deg C

**835MHz Validation @20dBm/Area Scan (61x71x1):** Measurement grid: dx=15mm, dy=15mm

Maximum value of SAR (interpolated) = 1.04 mW/g


**835MHz Validation @20dBm/Zoom Scan (7x7x7)/Cube 0:** Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 32.0 V/m; Power Drift = 0.132 dB

Peak SAR (extrapolated) = 1.41 W/kg

**SAR(1 g) = 0.969 mW/g; SAR(10 g) = 0.642 mW/g**

Maximum value of SAR (measured) = 1.05 mW/g



Applicant:	Kyocera
FCC ID:	V65S2150A1
Report #:	CT- S2150-9A-0213_Rev1

Test Laboratory: Comptest/Kyocera

Date: 03/15/2013

**835MHz Validation(Muscle), Probe #3036, DAE #603, Dipole #5d016**

Communication System: CW, Frequency: 835 MHz, Duty Cycle: 1:1

Medium: M800,Medium parameters used:  $f = 835 \text{ MHz}$ ;  $\sigma = 0.95 \text{ mho/m}$ ;  $\epsilon_r = 53.9$ ;  $\rho = 1000 \text{ kg/m}^3$

Phantom: SAM 12,Phantom section: Flat Section

**DASY4 Configuration:**

Probe: ES3DV3 - SN3036, ConvF(5.83, 5.83, 5.83), Calibrated: 5/29/2012

Sensor-Surface: 4mm (Mechanical Surface Detection),

Electronics: DAE4 Sn603,Calibrated: 9/12/2012

Measurement SW: DASY4, V4.7 Build 80

Postprocessing SW: SEMCAD, V1.8 Build 186

**Temperature:**Room T = 21.8  $\pm$  1 deg C, Liquid T = 22.0  $\pm$  1 deg C

**835MHz Validation @20dBm/Area Scan (61x71x1):** Measurement grid: dx=15mm, dy=15mm

Maximum value of SAR (interpolated) = 1.05 mW/g


**835MHz Validation @20dBm/Zoom Scan (7x7x7)/Cube 0:** Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 32.1 V/m; Power Drift = 0.099 dB

Peak SAR (extrapolated) = 1.41 W/kg

**SAR(1 g) = 0.972 mW/g; SAR(10 g) = 0.643 mW/g**

Maximum value of SAR (measured) = 1.05 mW/g




0 dB = 1.05mW/g





Applicant:	Kyocera
FCC ID:	V65S2150A1
Report #:	CT- S2150-9A-0213_Rev1

**Interpolated SAR(x,y,z,f0)**  
SAR; Z Scan: Value Along Z, X=0, Y=0



Applicant:	Kyocera
FCC ID:	V65S2150A1
Report #:	CT- S2150-9A-0213_Rev1

Test Laboratory: Comptest/Kyocera

Date: 02/21/2013

**1900MHz Validation (Muscle) @ 20dBm Probe 1618, DAE 675 and Dipole 5d016**

Communication System: CW; Frequency: 1900 MHz; Duty Cycle: 1:1  
Medium parameters used (interpolated):  $f = 1900$  MHz;  $\sigma = 1.53$  S/m;  $\epsilon_r = 51.26$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section

Meas. Ambient Temp (celsius) = 22.10 ; Tissue Temp(celsius) = 21.40

**DASY Configuration:**

Probe: ET3DV6 - SN1618; ConvF(4.42, 4.42, 4.42); Calibrated: 9/13/2012;

Modulation Compensation:

Sensor-Surface: 4mm (Mechanical Surface Detection),  $z = 2.7, 32.7$

Electronics: DAE4 Sn675; Calibrated: 5/23/2012

Phantom: SAM 12; Type: SAM; Serial: TP-1148

DASY52 52.8.5(1059); SEMCAD X 14.6.8(7028)

**Configuration/1900MHz(Muscle) Validation @20dBm/Area Scan (61x61x1):** Interpolated grid:  $dx=1.500$  mm,  $dy=1.500$  mm

Maximum value of SAR (interpolated) = 4.76 W/kg

**Configuration/1900MHz(Muscle) Validation @20dBm/Zoom Scan (7x7x7)/Cube 0:** Measurement grid:


$dx=5$ mm,  $dy=5$ mm,  $dz=5$ mm

Reference Value = 54.390 V/m; Power Drift = -0.20 dB

Peak SAR (extrapolated) = 5.58 W/kg

**SAR(1 g) = 3.74 W/kg; SAR(10 g) = 2.06 W/kg**


Maximum value of SAR (measured) = 4.26 W/kg



0 dB = 4.76 W/kg = 6.78 dBW/kg



Applicant:	Kyocera
FCC ID:	V65S2150A1
Report #:	CT- S2150-9A-0213_Rev1



Applicant:	Kyocera
FCC ID:	V65S2150A1
Report #:	CT- S2150-9A-0213_Rev1

Test Laboratory: Comptest/Kyocera

Date: 02/22/2013

**1900MHz Validation (Muscle) @ 20dBm Probe 1618, DAE 675 and Dipole 5d016**

Communication System: CW; Frequency: 1900 MHz; Duty Cycle: 1:1  
Medium parameters used (interpolated):  $f = 1900$  MHz;  $\sigma = 1.55$  S/m;  $\epsilon_r = 52.5$ ;  $\rho = 1000$  kg/m<sup>3</sup>

Phantom section: Flat Section

Meas. Ambient Temp(celsius) = 22.10 ; Tissue Temp(celsius) = 21.40

**DASY Configuration:**

Probe: ET3DV6 - SN1618; ConvF(4.42, 4.42, 4.42); Calibrated: 9/13/2012;

Modulation Compensation:

Sensor-Surface: 4mm (Mechanical Surface Detection),  $z = 2.7, 32.7$

Electronics: DAE4 Sn675; Calibrated: 5/23/2012

Phantom: SAM 12; Type: SAM; Serial: TP-1148

DASY52 52.8.5(1059); SEMCAD X 14.6.8(7028)

**Configuration/1900MHz(Muscle) Validation @20dBm/Area Scan (61x61x1):** Interpolated grid:  $dx=1.500$  mm,  $dy=1.500$  mm

Maximum value of SAR (interpolated) = 4.73 W/kg

**Configuration/1900MHz(Muscle) Validation @20dBm/Zoom Scan (7x7x7)/Cube 0:** Measurement grid:


$dx=5$ mm,  $dy=5$ mm,  $dz=5$ mm

Reference Value = 52.470 V/m; Power Drift = 0.06 dB

Peak SAR (extrapolated) = 5.77 W/kg

**SAR(1 g) = 3.86 W/kg; SAR(10 g) = 2.13 W/kg**

Maximum value of SAR (measured) = 4.39 W/kg



0 dB = 4.73 W/kg = 6.75 dBW/kg