



Smoke/Heat Detector

Model 325
 1354517850
 FCC ID: VN325020
 Return to CWSI for servicing
 Refer to Inстал 101-200 Rev E
 Manufactured by
 Apollo America
 29 Corporate Drive
 Auburn Hills, MI 48326
 Made in USA

Supply 4.5VDC
 Sensitivity 1.6-3.1volts
 Max Current 50mA
 Alarm Current 20mA
 Supervisory Current 25uA
 Test weekly by pushing test/reset button
 Supplementary heat setting 132°F (51°C)
 Do not install in ambient over 100°F (38°C)
 Clean with dry cloth

APPROXIMATE
 LABEL LOCATION

APPROXIMATE
 LABEL LOCATION