

FCRN: 0017145996
 FCC-ID: VT8-PSENSLN
 IC-ID: 7482A-PSENSLN

May 12, 2016





Page 1 of 3

Attestation letter

We, Pilz GmbH & Co. KG hereby declare, that the test report of CETECOM laboratory are also to be cover the following products:

Kind of product:	Operating Mode Selector
Product Series:	PSEN slock
Product Name: (Family Approval)	PSEN si-X.Xn X.X
CETECOM Testreport No.:	Test report No.: 1-8548/14-01-02
Model Name	Product Label
PSEN si-1.0n 1.1 (570613)	
	<p>This was the DUT (Device under Test) of Test report No.: Cetecom 1-8548/14-01-02-A (2014-10-27)</p> <ul style="list-style-type: none"> - coding: coded - connector: 5 pin - magnetic holding force: 1.0 kN
PSEN si-0.5n 1.1 (570513)	
	<p><u>Difference to DUT:</u></p> <ul style="list-style-type: none"> - magnetic holding force: 0.5 kN

the spirit of safety

<p>PSEN si-0.5n 2.1 (570514)</p>	
	<p><u>Difference to DUT:</u> - coding: fully coded - magnetic holding force: 0.5 kN</p>
<p>PSEN si-0.5n 2.2 (570515)</p>	
	<p><u>Difference to DUT:</u> - coding: uniquely coded - magnetic holding force: 0.5 kN</p>
<p>PSEN si-1.0n 2.1 (570614)</p>	
	<p><u>Difference to DUT:</u> - coding: fully coded</p>
<p>PSEN si-1.0n 2.2 (570615)</p>	
	<p><u>Difference to DUT:</u> - coding: uniquely coded</p>

Authorized Signature:
Print Name & Title:
Date:



Jürgen Kitzing, Approval Manager
07. December 2015