



W66 N220 Commerce Court • Cedarburg, WI 53012 • USA  
Phone: 262.375.4400 • Fax: 262.375.4248  
[www.lsr.com](http://www.lsr.com)

## ENGINEERING TEST REPORT # 310037-A LSR Job #: C-871

### Compliance Testing of:

Casi-Rusco RFID Module

### Test Date(s):

March 24<sup>th</sup> and April 12<sup>th</sup> 2010

### Prepared For:

API Healthcare  
Attn: Gary Sutcliffe  
1550 Innovation Way  
Hartford, WI 53027

In accordance with:

Federal Communications Commission (FCC)

Part 15, Subpart C, Section 15.209, and 15.109

Industry Canada (IC)

RSS 210 Annex 2 and section 2.7

General Operating Requirements for Low-Power License-Exempt Transceivers

### This Test Report is issued under the Authority of:

Thomas T. Smith, Manager EMC Test Services

Signature:

Date: 05.06.10

### Test Report Reviewed by:

Ryan M. Urness, Laboratory Manager

Signature:

Date: 05.06.10

### Tested by:

Khairul Aidi Zainal, Senior EMC Engineer

Signature:

Date: 05.05.10

*This Test Report may not be reproduced, except in full, without written approval of LS Research, LLC.*

## TABLE OF CONTENTS (page 1 of 2)

Description	Page
<b>EXHIBIT 1: INTRODUCTION</b>	
1.1 Scope	4
1.2 Normative References	5
1.3 LS Research, LLC Test Facility	6
1.4 Location of Testing	6
1.5 Test Equipment Utilized	6
<b>EXHIBIT 2: PERFORMANCE ASSESSMENT</b>	
2.1 Client Information	7
2.2 Equipment Under Test (EUT) Information	7
2.3 Associated Antenna Description	7
2.4 EUT's Technical Specifications	8
2.5 Product Description	9
<b>EXHIBIT 3: EUT OPERATING CONDITIONS &amp; CONFIGURATIONS DURING TESTS</b>	
3.1 Climate Test Conditions	10
3.2 Applicability & Summary of EMC Emission Test Results	10
3.3 Modifications Incorporated in the EUT for Compliance Purposes	10
3.4 Deviations & Exclusions from Test Specifications	10
<b>EXHIBIT 4: DECLARATION OF CONFORMITY</b>	11
<b>EXHIBIT 5: RADIATED EMISSIONS TESTING TRANSMIT AND RECEIVE</b>	
5.1 Test Setup	12
5.2 Test Procedure	12
5.3 Test Equipment Utilized	13
5.4 Test Results	13
5.5 Calculation of Radiated Emissions Limits	14-15
5.6 Radiated Emissions Test Data Chart	16-19
5.7 Test Setup Photo(s) – Radiated Emissions Test	20-21
5.8 Screen Captures – Radiated Emissions Test	22-26
<b>EXHIBIT 6: CONDUCTED EMISSIONS TEST, AC POWER LINE TRANSMIT AND RECEIVE.</b>	
6.1 Test Setup	27
6.2 Test Procedure	27
6.3 Test Equipment Utilized	27
6.4 Test Results	27
6.5 FCC Limits of Conducted Emissions at the AC Mains Ports	28
6.6 Conducted Emissions Test Data Chart	29
6.7 Test Setup Photo(s) – Conducted Emissions Test	30
6.8 Screen Captures – Conducted Emissions Test	31

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 2 of 39

## **TABLE OF CONTENTS** (Page 2 of 2)

Description	Page
<b>EXHIBIT 7: OCCUPIED BANDWIDTH</b>	
7.1 Limits	32
7.2 Method of Measurements	32
7.3 Test Data	32
7.4 Screen Captures – Occupied Bandwidth	33
<b>EXHIBIT 8: BAND-EDGE MEASUREMENT</b>	
8.1 Test Criterion	34
8.2 Screen Captures	34-36
<b>APPENDICES</b>	
APPENDIX A: TEST EQUIPMENT LIST	37
APPENDIX B: TEST STANDARDS	38
APPENDIX C: UNCERTAINTY STATEMENT	39

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 3 of 39

## EXHIBIT 1. INTRODUCTION

### 1.1 SCOPE

<b>References:</b>	FCC Part 15, Subpart C, Section 15.209
<b>Title:</b>	Telecommunication – Code of Federal Regulations, CFR 47, Part 15
<b>Purpose of Test:</b>	To gain FCC Certification Authorization for Low-Power License-Exempt Transmitters.

<b>References:</b>	FCC Part 15, Subpart B, Section 15.109
<b>Title:</b>	Telecommunication – Code of Federal Regulations, CFR 47, Part 15
<b>Purpose of Test:</b>	To gain FCC Certification Authorization for a Digital Device or a Non-Intentional Radiator.

<b>References:</b>	RSS 210 Annex 2
<b>Title:</b>	Low-power License-exempt Radiocommunication Devices (All Frequency Bands): Category I equipment.
<b>Purpose of Test:</b>	To gain IC Certification Authorization for Low-Power License-Exempt Transmitters.

<b>References:</b>	RSS GEN
<b>Title:</b>	General requirements and Information for the Certification of Radiocommunication Equipment.
<b>Purpose of Test:</b>	To gain IC Certification Authorization for Low-Power License-Exempt Transmitters.

<b>Test Procedures:</b>	Both conducted and radiated emissions measurements were conducted in accordance with American National Standards Institute ANSI C63.4 – American National Standard for Methods of Measurement of Radio-Noise Emissions from Low-Voltage Electrical and Electronic Equipment in the Range of 9 kHz to 40 GHz.
<b>Environmental Classification:</b>	<ul style="list-style-type: none"><li>• Commercial, Industrial or Business</li><li>• Residential</li></ul>

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 4 of 39

## 1.2 NORMATIVE REFERENCES

Publication	Year	Title
47 CFR, Parts 0-15 (FCC)	2009	Code of Federal Regulations - Telecommunications
RSS 210 Annex 2	2007	Low-power License-exempt Radiocommunication Devices (All Frequency Bands): Category I equipment.
RSS GEN	2007	General requirements and information for the certification of Radiocommunication Equipment.
ANSI C63.4	2009	American National Standard for Methods of Measurement of Radio-Noise Emissions from Low-Voltage Electrical and Electronic Equipment in the Range of 9 kHz to 40 GHz.
CISPR 16-1-1	2006-03 A1: 2006-09 A2: 2007-07	Specification for radio disturbance and immunity measuring apparatus and methods. Part 1-1: Measuring Apparatus.
CISPR 16-2-1	2003 A1: 2004-04 A2: 2007-07	Specification for radio disturbance and immunity measuring apparatus and methods. Part 201: Conducted disturbance measurement.

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 5 of 39

### **1.3 LS Research, LLC TEST FACILITY**

LS Research, LLC is accredited by A2LA (American Association for Laboratory Accreditation) to conform to ISO/IEC 17025, 2005 "General Requirements for the Competence of Calibration and Testing Laboratories".

LS Research, LLC's scope of accreditation includes all test methods listed herein, unless otherwise noted. Accreditation status can be verified at A2LA's web site: [www.a2la2.net](http://www.a2la2.net).

### **1.4 LOCATION OF TESTING**

All testing was performed at LS Research, LLC, W66 N220 Commerce Court, Cedarburg, Wisconsin, 53012 USA, utilizing the facilities listed below, unless otherwise noted.

List of Facilities Located at LS Research, LLC:

- Compact Semi-Anechoic Chamber
- FCC Listed Semi-Anechoic Chamber
- Open Area Test Site (OATS)

### **1.5 TEST EQUIPMENT UTILIZED**

A complete list of equipment utilized in testing is provided in Appendix A of this test report. Calibration dates are indicated in Appendix A. All test equipment is calibrated by an ISO 17025 accredited calibration laboratory, traceable to the SI standard.

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 6 of 39

## EXHIBIT 2. PERFORMANCE ASSESSMENT

### 2.1 CLIENT INFORMATION

<b>Manufacturer Name:</b>	API Healthcare Corporation.
<b>Address:</b>	1550 Innovation Way Hartford, WI 53027
<b>Contact Person:</b>	Gary Sutcliffe
<b>Contact Phone:</b>	262.670.2789
<b>Contact Email:</b>	Gary.sutcliffe@apihealthcare.cc

### 2.2 EQUIPMENT UNDER TEST (EUT) INFORMATION

*The following information has been supplied by the applicant.*

<b>Product Name:</b>	Casi-Rusco RFID Module
<b>Model Number:</b>	RFID Module: DB-RFIDEAS_CR-CD Host: TA-500
<b>Serial Number:</b>	RFID module: A149380 Host: A96363

### 2.3 ASSOCIATED ANTENNA DESCRIPTION

The antenna associated with the module is a multi-turn loop antenna.

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 7 of 39

## 2.4 EUT'S TECHNICAL SPECIFICATIONS

### Additional Information:

Frequency Range (in MHz)	0.125 MHz
RF Power in Watts (Near-field measurement at 3 meters)	EUT outside host enclosure: 0.0004753 Watts EUT Inside host enclosure : 0.0000189 Watts
Conducted Output Power (in dBm)	N/A
EIRP (in mW)	N/A
Field Strength at 3 meters	EUT outside host enclosure: 92.0 dB $\mu$ V/m EUT Inside host enclosure : 77.9 dB $\mu$ V/m
Occupied Bandwidth (99% BW)	437 Hz
Type of Modulation	ASK
Emission Designator	437HA1D
Transmitter Spurious (worst case) at 3 meters	EUT Outside: 39.7 dB $\mu$ V/m at 351.3 MHz EUT Inside : 38.7 dB $\mu$ V/m at 154.8 MHz
Receiver Spurious (worst case) at 3 meters	Refer to transmitter since EUT transmit and receives at the same time.
Frequency Tolerance %, Hz, ppm	50 ppm
Microprocessor Model # (if applicable)	PIC16C505 ATMEGA128
EUT will be operated under FCC Rule Part(s)	CFR 47 part 15.209
Antenna Information:	
a) Antenna Type	Multiple turn loop
b) Detachable/Non-Detachable	Non-detachable
c) Antenna Gain (in dBi)	Not available
Modular Filing	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Portable or Mobile?	Portable

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 8 of 39

## **2.5 PRODUCT DESCRIPTION**

The RF Ideas Casi-Rusco module is a 125 kHz RFID module. It is a modular product that may be incorporated into different API healthcare host consoles. The Casi-Rusco module will only be installed in products under the control of API healthcare Corporation. It is used exclusively with API Healthcare access point control applications. The Casi-Rusco RFID module is powered by the host interface with 5VDC. Communications with the host is via digital interface lines connecting the Casi-Rusco module and the host microprocessor. The Casi-Rusco RFID module is not self sufficient and cannot function without the use of a host unit. API healthcare will have control over the installation of the Casi-Rusco RFID module in its line of access point control applications.

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 9 of 39

### **EXHIBIT 3. EUT OPERATING CONDITIONS & CONFIGURATIONS DURING TESTS**

#### **3.1 CLIMATE TEST CONDITIONS**

<b>Temperature:</b>	71° Fahrenheit
<b>Humidity:</b>	34%
<b>Pressure:</b>	749 mmHg

#### **3.2 APPLICABILITY & SUMMARY OF EMC EMISSION TEST RESULTS**

<b>FCC Paragraph</b>	<b>Test Requirements</b>	<b>Compliance (yes/no)</b>
FCC : 15.107 IC : RSS GEN 7.2.2	Power Line Conducted Emissions Measurements	Yes
IC: RSS GEN 4.6	Occupied Bandwidth	Yes
FCC : 15.109 IC : RSS 210 2.6	Un-Intentional Radiated Emissions	Yes
FCC : 15.209 (a) IC : RSS 210 A2	Maximum RF Output Power	Yes
FCC : 15.209 (c) IC : RSS 210 A2	Maximum RF Spurious Emissions	Yes
FCC : 15.109 & 15.205 IC : RSS 210 A2 and 2.6	Transmitter General Radiated Emissions	Yes
FCC: 15.209 (b)	Band edge requirements	Yes

#### **3.3 MODIFICATIONS INCORPORATED IN THE EUT FOR COMPLIANCE PURPOSES**

None       Yes (explain below)

#### **3.4 DEVIATIONS & EXCLUSIONS FROM TEST SPECIFICATIONS**

None       Yes (explain below)

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 10 of 39

## EXHIBIT 4. DECLARATION OF CONFORMITY

The EUT was found to **MEET** the requirements as described within the specification of FCC Title 47, CFR Part 15.209, and Industry Canada RSS-210, Issue 7 (2007), Section 2.6 for a Low-Power License-Exempt Transmitters, as well as the specification of FCC Title 47, CFR Part 15.109, and Industry Canada RSS-210, Issue 7 (2007), Section 7 for non-intentional radiators.

If some emissions are seen to be within 3 dB of their respective limits:

As these levels are within the tolerances of the test equipment and site employed, there is a possibility that this unit, or a similar unit selected out of production may not meet the required limit specification if tested by another agency.

LS Research, LLC certifies that the data contained herein was taken under conditions that meet or exceed the requirements of the test specifications. The results in this Test Report apply only to the item(s) tested on the above-specified dates. Any modifications made to the EUT subsequent to the indicated test date(s) will invalidate the data herein, and void this certification.

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 11 of 39

## EXHIBIT 5. RADIATED EMISSIONS TEST FOR TRANSMIT AND RECEIVE.

### 5.1 Test Setup

The test setup was assembled in accordance with Title 47, CFR FCC Part 15, RSS GEN, and ANSI C63.4. The Casi-Rusco RFID module, henceforth referred to as the EUT, was placed on an 80cm high non-conductive pedestal, centered on a flush mounted 2-meter diameter turntable inside a 3 meter Semi-Anechoic, FCC listed Chamber. The EUT was tested in two setups:

1. The EUT outside of the host enclosure.
2. The EUT inside of the host enclosure.

The first setup variant is for modular testing while the second depicts normal usage/operation. The EUT operates on a single channel at 125 kHz.

The host (TA500) used in the test was chosen because it has many of the features that would be incorporated in a typical host reader. It was configured in an arrangement that may have the most interaction with the AWID badge reader under test. The host enclosure draws power via POE (power over Ethernet) which in turn powers the EUT. The host was exercised by activating communication through an Ethernet connection. It was tested against class B limits for residential and light industrial applications.

For the test, the EUT was in normal configuration where it continuously looks for a badge. Initial measurements were performed at 3m separation to identify the emissions below 30MHz, and all identified emissions were then re-measured at a 10m separation distance.

In accordance with Title 47, CFR FCC Part 15.33(b)(1), because the highest clock frequency present in the system is 90MHz, spurious emissions investigation will be tested to 1GHz.

### 5.2 Test Procedure

Radiated RF measurements were performed at a separation distance of 3 meters on the EUT in a Semi-Anechoic, FCC listed Chamber. The frequency range from 10 kHz to 1000 MHz was scanned and investigated. In cases where emissions below 30MHz were found, measurements of those emissions were repeated on the OATS at a 10m measurement distance. The radiated RF emission levels were manually noted at the various fixed degree settings of azimuth on the turntable and antenna height. A Biconical Antenna was used to measure emissions from 30 MHz to 300 MHz, and a Log Periodic Antenna was used to measure emissions from 300 MHz to 1000 MHz. For emissions below 30 MHz, an active loop antenna was used. The loop antenna was set at a height of 1m above the conducting ground plane and it was rotated about its vertical and horizontal axes (while utilizing the turntable to rotate the EUT) in order to measure the maximum radiated RF emissions. The maximum radiated RF emissions above 30MHz were found by raising and lowering the antenna between 1 and 4 meters in height, using both horizontal and vertical antenna polarities and rotating the EUT using the turntable.

The EUT was rotated along three orthogonal axes during the investigations to find the highest emission levels. In addition, the fundamental power and frequency was monitored while the EUT supply voltage was varied  $\pm 15\%$  of the nominal (102 VAC and 138 VAC).

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 12 of 39

The receiver was operated with the resolution bandwidth set at 200 Hz for measurements between 9kHz and 150kHz, 9kHz for measurements between 150kHz and 30MHz and 120kHz for measurements between 30MHz and 1000 MHz.

**Due to the nature of the device, while in normal operation, the emissions of the transmitter and receiver can be measured simultaneously. Proceeding graphs and data in this report are that of both TRANSMIT and RECEIVE modes.**

### **5.3 Test Equipment Utilized**

A list of the test equipment and antennas utilized for the Radiated Emissions test can be found in Appendix A. This list includes calibration information and equipment descriptions. All equipment is calibrated and used according to the operation manuals supplied by the manufacturers. All calibrations of the antennas used were performed at an IEC/ISO 17025 accredited calibration laboratory, traceable to the SI standard. In addition, the Connecting Cables were measured for losses using a calibrated Signal Generator and an Agilent E4445A/N9039A EMI System. The resulting correction factors and the cable loss factors from these calibrations were entered into the EMI Receiver database. As a result, the data taken from the EMI Receiver accounts for the antenna correction factor as well as cable loss or other corrections, and can therefore be entered into the database as a corrected meter reading. The EMI Receiver was operated with resolution bandwidths as prescribed in ANSI C63.4.

### **5.4 Test Results**

The EUT was found to **MEET** the Radiated Emissions requirements of Title 47 CFR, FCC Part 15.209 for a Low-Power License-Exempt transmitter [Canada RSS-210]. The frequencies with significant RF signal strength were recorded and plotted as shown in the Data Charts and Graphs. The voltage variation test revealed that the EUT showed no variation in power and frequency. The power was then cycled On/Off to observe system response. No unusual response was observed, the emission characteristics were within compliant parameters, and the system returned to the same state of operation as before the power cycle.

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 13 of 39

## 5.5 CALCULATION OF RADIATED EMISSIONS LIMITS

### Transmitter Limits

The maximum peak output power of an intentional radiator in the 9-490 kHz band, as specified in Title 47 CFR 15.209 and RSS 210 section 2.7, is calculated in a formula as described below. The harmonic and spurious RF emissions, with appropriate receiver bandwidths, as specified in 15.209 (c) and section 2.7 of RSS 210, shall be below the measured power of the desired signal, and must also meet the requirements described in 15.205(c) for FCC and table 1 of RSS 210 where applicable.

The following table depicts the general radiated emission limits. These limits are obtained from Title 47 CFR, Part 15.209, for radiated emissions measurements and are comparable to that of table 3 in RSS 210 section 2.7. These limits were applied to the fundamental emission of the intentional radiator as well as all other significant spurious signals.

Frequency (MHz)	Limit $\mu\text{V}/\text{m}$	Limit $(\text{dB}\mu\text{V}/\text{m})$	Measurement Distance (m)
0.009-0.490	2400/F (kHz)	Note 1	300
0.490-1.705	24000/F (kHz)		30
1.705-30.0	30		30
30-88	100	40.0	3
88-216	150	43.5	3
216-960	200	46.0	3
960-24,000	500	54.0	3

#### Note 1: Sample calculation for the Fundamental Emission of a transmitter:

For Example:

If a transmitter operates at a fundamental frequency of 25 kHz, the emission limit may be calculated:

$$2400/F = 2400/25 = 96.0 \mu\text{V}/\text{m} \text{ if measured at 300 meters separation.}$$

Expressed in decibels:  $20 \log_{10} (96.0) = 39.64 \text{ dB}\mu\text{V}/\text{m}$  at 300 m separation.

At 3 meters separation, the limit may be extrapolated by the addition of 40 dB/decade per 47CFR 15.31(f)(2)

$$\text{Limit for the fundamental emission} = 39.64 \text{ dB}\mu\text{V}/\text{m} + 80 \text{ dB} = 119.6 \text{ dB}/\mu\text{V}/\text{m} \text{ at 3 meters}$$

#### Sample conversion from field strength $\mu\text{V}/\text{m}$ to $\text{dB}\mu\text{V}/\text{m}$ :

$$\begin{aligned} \text{dB}\mu\text{V}/\text{m} &= 20 \log_{10} (100) \\ &= 40 \text{ dB}\mu\text{V}/\text{m} \text{ (from 30-88 MHz)} \end{aligned}$$

#### For measurements made at 1.0 meter, a 9.5 dB correction may be invoked.

960 MHz to 10,000 MHz

500  $\mu\text{V}/\text{m}$  or 54.0 dB/ $\mu\text{V}/\text{m}$  at 3 meters

$$54.0 + 9.5 = 63.5 \text{ dB}/\mu\text{V}/\text{m} \text{ at 1 meter}$$

#### For measurements made at 0.3 meter, a 20 dB correction may be invoked.

960 MHz to 10,000 MHz

500  $\mu\text{V}/\text{m}$  or 54.0 dB/ $\mu\text{V}/\text{m}$  at 3 meters

$$54.0 + 20 = 74 \text{ dB}/\mu\text{V}/\text{m} \text{ at 0.3 meters}$$

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 14 of 39

## Receiver Limits

The following table depicts the Class B limits for an unintentional radiator. These limits are obtained from Title 47 CFR, Part 15.109(a) and RSS 210 section 2.6, for radiated emissions measurements.

Frequency (MHz)	3 m Limit ( $\mu$ V/m)	3 m Limit (dB $\mu$ V/m)
30-88	100	40.0
88-216	150	43.5
216-960	200	46.0
960-10,000	500	54.0

Sample conversion from field strength  $\mu$ V/m to dB $\mu$ V/m:

$$\text{dB}\mu\text{V/m} = 20 \log_{10} (\text{3m limit})$$

from 30-88 MHz for example:  $\text{dB}\mu\text{V/m} = 20 \log_{10} (100)$

$$40.0 \text{ dB}\mu\text{V/m} = 20 \log_{10} (100)$$

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 15 of 39

## 5.6

**RADIATED EMISSIONS DATA CHART**

3 Meter Measurements of Electromagnetic Radiated Emissions

Frequency Range Inspected: 9 kHz to 1000 MHz

Manufacturer:	API Healthcare				
Date(s) of Test:	March 24 <sup>th</sup> and April 12 <sup>th</sup> 2010				
Project Engineer:	Aidi Zainal				
Test Engineer(s):	Aidi Zainal and Ken Boston				
Voltage:	EUT : 5VDC (from Host) Host : 120 VAC				
Operation Mode:	Normal operation. Simultaneous transmit and receive				
Environmental Conditions in the Lab:	Temperature: 20 – 25 °C Relative Humidity: 30 – 60 %				
EUT Power:	√	Single Phase 120VAC		3 Phase ____ VAC	
		Battery	√	Other: TA500	
EUT Placement:	√	80cm non-conductive table		10cm Spacers	
EUT Test Location:	√	3 Meter Semi-Anechoic FCC Listed Chamber	√	10m OATS	
Measurements:		Pre-Compliance		Preliminary	√ Final
Detectors Used:	√	Peak	√	Quasi-Peak	√ Average

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 16 of 39

## RADIATED EMISSIONS DATA CHART (continued)

The following table depicts the level of significant **spurious** radiated RF emissions found for both **transmit** and **receive** mode:

### 1. EUT outside of host enclosure.

Frequency (MHz)	Antenna Polarization	EUT Orientation	Height (m)	Azimuth (°)	Q. Peak Det. (dB $\mu$ V/m)	Limit (dB $\mu$ V/m)	Margin (dB)
154.9	H	V	1.22	158	36.7	43.0	6.3
165.9	H	V	1.80	85	30.1	43.0	12.9
175.7	H	V	1.00	195	32.9	43.0	10.1
191.6	H	V	1.60	0	35.0	43.0	8.0
199.1	H	V	1.00	0	36.0	43.0	7.0
207.6	H	V	1.50	0	33.7	43.0	9.3
255.5	H	V	1.30	65	35.0	46.0	11.0
110.6	V	V	1.00	35	33.2	43.0	9.8
154.9	V	V	1.00	0	36.2	43.0	6.8
165.9	V	V	1.00	320	37.1	43.0	5.9
367.3	V	V	1.40	0	39.7	46.0	6.3
351.3	H	V	1.00	265	36.9	46.0	9.1
367.3	H	V	1.00	245	35.7	46.0	10.3

*Notes:*

- 1) An Average and quasi peak Detector function was used in measurements below 30 MHz, a Quasi-Peak Detector was used in measurements between 30 MHz and 1 GHz.
- 2) The spurs seen are independent of EUT orientation.
- 3) V = Vertical, S= side, H = Horizontal, F= Flat.

### 2. EUT inside of host enclosure.

Frequency (MHz)	Antenna Polarization	EUT Orientation	Height (m)	Azimuth (°)	Q. Peak Det. (dB $\mu$ V/m)	Limit (dB $\mu$ V/m)	Margin (dB)
31.9	V	V	1.00	325	31.1	40.0	8.9
99.6	V	V	1.00	233	34.7	43.0	8.3
110.6	V	V	1.27	177	38.7	43.0	4.3
154.8	V	V	1.00	0	32.5	43.0	10.5
154.8	H	V	1.27	177	38.7	43.0	4.3
165.9	H	V	1.00	0	35.5	43.0	7.5
207.6	H	V	1.20	183	33.4	43.0	9.6
223.6	H	V	1.30	0	37.6	46.0	8.4

*Notes:*

- 1) An Average and quasi peak Detector function was used in measurements below 30 MHz, a Quasi-Peak Detector was used in measurements between 30 MHz and 1 GHz.
- 2) The spurs seen are independent of EUT orientation.
- 3) V = Vertical, S= side, H = Horizontal, F= Flat.

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 17 of 39

## RADIATED EMISSIONS DATA CHART (continued)

The following table depicts the level of significant radiated RF **fundamental and harmonic** emissions seen when the EUT OUTSIDE of the host enclosure (3m measurement):

Frequency (MHz)	Antenna Polarization	EUT Orientation	Height (m)	Azimuth (°)	Peak Det. (dB $\mu$ V/m)	Q. Peak Det. (dB $\mu$ V/m)	Avg Det. (dB $\mu$ V/m)	Limit (dB $\mu$ V/m)	Margin (dB)
0.1250	V	S	1.00	188	92.0	92.0	92.0	105.7	13.7
0.2500				Note 2					
0.3751	V	S	1.00	177	58.1	56.8	54.8	96.1	41.4
0.5001				Note 2					
0.6251	V	S	1.00	175	52.1	48.4	45.3	71.7	23.3
0.7501				Note 2					
0.8751	V	S	1.00	178	46.7	44.3	40.4	68.8	24.4
1.0002				Note 2					
1.1252	V	S	1.00	155	44.1	39.4	35.5	66.6	27.2
1.2502				Note 2					

The following table depicts the level of significant radiated RF **fundamental and harmonic** emissions seen when the EUT OUTSIDE of the host enclosure (10m measurement):

Frequency (MHz)	Antenna Polarization	EUT Orientation	Height (m)	Azimuth (°)	Peak Det. (dB $\mu$ V/m)	Q. Peak Det. (dB $\mu$ V/m)	Avg Det. (dB $\mu$ V/m)	Limit (dB $\mu$ V/m)	Margin (dB)
0.1250	V	S	1.00	7	64.2	62.4	59.5	84.8	25.3
0.2500				Note 2					
0.3751				Note 2					
0.5001				Note 2					

Notes:

- 1) An Average and quasi peak Detector function was used in measurements below 30 MHz, a Quasi-Peak Detector was used in measurements between 30 MHz and 1 GHz.
- 2) Measurement buried within receiver system noise floor.
- 3) Measurements below 30MHz were performed at 3m and 10m separation distance. The limits were corrected to reflect the change in measurement distance.
- 4) V = Vertical, S= side, H = Horizontal, F= Flat.

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 18 of 39

## RADIATED EMISSIONS DATA CHART (continued)

The following table depicts the level of significant radiated RF **fundamental and harmonic** emissions seen when the EUT INSIDE of the host enclosure (3m measurement):

Frequency (MHz)	Antenna Polarization	Host Orientation	Height (m)	Azimuth (°)	Peak Det. (dB $\mu$ V/m)	Q. Peak Det. (dB $\mu$ V/m)	Avg Det. (dB $\mu$ V/m)	Limit (dB $\mu$ V/m)	Margin (dB)
0.1250	V	V	1.00	0	78.0	77.9	77.9	105.7	27.8
0.2500				Note 2					
0.3751	V	V	1.00	0	54.2	51.9	46.7	96.1	49.5
0.5001				Note 2					
0.6251	V	V	1.00	0	46.6	43.8	38.0	71.7	27.9
0.7501	V	V	1.00	154	43.7	39.5	32.8	70.1	30.6
0.8751	V	V	1.00	0	46.1	41.5	35.7	68.8	27.2
1.0002				Note 2					
1.1252	V	V	1.00	7	40.2	36.2	30.1	66.6	30.4
1.2502				Note 2					

The following table depicts the level of significant radiated RF **fundamental and harmonic** emissions seen when the EUT INSIDE of the host enclosure (10m measurement):

Frequency (MHz)	Antenna Polarization	Host Orientation	Height (m)	Azimuth (°)	Peak Det. (dB $\mu$ V/m)	Q. Peak Det. (dB $\mu$ V/m)	Avg Det. (dB $\mu$ V/m)	Limit (dB $\mu$ V/m)	Margin (dB)
0.1250	V	V	1.00	0	56.1	53.9	49.9	84.8	34.9
0.2500				Note 2					
0.3751				Note 2					
0.5001				Note 2					


Notes:

- 1) An Average and quasi peak Detector function was used in measurements below 30 MHz, a Quasi-Peak Detector was used in measurements between 30 MHz and 1 GHz.
- 2) Measurement buried within receiver system noise floor.
- 3) Measurements below 30MHz were performed at 3m and 10m separation distance. The limits were corrected to reflect the change in measurement distance.
- 4) V = Vertical, S= side, H = Horizontal, F= Flat

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 19 of 39

## 5.7 Test Setup Photo(s) – Radiated Emissions Test

### 5.7.1 EUT outside of Host



Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 20 of 39

### 5.7.2 EUT inside of Host



Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 21 of 39


## 5.8 Screen Captures - Radiated Emissions Testing

These screen captures represent Peak Emissions. For radiated emission measurements, a Quasi-Peak or Average detector function is utilized when measuring frequencies below 1 GHz.


The signature scans shown here are from worst-case emissions with the sense antenna in either vertical or horizontal polarity for worst case presentations.

### 5.8.1 EUT outside of host.

#### 9 kHz to 150 kHz, at 3m




#### 150 kHz-1MHz, at 3m




Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 22 of 39

## 1 MHZ to 30 MHz, at 3m




## Horizontal Polarization, 30 MHz to 300 MHz, at 3m




Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 23 of 39

## Horizontal Polarization, 300 MHz to 1000 MHz, at 3m




### 5.8.2 EUT inside of host.




Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 24 of 39

## 150 kHz-1MHz, at 3m




## 1 MHz to 30 MHz, at 3m




Prepared For: API Healthcare	Model #: DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #: 310037	FCC ID #:	Page 25 of 39

## Horizontal Polarization, 30 MHz to 300 MHz, at 3m



## Horizontal Polarization, 300 MHz to 1000 MHz, at 3m



Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 26 of 39

## EXHIBIT 6. CONDUCTED EMISSIONS TEST, AC POWER LINE TRANSMIT AND RECEIVE:

### 6.1 Test Setup

The test area and setup are in accordance with ANSI C63.4 and with Title 47 CFR, FCC Part 15 (Industry Canada RSS-210, Issue 7, 2007). The EUT was placed on a non-conductive wooden table, with a height of 80 cm above the reference ground plane. The EUT's power cable was plugged into a  $50\Omega$  (ohm), 50/250  $\mu\text{H}$  Line Impedance Stabilization Network (LISN). The AC power supply of 120V was provided via an appropriate broadband EMI Filter, and then to the LISN line input. Final readings were then taken and recorded. After the EUT was setup and connected to the LISN, the RF Sampling Port of the LISN was connected to a 10 dB Attenuator-Limiter, and then to the HP8546/85460A EMI System. The EMCO LISN used has the ability to terminate the unused port with a  $50\Omega$  (ohm) load when switched to either L1 (line) or L2 (neutral).

### 6.2 Test Procedure

The EUT was investigated in normal operation mode for this portion of the testing. The appropriate frequency range and bandwidths were selected on the EMI Receiver, and measurements were made. The bandwidth used for these measurements is 9 kHz, for Quasi-Peak and Average detectors in the frequency range of 150 kHz to 30MHz. Final readings were then taken and recorded.

### 6.3 Test Equipment Utilized

A list of the test equipment and accessories utilized for the Conducted Emissions test is provided in Appendix A. This list includes calibration information and equipment descriptions. All equipment is calibrated and used according to the operation manuals supplied by the manufacturers. Calibrations of the LISN and Limiter were performed by an ISO 17025 accredited calibration laboratory, traceable to the SI standard. All cables are calibrated and checked periodically for conformance. The emissions are measured on the HP8546/85460A EMI System, which has automatic correction for all factors stored in memory and allows direct readings to be taken.

### 6.4 Test Results

The EUT was found to **MEET** the Conducted Emission requirements of FCC Part 15.207 and RSS GEN 7.2.2 Conducted Emissions for an Intentional Radiator. See the Data Charts and Graphs for more details of the test results.

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 27 of 39

## 6.5 FCC Limits of Conducted Emissions at the AC Mains Ports

Frequency Range (MHz)	Class B Limits (dB $\mu$ V)		Measuring Bandwidth
	Quasi-Peak	Average	
0.150 -0.50 *	66-56	56-46	RBW = 9 kHz VBW $\geq$ 9 kHz for QP VBW = 1 Hz for Average
0.5 – 5.0	56	46	
5.0 – 30	60	50	
* The limit decreases linearly with the logarithm of the frequency in this range.			

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 28 of 39

## 6.6

CONDUCTED EMISSIONS – TEST DATA CHART

Manufacturer:	API Healthcare					
Date(s) of Test:	April 12 <sup>th</sup> 2010					
Project Engineer:	Aidi Zainal					
Test Engineer:	Peter Feilen					
Voltage:	110 VAC and 230 VAC					
Operation Mode:	Normal operation					
Environmental Conditions in the Lab:	Temperature: 20 – 25 °C Relative Humidity: 30 – 60 %					
Test Location:	<input checked="" type="checkbox"/>	AC mains test bench			Chamber	
EUT Placed On:	<input checked="" type="checkbox"/>	40cm from Vertical Ground Plane			10cm Spacers	
	<input checked="" type="checkbox"/>	80cm above Ground Plane			Other:	
Measurements:	Pre-Compliance		Preliminary	<input checked="" type="checkbox"/>	Final	
Detectors Used:	Peak		<input checked="" type="checkbox"/>	Quasi-Peak	<input checked="" type="checkbox"/>	Average

**110 VAC, 60 Hz**

Frequency (MHz)	Line	QUASI-PEAK			AVERAGE		
		Q-Peak Reading (dB $\mu$ V)	Q-Peak Limit (dB $\mu$ V)	Quasi-Peak Margin (dB)	Average Reading (dB $\mu$ V)	Average Limit (dB $\mu$ V)	Average Margin (dB)
2.068	1.0	34.8	56.0	21.2	29.9	46.0	16.1
0.401	1.0	29.5	57.8	28.3	26.0	47.8	21.8
2.136	1.0	34.0	56.0	22.0	29.4	31.6	2.2
6.473	1.0	35.1	60.0	24.9	33.2	50.0	16.8
13.360	1.0	33.3	60.0	26.7	29.0	50.0	21.0
0.155	1.0	34.0	65.7	31.7	5.8	55.7	49.9
0.152	2.0	35.2	65.9	30.7	11.2	55.9	44.7
0.466	2.0	30.9	56.6	25.7	28.4	46.6	18.2
1.801	2.0	32.9	56.0	23.1	29.6	46.0	16.4
2.067	2.0	35.3	56.0	20.7	30.7	46.0	15.3
6.272	2.0	35.3	60.0	24.7	31.1	50.0	18.9
13.420	2.0	32.5	60.0	27.5	27.4	50.0	22.6

**Notes:**

- 1) The emissions listed are characteristic of the power supply used, and did not change by the EUT.
- 2) The EUT exhibited similar emissions when the AWID was inside the host.

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 29 of 39


**230 VAC, 50 Hz**

Frequency (MHz)	Line	<u>QUASI-PEAK</u>			<u>AVERAGE</u>		
		Q-Peak Reading (dB $\mu$ V)	Q-Peak Limit (dB $\mu$ V)	Quasi-Peak Margin (dB)	Average Reading (dB $\mu$ V)	Average Limit (dB $\mu$ V)	Average Margin (dB)
9.694	1.0	32.8	60.0	27.2	26.9	50.0	23.1
3.877	1.0	31.2	56.0	24.8	26.0	46.0	20.0
0.467	1.0	32.6	56.6	24.0	17.9	31.6	13.7
23.130	1.0	31.2	60.0	28.8	26.1	50.0	23.9
5.743	1.0	32.9	60.0	27.1	32.1	50.0	17.9
2.071	1.0	32.1	56.0	23.9	31.2	46.0	14.8
2.069	2.0	34.0	56.0	22.0	32.2	46.0	13.8
0.437	2.0	33.0	57.1	24.1	30.5	47.1	16.6
3.805	2.0	35.4	56.0	20.6	32.5	46.0	13.5
26.610	2.0	28.8	60.0	31.2	25.0	50.0	25.0
0.157	2.0	16.6	65.6	49.0	4.3	55.6	51.3

**Notes:**

- 1) The emissions listed are characteristic of the power supply used, and did not change by the EUT.
- 2) The EUT exhibited similar emissions when the AWID was inside the host.

## **6.7 Test Setup Photo(s) – Conducted Emissions Test**




Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 30 of 39


## 6.8 Screen Captures – Conducted Emissions Test

These screen captures represent Peak Emissions. For conducted emission measurements, both a Quasi-Peak detector function and an Average detector function are utilized. The emissions must meet both the Quasi-peak limit and the Average limit as described in 47 CFR 15.207 and RSS GEN 7.2.2.

Line 1



Line 2



Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 31 of 39

## EXHIBIT 7. OCCUPIED BANDWIDTH

### 7.1 Limits

There are no stated limits for the occupied bandwidth for devices operating under Title 47, CFR FCC Part 15.209. However, measurement of the bandwidth is required by Industry Canada per RSS GEN Section 4.6

### 7.2 Method of Measurements

ANSI C63.4, FCC and IC standard procedures were adhered to in these measurements.

The transmitter output was placed in normal operation mode. The bandwidth of the fundamental frequency was measured via radiated measurement with the Spectrum Analyzer using RBW=200 Hz and VBW=2 kHz.


### 7.3 Test Data

Mode	Center Frequency (kHz)	Measured -6 dBc Occ. BW (Hz)	Measured -20 dBc Occ. BW (Hz)
AWID outside host	125.0	235	429
AWID inside host	125.0	235	437


Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 32 of 39

## 7.4 Screen Captures - OCCUPIED BANDWIDTH

### -20 dBc Occupied Bandwidth, AWID outside host.



### -20 dBc Occupied Bandwidth, AWID inside host



Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 33 of 39

## EXHIBIT 8. BAND EDGE MEASUREMENT


### 8.1 Test Criterion

FCC 15.209(b) requires a measurement of spurious emission levels to be no higher than the fundamental emission level, in particular at the Band-Edges where the intentional radiator operates. The operation of this device shall also be limited to the frequency band between 110 kHz and 490 kHz. No components of the fundamental emission shall be allowed outside of this band.

### 8.2 Screen captures.


#### 8.2.1 AWID outside of host

Screen Capture Demonstrating Compliance at the Lower Band-Edge




Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 34 of 39

### Screen Capture Demonstrating Compliance at the Higher Band-Edge




### 8.2.2 AWID inside of host

#### Screen Capture Demonstrating Compliance at the Lower Band-Edge



Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 35 of 39

## Screen Capture Demonstrating Compliance at the Higher Band-Edge



Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 36 of 39

## APPENDIX A

 <b>LS RESEARCH LLC</b> Wireless Product Development: <b>Equipment Calibration</b>								
Date : <u>23-Mar-2010</u>								
Type Test : <u>Radiated Emissions (209)</u>								
Job # : <u>C-871</u>								
Prepared By: <u>AI DI</u>	Customer : <u>API Healthcare</u>							
		Quote #: <u>310037</u>						
No.	Asset #	Description	Manufacturer	Model #	Serial #	Cal Date	Cal Due Date	Equipment Status
1	AA 960006	Active Loop Antenna	EMCO	6502	9205-2753	9/14/2009	9/14/2011	Active Calibration
2	EE 960157	3Hz-13.2GHz Spectrum Analyzer	Agilent	E4445A	MY48250225	7/2/2009	7/2/2010	Active Calibration
3	EE 960158	RF Preselector	Agilent	N9039A	MY46520110	7/2/2009	7/2/2010	Active Calibration
4	AA 960150	Bicon Antenna	ETS	3110B	0003-3346	11/3/2009	11/3/2010	Active Calibration
5	aa 960078	Log Periodic Antenna	EMCO	93146	9701-4855	10/16/2009	10/16/2010	Active Calibration

 <b>LS RESEARCH LLC</b> Wireless Product Development <b>Equipment Calibration</b>								
Date : <u>23-Mar-2010</u>								
Type Test : <u>AC mains conducted</u>								
Job # : <u>C-871</u>								
Prepared By: <u>Aidi</u>	Customer : <u>API Healthcare</u>							
Quote #: <u>310037</u>								
No.	Asset #	Description	Manufacturer	Model #	Serial #	Cal Date	Cal Due Date	Equipment Status
1	ee 960013	EMI Receiver	HP	8546A System	3617A00320;3448A	9/17/2009	9/17/2010	Active Calibration
2	ee 960014	EMI Receiver-filter section	HP	85460A	3448A00296	9/17/2009	9/17/2010	Active Calibration
3	aa 960031	Transient Limiter	HP	11947A	3107A01708	9/15/2009	9/15/2010	Active Calibration
4	aa 960009	LISN	EMCO	3810/2NM	9509-1152	9/16/2009	9/16/2010	Active Calibration

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 37 of 39

## APPENDIX B – TEST STANDARDS: CURRENT PUBLICATION DATES

STANDARD #	DATE	Am. 1	Am. 2
ANSI C63.4	2009		
ANSI C63.10	2009		
CISPR 11	2009-05	2009-12 P	
CISPR 12	2007-05		
CISPR 14-1	2005-11	2008-11	
CISPR 14-2	2001-11	2001-11	2008-05
CISPR 16-1-1 Note 1	2010-01		
CISPR 16-1-2 Note 1	2003	2004-04	2006-07
CISPR 22	2008-09		
CISPR 24	1997-09	2001-07	2002-10
EN 55011	2009		
EN 55014-1	2006		
EN 55014-2	1997		
EN 55022	2006	2007	
EN 60601-1-2	2007-03		
EN 61000-3-2	2006-05		
EN 61000-3-3	2008-12		
EN 61000-4-2	2009-05		
EN 61000-4-3	2006-07	2008-05	
EN 61000-4-4	2004		
EN 61000-4-5	2006-12		
EN 61000-4-6	2009-05		
EN 61000-4-8	1994	2001	
EN 61000-4-11	2004-10		
EN 61000-6-1	2007-02		
EN 61000-6-2	2005-12		
EN 61000-6-3	2007-02		
EN 61000-6-4	2007-02		
FCC 47 CFR, Parts 0-15, 18, 90, 95	2009		
FCC Public Notice DA 00-1407	2000		
FCC ET Docket # 99-231	2002		
FCC Procedures	2007		
ICES 001	2006-06		
ICES 002	2009-08		
ICES 003	2004-02		
IEC 60601-1-2 Note 1	2007-03		
IEC 61000-3-2	2005-11	2008-03	2009-02
IEC 61000-3-3	2008-06		
IEC 61000-4-2	2008-12		
IEC 61000-4-3	2008-04	incl in 2008-04	2009-12 FD

*Note 1: Test not on LSR Scope of Accreditation.*

Updated on 04-27-10  
P=Project FD= Final Draft

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 38 of 39

## **APPENDIX C** **Uncertainty Statement**

This uncertainty represents an expanded uncertainty expressed at approximately the 95 % confidence level, using a coverage factor of k=2.

*Table of Expanded Uncertainty Values, (K=2) for Specified Measurements*

Measurement Type	Particular Configuration	Uncertainty Values
Radiated Emissions	3 – Meter chamber, Biconical Antenna	4.24 dB
Radiated Emissions	3-Meter Chamber, Log Periodic Antenna	4.8 dB
Radiated Emissions	10-Meter OATS, Biconical Antenna	4.18 dB
Radiated Emissions	10-Meter OATS, Log Periodic Antenna	3.92 dB
Conducted Emissions	Shielded Room/EMCO LISN	1.60 dB
Radiated Immunity	3 Volts/Meter in 3-Meter Chamber	1.128 Volts/Meter
Conducted Immunity	3 Volts level	1.0 V

Prepared For: API Healthcare	Model #:DB-RFIDEAS_CR-CD	LS Research, LLC
EUT: Casi Rusco RFID module	IC:	Template: 15.209 - v1 10-22-09
Report #:310037	FCC ID #:	Page 39 of 39