Label location

Label with **FCC ID:WP3GSD442N and IC:1467C-GSD442N** is located at the rear side panel.

Label

96mm

22mm

45mm

22mm

30mm

Model: GSD- 442 PG2(915). Supervised Indoor Wireless CO Gas Detector

⚠ **WARNING** Carbon monoxide can not be seen or smelled but it can kill you. If alarm signal sounds:
1. Operate reset/silence button.
2. Call your emergency services (fire department or 911).
3. Immediately move to fresh air – outdoors or by an open door/window.

CAUTION: Read installation instructions.
REMINDER
- Press the detector's test button once every week. Press the test button until the built-in buzzer sounds and the LEDs flashes sequentially.
- Once a month, use a vacuum cleaner to clean the air vents to keep them free of dust.
- Replace battery once a year or when a yellow LED flashes & buzzer beeps once in 60 second.
- For information contact: Visonic INC. (USA) West Dudley Town Rd. 65 Bloomfield, CT 06002. Phone: (860) 243-0833

This device complies with part 15 of the FCC rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.   **ARG H-11578**

Sensitivity based on UL 2034

Dip SW function:
Sw. 1: ON – UL Standard.
Sw. 1: OFF – EN Standard.
Sw. 2: NOT USED.

SIGNALING
Gas Detector
(UL) E309428
LISTED   NO.: X X X X X
FCC ID: WP3GSD442N
IC:1467C-GSD442N

S-303409 REV 03

14mm   **17mm**   **10mm**   **15mm**