

Proteus Digital Health, Inc.

TEST REPORT FOR

**PPM (RP4) Electronics Module
Model: SPC-0175**

Tested To The Following Standards:

**FCC Part 15 Subpart C Sections 15.247
and
RSS 210 Issue 8**

Report No.: 94175-17

Date of issue: April 2, 2013



This test report bears the accreditation symbol indicating that the testing performed herein meets the test and reporting requirements of ISO/IEC 17025 under the applicable scope of EMC testing for CKC Laboratories, Inc.

We strive to create long-term, trust based relationships by providing sound, adaptive, customer first testing services. We embrace each of our customers' unique EMC challenges, not as an interruption to set processes, but rather as the reason we are in business.

TABLE OF CONTENTS

Administrative Information	3
Test Report Information	3
Report Authorization	3
Test Facility Information	4
Software Versions	4
Site Registration & Accreditation Information	4
Summary of Results	5
Conditions During Testing	5
Equipment Under Test	6
Peripheral Devices	6
FCC Part 15 Subpart C	7
15.31(e) Voltage Variations	7
15.247(a)(1) RF Power Output	9
15.247(a)(1)(iii) Average time of Occupancy	12
-20dBc & 99% Occupied Bandwidth	58
Bandedge	66
15.247(d) Radiated of Spurious Emissions	71
Supplemental Information	196
Measurement Uncertainty	196
Emissions Test Details	196

ADMINISTRATIVE INFORMATION

Test Report Information

REPORT PREPARED FOR:

Proteus Digital Health, Inc.
2600 Bridge Parkway Suite 101
Redwood City, CA 94065

Representative: Robert Leichner
Customer Reference Number: C29833

DATE OF EQUIPMENT RECEIPT:**DATE(S) OF TESTING:****REPORT PREPARED BY:**

Dianne Dudley
CKC Laboratories, Inc.
5046 Sierra Pines Drive
Mariposa, CA 95338

Project Number: 94175

March 12, 2013

March 12-April 18, 2013

Report Authorization

The test data contained in this report documents the observed testing parameters pertaining to and are relevant for only the sample equipment tested in the agreed upon operational mode(s) and configuration(s) as identified herein. Compliance assessment remains the client's responsibility. This report may not be used to claim product endorsement by A2LA or any government agencies. This test report has been authorized for release under quality control from CKC Laboratories, Inc.

A handwritten signature in black ink that reads "Steve Behm". The signature is written in a cursive style and is positioned above a horizontal line.

Steve Behm
Director of Quality Assurance & Engineering Services
CKC Laboratories, Inc.

Test Facility Information



Our laboratories are configured to effectively test a wide variety of product types. CKC utilizes first class test equipment, anechoic chambers, data acquisition and information services to create accurate, repeatable and affordable test results.

TEST LOCATION(S):
CKC Laboratories, Inc.
1120 Fulton Place
Fremont, CA 94539

Software Versions

CKC Laboratories Proprietary Software	Version
EMITest Emissions	5.00.14
Immunity	5.00.07

Site Registration & Accreditation Information

Location	CB #	TAIWAN	CANADA	FCC	JAPAN
Fremont	US0082	SL2-IN-E-1148R	3082B-1	958979	A-0149

SUMMARY OF RESULTS

Standard / Specification: FCC Part 15 Subpart C 15.247 and RSS 210 Issue 8

Description	Test Procedure/Method	Results
Voltage Variation	FCC Part 15 Subpart C Section 15.31(e)	Pass
RF Power Output	FCC Part 15 Subpart C Section 15.247(a)(1) / DA 00-705	Pass
Average Time of Occupancy	FCC Part 15 Subpart C 15.247 (a)(1)(iii) / DA 00-705	Pass
-20dBc & 99% Occupied Bandwidth	FCC Part 15 Subpart C Section 15.247 / DA 00-705 / RSS 210 Issue 8	Pass
Bandedge	FCC Part 15 Subpart C / ITU-R 55/1/ DA 00-705	Pass
Radiated Spurious Emissions	FCC Part 15 Subpart C Section 15.247(d)	Pass

Conditions During Testing

This list is a summary of the conditions noted for or modifications made to the equipment during testing.

Summary of Conditions
Modifications during testing: Two ferrites (742 700 32) on a cable which connects from the EUT to a DC power supply with one pass through.
At the time of testing the serial numbers and software versions used were not supplied to the test engineers. The manufacturer declares that the following serial numbers and configurations were used:
SPC-0175 Hardware: - Part number: SPC-0175, Rev 3: Electronics Module, RP4 - Serial numbers: 000013241, 000013242, 000013243
Software Used supporting external control of Bluetooth radio: - Firmware: (test firmware for external control of Bluetooth radio) - Microcontroller: "External UART Control" (SVN repository # 3989) - Bluetooth radio: Intel "HCI_UART_115200bps.eep" dated 2/27/2008 - PC Application: Intel "HCI_Lite_V3.02.exe"

EQUIPMENT UNDER TEST (EUT)

EQUIPMENT UNDER TEST

PPM (RP4) Electronic Module

Manuf: Proteus Digital Health, Inc.

Model: SPC-0175

Serial: None

PERIPHERAL DEVICES

The EUT was tested with the following peripheral device(s):

Laptop AC/DC Power Adapter

Manuf: Dell

Model: D130PE1-00

Serial: CN-0JU012-48661-09U-K8GG-A04

Laptop

Manuf: Dell

Model: Latitude E6500

Serial: B76FVL1

USB to TTL Serial Cable-1.8m Wire End Version

Manuf: FTDI

Model: TTL-232RG-VREG1V8-WE

Serial: None

DC Power Supply

Manuf: EZ

Model: GP-4303A

Serial: 01070038

FCC PART 15 SUBPART C

This report contains EMC emissions test results under United States Federal Communications Commission (FCC) 47 CFR 15C requirements for Unlicensed Radio Frequency Devices, Subpart C - Intentional Radiators.

15.31(e) Voltage Variations

Test Conditions / Setup

Test Location: CKC Laboratories, Inc. • 1120 Fulton Places • Fremont, CA 94539 • (510) 249-1170

Customer: **Proteus Digital Health, Inc.**

Specification: **15.31(e)**

Work Order #: **94175**

Date: 3/12/2013

Time: 14:47:55

Equipment: **PPM (RP4) Electronics Module**

Sequence#: 3

Manufacturer: Proteus Digital Health, Inc.

Tested By: Hieu Song Nguyenpham

Model: SPC-0175

S/N: None

Test Equipment:

ID	Asset #	Description	Model	Calibration Date	Cal Due Date
	ANP05843	Cable	32022-2-29094K-48TC	8/7/2012	8/7/2014
	AN02668	Spectrum Analyzer	E4446A	2/22/2013	2/22/2015

Equipment Under Test (* = EUT):

Function	Manufacturer	Model #	S/N
PPM (RP4) Electronic Module*	Proteus Digital Health, Inc.	SPC-0175	None

Support Devices:

Function	Manufacturer	Model #	S/N
Laptop AC/DC Power Adapter	Dell	D130PE1-00	CN-0JU012-48661-09U-K8GG-A04
Laptop	Dell	Latitude E6500	B76FVL1
DC power Supply	EZ	GP-4303A	01070038
USB to TTL Serial Cable-1.8m	FTDI	TTL-232RG-VREG1V8-WE	None
Wire End Version			

Test Conditions / Notes:

The EUT is a battery device, and it is adaptive equipment. The EUT is placed on the test bench. The measurement is performed at the antenna port. The service port is connected to a laptop for testing configuration purposes. Instead of using a fresh battery, the EUT is connected to a DC power supply at 2.4V

Temperature: 19.9°C

Humidity: 40 %

Atmospheric Pressure: 101.9kPa

High Clock: 26Mhz

Software Used: HCI Lite

Rate power = +4dBm (nominal)

Transmitter Operation Frequency Range: 2400 - 2483.5 MHz

Low Channel: 2402MHz

Middle Channel: 2441Mhz

High Channel: 2480MHz

15.31(e) A fresh battery is used.

10dB External attenuation, 1.72 dB gain of the antenna and 0.9dB cable loss compensated as amplitude offset entered into the spectrum analyzer.

15.247(a)(1) RF Power Output

Test Location: CKC Laboratories, Inc • 1120 Fulton Places • Fremont, CA 94539 • (510) 249-1170

Customer: **Proteus Digital Health, Inc.**

Specification: **15.247(a)(1) Power Output (2400-2483.5 MHz FHSS)**

Work Order #: **94175**

Date: 4/18/2013

Test Type: **Radiated Scan**

Time: 10:45:01

Equipment: **PPM (RP4) Electronic Module**

Sequence#: 1

Manufacturer: Proteus Digital Health, Inc

Tested By: Hieu Song Nguyenpham

Model: SPC-0175

S/N: 000013241

Test Equipment:

ID	Asset #	Description	Model	Calibration Date	Cal Due Date
T1	ANP01211	Attenuator	PE7002-10	4/2/2013	4/2/2015
T2	ANP05843	Cable	32022-2-29094K-48TC	8/7/2012	8/7/2014
	AN02668	Spectrum Analyzer	E4446A	2/22/2013	2/22/2015

Equipment Under Test (* = EUT):

Function	Manufacturer	Model #	S/N
PPM (RP4) Electronic Module*	Proteus Digital Health, Inc	SPC-0175	000013241

Support Devices:

Function	Manufacturer	Model #	S/N
Laptop AC/DC Power Adapter	Dell	D130PE1-00	CN-0JU012-48661-09U-K8GG-A04
Laptop	Dell	Latitude E6500	B76FVL1
USB to TTL Serial Cable-1.8m Wire End Version	FTDI	TTL-232RG-VREG1V8-WE	None

Test Conditions / Notes:

The EUT is a battery device. The EUT is placed on the test bench. The measurement is performed at the antenna port.

The service port is connected to a laptop for testing configuration purposes. Instead of using a fresh battery, the EUT is connected to a DC power supply at 2.4V

Temperature: 22.9°C

Humidity: 32 %

Atmospheric Pressure: 102.4 kPa

High Clock: 26Mhz

Software Used: HCI_Lite_V3.02.exe

Rate power of chip = +4dBm

Transmitter Operation Frequency Range: 2400 - 2483.5 MHz

Low Channel: 2402MHz

Middle Channel: 2441Mhz

High Channel: 2480MHz

RBW=VBW=3MHz

Bit Pattern: 10101010

Table of RF power in WATTS for 3 modes

Ref	Freq in MHz	Meter dBμV	Factors	Dist	Corr	Power Output in Watt	Notes
1	2401.995	79.8	10.9	0	90.7	2.34423E-05	Low Channel GFSK
2	2401.995	78.4	10.9	0	89.3	1.69824E-05	Low Channel QPSK
3	2401.995	78	10.9	0	88.9	1.54882E-05	Low channel 8PSK
4	2441.026	77.8	10.9	0	88.7	1.47911E-05	Middle Channel GFSK
5	2441.026	76.1	10.9	0	87	0.00001	Middle Channel QPSK
6	2441.026	75.8	10.9	0	86.7	9.33254E-06	Middle Channel 8PSK
7	2479.95	77	10.9	0	87.9	1.23027E-05	High Channel GFSK
8	2479.95	74.8	10.9	0	85.7	7.4131E-06	High Channel QPSK
9	2479.95	74.5	10.9	0	85.4	6.91831E-06	High Channel 8PSK

Limit:

15.247(a)(1) Frequency hopping systems shall have hopping channel carrier frequencies separated by a minimum of 25 kHz or the 20 dB bandwidth of the hopping channel, whichever is greater. Alternatively, frequency hopping systems operating in the 2400-2483.5 MHz band may have hopping channel carrier frequencies that are separated by 25 kHz or two-thirds of the 20 dB bandwidth of the hopping channel, whichever is greater, provided the systems operate with an output power no greater than **125 mW**.

Test Setup Photos

