

FCC Part 15, Subpart C, Section 15.247

Test Report

On

Ruggedized Wireless Structural Health Monitoring Node FCC ID: XJQMSLINK0008

Customer Name: Lord Corporation

Customer P.O: 702539

Date of Report: November 17, 2017

Test Report No: R-6265N-1

Test Start Date: October 18, 2017

Test Finish Date: October 27, 2017

Test Technician: M. Seamans

Report Approved By: T. Hannemann

Report Prepared By: J. Ramsey

Our letters, procedures and reports are for the exclusive use of the customer to whom they are addressed and their communication or the use of the name of Retlif Testing Laboratories must receive our prior written approval. Our letters, procedures and reports apply only to the sample tested and are not necessarily indicative of the qualities of apparently identical or similar products. The letters, procedures and reports and the name of Retlif Testing Laboratories or insignia are not to be used under any circumstances in advertising to the general public. This test report shall not be reproduced, except in full, without the written approval of Retlif Testing Laboratories.

Technical Information

Report Number: R-6265N-1

Customer: Lord Corporation

Address: 459 Hurricane Lane, Suite 102

Williston, VT 05495

Manufacturer: Lord Corporation

Manufacturer Address: 459 Hurricane Lane, Suite 102

Williston, VT 05495

Test Sample: Ruggedized Wireless Structural Health Monitoring Node

Model Number: SHM-Link-201

Serial Number: 6329-0150-00001

FCC ID: XJQMSLINK0008

Digital Transmission – Direct Sequence Spread Spectrum

Type: Transmitter

Power Requirements: 3.6 VDC Internal Battery

Frequency of Operation: 2402.0 to 2480.0 MHz

Modulations: LXRS, LXRS+

Equipment Class: DTS

Antenna Type: Internal Chip Antenna 1.5 dBi Gain

Equipment Use: Wireless Data Node

Test Specification:

FCC Rules and Regulations Part 15, Subpart C, Section 15.247

Test Procedure:

ANSI C63.4: 2014 ANSI C63.10: 2013

Test Facility:

Retlif Testing Laboratories 101 New Boston Road Goffstown, NH 03045

FCC Designation Number: US5327



Retlif Testing Laboratories

Table 1 – Tests Performed

FCC Part 15, Subpart C	Test Method
15.247(b)(3)	Power Output
15.247(a)(2)	Occupied Bandwidth
15.247(d)	Antenna Terminal Out of Band/Band Edge Conducted Emissions
15.247(d)	Out of Band/Band Edge Radiated Emissions
15.247(e)	Power Density

EUT Operation:

The EUT was transmitting a modulated signal at 2.405 GHz (Channel 11), 2.440 GHz (Channel 18) and 2.480 GHz (Channel 26).

EUT Description:

The SHM-Link-201 Structural Health Monitoring Node is used for in-situ, multidimensional measurement and analysis of component strain and fatigue.

All equipment that was utilized to achieve the EUT operating state is specified in the table below:

Table 2 – Support Equipment

Description	Manufacturer	Model Number	Serial Number
Wireless Gateway	Lord Corporation	WSDA-200-USB	6307-2040-00086
Laptop	Gateway	NE56R52U	NXY1UAA045348501F63400



Retlif Testing Laboratories

Certification and Signatures

We certify that this report is a true representation of the results obtained from the tests of the equipment stated. We further certify that the measurements shown in this report were made in accordance with the procedures indicated and vouch for the qualifications of all Retlif Testing Laboratories personnel taking them.

Scott Wentworth Branch Manager

Low Wenter

NVLAP Approved Signatory

Todd Hannemann EMC Test Engineer

iNARTE Certified Technician ATL-0255-T

Non-Warranty Provision

The testing services have been performed, findings obtained and reports prepared in accordance with generally accepted laboratory principles and practices. This warranty is in lieu of all others, either expressed or implied.

Non-Endorsement

This test report contains only findings and results arrived at after employing the specific test procedures and standards listed herein. It is not intended to constitute a recommendation, endorsement or certification of the product or material tested. This test report must not be used by the client to claim product endorsement by NVLAP or any agency of the U.S. Government.



Retlif Testing Laboratories

Revision History

Revisions to this document are listed below; the latest revised document supersedes all previous issues of this document:

Revision	Date	Pages Affected
-	November 17, 2017	Original Release



Retlif Testing Laboratories

Requirements and Test Results

FCC Section 15.247 (a)(2) - Bandwidth

For systems using digital modulation techniques operating in the 902-928 MHz, 2400-2483.5 MHz, and 5725 – 5850 MHz bands the minimum 6 dB bandwidth shall be at least 500 kHz.

Results:

The minimum 6dB bandwidth measured while transmitting was 1.675 MHz. The device was found to meet the requirement of 15.247 (a)(2).

FCC Section 15.247 (b)(3) - Power Output

For systems using digital modulation in the 902-928 MHz, 2400-2483.5 MHz, and 5725-5850 MHz bands: 1 Watt. As an alternative to a peak power measurement, compliance with the one Watt limit can be based on a measurement of the maximum conducted output power. Maximum Conducted Output Power is defined as the total transmit power delivered to all antennas and antenna elements averaged across all symbols in the signaling alphabet when the transmitter is operating at its maximum power control level. Power must be summed across all antennas and antenna elements. The average must not include any time intervals during which the transmitter is off or is transmitting at a reduced power level. If multiple modes of operation are possible (e.g.: alternative modulation methods), the maximum conducted output power is the highest total transmit power occurring in any mode.

Results:

The maximum measured peak conducted output power when transmitting was 16.79 mW. The maximum antenna gain of the antenna is 1.5 dBi. The device was found to meet the power output requirements of 15.247 (b)(3) including de facto EIRP.



Retlif Testing Laboratories

Requirements and Test Results (con't)

FCC Section 15.247(d) – Unwanted Emissions

Antenna Terminal Out of Band/Band Edge Conducted Emissions

In any 100 kHz bandwidth outside the frequency band in which the spread spectrum or digitally modulated intentional radiator is operating, the radio frequency power that is produced by the intentional radiator shall be at least 20 dB below that in the 100 kHz bandwidth within the band that contains the highest level of the desired power, based on either an RF conducted or a radiated measurement, provided the transmitter demonstrates compliance with the peak conducted power limits. If the transmitter complies with the conducted power limits based on the use of RMS averaging over a time interval, as permitted under Paragraph (b)(3) of Section 15.247, the attenuation required under this paragraph shall be 30 dB instead of 20 dB. Attenuation below the general limits specified in Section 15.209(a) is not required. In addition, radiated emissions which fall in the restricted bands, as defined in Section 15.205(a) must also comply with the radiated emission limits specified in Section 15.209(a) (see Section 15.205(c)).

Results:

All measured out of band/band edge conducted emissions were below the specified limits and the device was found to meet the requirements of 15.247 (d).

FCC Section 15.247(d) – Unwanted Emissions

Radiated Spurious Emissions/Restricted Bands/Band Edge

Emissions which fall into restricted bands, as defined in 15.205(a) must comply with the radiated emissions limits specified in 15.209(a) and shown below in Table 3. Emissions emanating from the EUT cabinet and cables must also comply with the radiated emissions limits. Radiated emissions measurements were also performed at the band edges to ensure band edge compliance.

Frequency of Emission (MHz)	Field Strength (microvolts/meter)	Measurement Distance (meters)
30 to 88	100	3
88 to 216	150	3
216 to 960	200	3
Above 960	500	3

Table 3 - Radiated Emission Limits

Results:

All spurious emissions were measured and found to be in compliance with the limits specified in 15.209(a). Band edge emissions were also found to be in compliance with the limits specified in 15.209(a).



Retlif Testing Laboratories

Requirements and Test Results (con't)

FCC Section 15.247(e) - Power Spectral Density

For digitally modulated systems, the power spectral density conducted from the intentional radiator to the antenna shall not be greater than 8 dBm in any 3 kHz band during any time interval of continuous transmission. This power spectral density shall be determined in accordance with the provisions of paragraph (b) of this section. The same method of determining the conducted output power shall be used to determine the power spectral density.

Results:

The power spectral density conducted from the intentional radiator to the antenna was not greater than 8 dBm in any 3 kHz band during any time interval of continuous transmission. This power spectral density was determined in accordance with Section 15.247(b)(3), herein.



Retlif Testing Laboratories

Requirements and Test Results (con't)

Field Strength Calculation/Conversion:

The maximized field strength of the emission was obtained as follows:

CR = MR + CF

Where:

CR = Corrected Reading in dBµV/m

MR = Uncorrected Meter Reading in dBµV

CF = Correction Factor in dB (Antenna Factor, Pre-amp + Cable Loss)

Example:

 $MR = 15.35 dB\mu V$

CF = 16.85 dB

 $CR = 15.35 \text{ dBuV} + 16.85 = 32.2 \text{ dB}\mu\text{V/m}$

dBµV/M is converted to uV/M for comparison to the specified limit using the formula:

invLog dBµV/M/20

32.2 dBuV/m = 40.74 uV/m

RF Power Conversion:

Power readings in dBm may be converted to mW using the formula:

InvLog dBm/10

Example: 20dBm = 100mW



Retlif Testing Laboratories

FCC Section 15.247 (i) RF Exposure Limits

Spread Spectrum Transmitters operating under 15.247 must be operated in a manner that ensures the public is not exposed to RF energy levels in access of the commission's guidelines. Based on the transmitter power and maximum antenna gain (see calculation below) the minimum separation distance was calculated to determine the distance for acceptable MPE power density levels to meet both the Occupational/Controlled Exposure and the General Population/Uncontrolled Exposure requirements of FCC Part 1.1310. The calculation below uses the more stringent General Population MPE Limits.

$$S = \frac{PG}{4 \prod Dsq}$$

D = Minimum Separation Distance in cm

S = Max allowed Power Density in mW/cmsq

Per 1.1310 For the Frequency of 2400 MHz S = 1 mW/cmsq

Power = Max Power Input to Antenna = 16.79 mW

Gain = Max Power Gain of Antenna = 1.5 dBi = 1.41 numeric

1.0 mW/cmsq =
$$\frac{16.79 \times 1.41}{4 \times (3.14) \times D^2}$$
 = $\frac{23.71}{12.56 \times D^2}$

$$D^2 = \frac{23.71}{12.56x1.0}$$

$$D =)1.88 = 1.37 \text{ cm}$$



Retlif Testing Laboratories

Equipment List

FCC Section 15.247(a)(2) Occupied Bandwidth

EN	Manufacturer	Description	Range	Model No.	Cal Date	Due Date
5134	NARDA MICROWAV	E ATTENUATOR, COAXIAL	10 dB, DC - 12.4 GHz	757C-10	12/2/2016	12/31/2017
5231	AGILENT / HP	ANALYZER, SPECTRUM	3 Hz - 26.5 GHz	E4440A	5/24/2017	5/31/2018

FCC Section 15.247 (d) Band Edge Conducted Emissions

EN	Manufacturer	Description	Range	Model No.	Cal Date	Due Date
5134	NARDA MICROWAVI	E ATTENUATOR, COAXIAL	10 dB, DC - 12.4 GHz	757C-10	12/2/2016	12/31/2017
5231	AGILENT / HP	ANALYZER, SPECTRUM	3 Hz - 26.5 GHz	E4440A	5/24/2017	5/31/2018

FCC Section 15.247(b)(3) Power Output

EN	Manufacturer	Description	Range	Model No.	Cal Date	Due Date
5134	NARDA MICROWAV	E ATTENUATOR, COAXIAL	10 dB, DC - 12.4 GHz	757C-10	12/2/2016	12/31/2017
5231	AGILENT / HP	ANALYZER, SPECTRUM	3 Hz - 26.5 GHz	E4440A	5/24/2017	5/31/2018

FCC Section 15.247 (d) Out of Band/Band Edge Radiated Emissions

EN	Manufacturer	Description	Range	Model No.	Cal Date	Due Date
1232	AGILENT / HP	PRE-AMPLIFIER	1 - 26.5 GHz	8449B	5/23/2017	5/31/2018
3258	ETS / EMCO	ANTENNA, DOUBLE RIDGED GUIDE	1 - 18 GHz	3115	10/13/2016	4/30/2018
3427B	ETS / EMCO	ANTENNA, BICONICAL	20 - 200 MHz	3104	9/21/2017	3/31/2019
3430	MCS	ANTENNA, HORN	18 - 26.5 GHz	K-5039	No Calibrati	on Required
4029B	RETLIF	OPEN AREA TEST SITE, ATTENUATION	3 / 10 Meters	RNH	4/13/2016	4/30/2018
443	ELECTRO-METRICS	ANTENNA, LOG PERIODIC	200 MHz - 1000 MHz	LPA-25	10/6/2016	4/30/2018
5070	ROHDE & SCHWARZ	RECEIVER, EMI	20 Hz - 40 GHz	ESIB40	10/21/2016	10/31/2017
5188	Cybertron	COMPUTER, CONTROL	N/A	TSVQJA2221	No Calibrati	on Required



Retlif Testing Laboratories

Equipment List_(continued)

FCC Section 15.247(e) Power Density

EN	Manufacturer	Description	Range	Model No.	Cal Date	Due Date
5134	NARDA MICROWAV	E ATTENUATOR, COAXIAL	10 dB, DC - 12.4 GHz	757C-10	12/2/2016	12/31/2017
5231	AGII ENT / HP	ANALYZER SPECTRUM	3 Hz - 26 5 GHz	F4440A	5/24/2017	5/31/2018



Retlif Testing Laboratories


Test Photographs Occupied Bandwidth




Test Setup



Retlif Testing Laboratories




	EMISSIONS TEST DATA SHEET	
Method:	Occupied Bandwidth	
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (a)(2)	
Job Number:	R-6265N-1	
Customer:	Lord Corporation	
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node	
Model Number:	SHM-Link-201	
Serial Number:	6329-0150-00001	
Operating Mode:	Transmitting modulated (LXRS) signal at 2.405GHz	
Technician:	Technician: M.Seamans	
Date(s):	Date(s): October 18 th , 2017	
Temp/ Relative Humidity:	20.7 °C / 39.1 %	
Notes:	6dB Bandwidth: 1.675 MHz	






	EMISSIONS TEST DATA SHEET	
Method:	Occupied Bandwidth	
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (a)(2)	
Job Number:	R-6265N-1	
Customer:	Lord Corporation	
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node	
Model Number:	SHM-Link-201	
Serial Number:	6329-0150-00001	
Operating Mode:	Transmitting modulated (LXRS) signal at 2.440GHz	
Technician:	Technician: M.Seamans	
Date(s):	Date(s): October 18 th , 2017	
Temp/ Relative Humidity:	20.7 °C / 39.1 %	
Notes:	6dB Bandwidth: 1.675 MHz	






	EMISSIONS TEST DATA SHEET	
Method:	Occupied Bandwidth	
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (a)(2)	
Job Number:	R-6265N-1	
Customer:	Lord Corporation	
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node	
Model Number:	SHM-Link-201	
Serial Number:	6329-0150-00001	
Operating Mode:	Transmitting modulated (LXRS) signal at 2.480GHz	
Technician:	n: M.Seamans	
Date(s):	(s): October 18 th , 2017	
Temp/ Relative Humidity:	20.7 °C / 39.1 %	
Notes:	6dB Bandwidth: 1.675 MHz	






EMISSIONS TEST DATA SHEET	
Method:	Occupied Bandwidth
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (a)(2)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS+) signal at 2.405GHz
Technician:	M.Seamans
Date(s):	October 18 th , 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	6dB Bandwidth: 2.242 MHz






EMISSIONS TEST DATA SHEET	
Method:	Occupied Bandwidth
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (a)(2)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS+) signal at 2.440GHz
Technician:	M.Seamans
Date(s):	October 18 th , 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	6dB Bandwidth: 2.242 MHz





EMISSIONS TEST DATA SHEET	
Method:	Occupied Bandwidth
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (a)(2)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS+) signal at 2.480GHz
Technician:	M.Seamans
Date(s):	October 18 th , 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	6dB Bandwidth: 2.242 MHz






Test Photographs Power Output




Test Setup



Retlif Testing Laboratories




EMISSIONS TEST DATA SHEET	
Method:	Power Output
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (b)(3)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS) signal at 2.405GHz
Technician:	M.Seamans
Date(s):	October 18 th , 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Power Output: 12.14 dBm






EMISSIONS TEST DATA SHEET	
Method:	Peak Power Output
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (b)(3)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS) signal at 2.440GHz
Technician:	M.Seamans
Date(s):	October 18 th , 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Power Output: 11.66 dBm






EMISSIONS TEST DATA SHEET	
Method:	Peak Power Output
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (b)(3)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS) signal at 2.480GHz
Technician:	M.Seamans
Date(s):	October 18 th , 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Power Output: 11.23 dBm






EMISSIONS TEST DATA SHEET	
Method:	Power Output
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (b)(3)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS+) signal at 2.405GHz
Technician:	M.Seamans
Date(s):	October 18 th , 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Power Output: 12.25 dBm






EMISSIONS TEST DATA SHEET	
Method:	Peak Power Output
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (b)(3)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS+) signal at 2.440GHz
Technician:	M.Seamans
Date(s):	October 18 th , 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Power Output: 11.77 dBm





EMISSIONS TEST DATA SHEET	
Method:	Peak Power Output
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (b)(3)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS+) signal at 2.480GHz
Technician:	M.Seamans
Date(s):	October 18 th , 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Power Output: 11.35 dBm






Test Photographs Antenna Terminal Out of Band/Band Edge Conducted Emissions




Test Setup




Retlif Testing Laboratories






EMISSIONS TEST DATA SHEET	
Method:	Conducted Out of Band
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (d)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS) signal at 2.405GHz
Technician:	M.Seamans
Date(s):	October 18 th , 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Limit: -7.8 dBm






EMISSIONS TEST DATA SHEET	
Method:	Conducted Out of Band
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (d)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS) signal at 2.405GHz
Technician:	M.Seamans
Date(s):	October 18th, 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Limit: -7.8 dBm






EMISSIONS TEST DATA SHEET	
Method:	Conducted Out of Band
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (d)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS) signal at 2.440GHz
Technician:	M.Seamans
Date(s):	October 18 th , 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Limit: -7.8 dBm






EMISSIONS TEST DATA SHEET	
Method:	Conducted Out of Band
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (d)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS) signal at 2.440GHz
Technician:	M.Seamans
Date(s):	October 18 th , 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Limit: -7.8 dBm






EMISSIONS TEST DATA SHEET	
Method:	Conducted Out of Band
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (d)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS) signal at 2.480GHz
Technician:	M.Seamans
Date(s):	October 18th, 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Limit: -7.8 dBm






EMISSIONS TEST DATA SHEET	
Method:	Conducted Out of Band
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (d)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS) signal at 2.480GHz
Technician:	M.Seamans
Date(s):	October 18 th , 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Limit: -7.8 dBm






EMISSIONS TEST DATA SHEET	
Method:	Conducted Out of Band
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (d)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS+) signal at 2.405GHz
Technician:	M.Seamans
Date(s):	October 18 th , 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Limit: -7.8 dBm






EMISSIONS TEST DATA SHEET	
Method:	Conducted Out of Band
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (d)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS+) signal at 2.405GHz
Technician:	M.Seamans
Date(s):	October 18 th , 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Limit: -7.8 dBm






EMISSIONS TEST DATA SHEET	
Method:	Conducted Out of Band
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (d)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS+) signal at 2.440GHz
Technician:	M.Seamans
Date(s):	October 18 th , 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Limit: -7.8 dBm






EMISSIONS TEST DATA SHEET	
Method:	Conducted Out of Band
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (d)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS+) signal at 2.440GHz
Technician:	M.Seamans
Date(s):	October 18 th , 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Limit: -7.8 dBm






EMISSIONS TEST DATA SHEET	
Method:	Conducted Out of Band
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (d)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS+) signal at 2.480GHz
Technician:	M.Seamans
Date(s):	October 18th, 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Limit: -7.8 dBm







EMISSIONS TEST DATA SHEET	
Method:	Conducted Out of Band
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (d)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS+) signal at 2.480GHz
Technician:	M.Seamans
Date(s):	October 18 th , 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Limit: -7.8 dBm








EMISSIONS TEST DATA SHEET	
Method:	Band Edge
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (d)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS) signal at 2.405GHz
Technician:	M.Seamans
Date(s):	October 18 th , 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Limit: -7.8 dBm






EMISSIONS TEST DATA SHEET	
Method:	Band Edge
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (d)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS) signal at 2.480GHz
Technician:	M.Seamans
Date(s):	October 18 th , 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Limit: -7.8 dBm






EMISSIONS TEST DATA SHEET	
Method:	Band Edge
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (d)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS+) signal at 2.405GHz
Technician:	M.Seamans
Date(s):	October 18th, 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Limit: -7.8 dBm





EMISSIONS TEST DATA SHEET	
Method:	Band Edge
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (d)
Job Number:	R-6265N-1
Customer:	Lord Corporation
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node
Model Number:	SHM-Link-201
Serial Number:	6329-0150-00001
Operating Mode:	Transmitting modulated (LXRS+) signal at 2.480GHz
Technician:	M.Seamans
Date(s):	October 18 th , 2017
Temp/ Relative Humidity:	20.7 °C / 39.1 %
Notes:	Limit: -7.8 dBm







Test Setup



Retlif Testing Laboratories



Horizontal Antenna Polarization, 30 MHz to 200 MHz, Biconical Antenna



Vertical Antenna Polarization, 30 MHz to 200 MHz, Biconical Antenna



Retlif Testing Laboratories



Horizontal Antenna Polarization, 200 MHz to 1 GHz, Log Periodic



Vertical Antenna Polarization, 200 MHz to 1 GHz, Log Periodic



Retlif Testing Laboratories



Horizontal Antenna Polarization, 1 GHz to 18 GHz



Vertical Antenna Polarization, 1 GHz to 18 GHz



Retlif Testing Laboratories




Horizontal Antenna Polarization, 18 GHz to 25 GHz



Vertical Antenna Polarization, 18 GHz to 25 GHz



Retlif Testing Laboratories



RETLIF TESTING LABORATORIES		
EMISSIONS TEST DATA SHEET		
Test Method	Unwanted Emissions into Restricted Frequency Bands	
Customer	Lord Corporation	
Job Number	R-6265N-1	
Test Sample	Ruggedized Wireless Structural Health Monitoring Node	
Model Number	SHM-Link-201	
Serial Number	6329-0150-00001	
Test Specification	FCC Part 15 Subpart C	Paragraph: 15.247(d)
Operating Mode	Transmitting modulated signal at 2405 MHz, 2440 MHz and 2480 MHz consecutive	utively.
Technician	M. Seamans	
Date	October 27 th , 2017	

	TEST PARAMETERS							
Restricted Band	Measured Frequency	Meter Reading	Correction Factor	Corrected Reading			Converted Reading	Limit at 3M
MHz	MHz	dBuV	dB	dBuV/m			uV/m	uV/m
37.50	-	-	-	-			-	100.00
	38.00	4.30	14.20	18.50	*		8.41	I
38.25	-	-	-	-			-	100.00
73.00	-	-	-	-			-	100.00
	74.00	15.54	8.36	23.90	*		15.67	I
74.60	-	-	-	-			1	100.00
74.80	-	-	-	-			-	100.00
	75.00	10.04	8.36	18.40	*		8.32	
75.20	-	-	-	-			-	100.00
108.00	-	-	-	-			-	150.00
	115.00	6.08	10.02	16.10	*		6.38	
	-	-	-	-			-	
121.94	-	-	-	-			-	150.00
123.00	-	-	-	-			-	150.00
	130.00	6.66	9.44	16.10	*		6.38	
	-	-	-	-			-	
138.00	-	-	-	-			-	150.00

No EUT emissions within 10 dB of the specified test limit were observed at the specified test distance throughout the given frequency spectrum. * This emission is not from the EUT. It is a measurement of minimum measurement system sensitivity (Noise Floor).

Data Sheet 1 of 7



Retlif Testing Laboratories

	RETLIF TESTING LABORATORIES ==				
	EMISSIONS TEST DATA SHEET				
Test Method	Unwanted Emissions into Restricted Frequency Bands				
Customer	Lord Corporation				
Job Number	R-6265N-1				
Test Sample	Ruggedized Wireless Structural Health Monitoring Node				
Model Number	SHM-Link-201				
Serial Number	6329-0150-00001				
Test Specification	FCC Part 15 Subpart C	Paragraph: 15.247(d)			
Operating Mode	Transmitting modulated signal at 2405 MHz, 2440 MHz and 2480 MHz consecutively.				
Technician	M. Seamans				
Date	October 27 th , 2017				

TEST PARAMETERS							
Restricted Band	Measured Frequency	Meter Reading	Correction Factor	Corrected Reading		Converted Reading	Limit at 3M
MHz	MHz	dBuV	dB	dBuV/m		uV/m	uV/m
149.90	-	-	-	-		-	150.00
	150.00	4.03	11.17	15.20	*	5.75	
150.05	-	-	-	-		-	150.00
156.52	-	-	-	-		-	150.00
	156.52	4.22	12.08	16.30	*	6.53	
156.52	-	-	-	-		-	150.00
156.70	-	_	-	-		-	150.00
	156.80	4.18	12.12	16.30	*	6.53	
156.90	-	-	-	-		-	150.00
162.01	-		-	-			150.00
	165.00	4.72	12.68	17.40	*	7.41	
167.17	-	-	-	-		-	150.00
167.72	-	-	-	-		-	150.00
	170.00	5.60	12.80	18.40	*	8.32	
173.20	-	-	-	-		-	150.00
		_					

No EUT emissions within 10 dB of the specified test limit were observed at the specified test distance throughout the given frequency spectrum. * This emission is not from the EUT. It is a measurement of minimum measurement system sensitivity (Noise Floor).

Data Sheet 2 of 7



Retlif Testing Laboratories

	= RETLIF TESTING LABORATORIES ==					
	EMISSIONS TEST DATA SHEET					
Test Method	Unwanted Emissions into Restricted Frequency Bands					
Customer	Lord Corporation					
Job Number	R-6265N-1					
Test Sample	Ruggedized Wireless Structural Health Monitoring Node					
Model Number	SHM-Link-201					
Serial Number	6329-0150-00001					
Test Specification	FCC Part 15 Subpart C	Paragraph: 15.247(d)				
Operating Mode	erating Mode Transmitting modulated signal at 2405 MHz, 2440 MHz and 2480 MHz consecutively.					
Technician	M. Seamans					
Date	October 27 th , 2017					

	TEST PARAMETERS							
Restricted Band	Measured Frequency	Meter Reading	Correction Factor	Corrected Reading		Converted Reading	Limit at 3M	
MHz	MHz	dBuV	dB	dBuV/m		uV/m	uV/m	
240.00	-	-	-	-	<u> </u>	-	200.00	
	260.00	-0.85	16.85	16.00	*	6.31		
285.00	-	-	-			-	200.00	
322.80	-	-	-			-	200.00	
	330.00	-0.71	18.91	18.20	*	8.13		
335.40	-	-	-			-	200.00	
399.90	-	-	-			-	200.00	
	405.00	-3.39	21.49	18.10	*	8.04		
410.00	-	-	-			-	200.00	
608.00	-		-			-	200.00	
	611.00	-3.44	27.34	23.90	*	16.67		
614.00	-	-	-			-	200.00	
960.00	-	-	-			-	500.00	
	975.00	-0.20	32.10	31.90	*	39.36		
1240.00	-	-	-			-	500.00	
1300.00	-	-	-	-		-	500.00	
	1350.00	33.07	-9.40	23.67	*	15.25		
1427.00	-	-	-	-		-	500.00	

EUT emissions observed throughout the given frequency spectrum were recorded and evaluated. Emission levels closest to the limit are listed on this data sheet. * This emission is not from the EUT. It is a measurement of minimum measurement system sensitivity (Noise Floor).

Data Sheet 3 of 7



Retlif Testing Laboratories

RETLIF TESTING LABORATORIES							
	EMISSIONS TEST DATA SHEET						
Test Method	Unwanted Emissions into Restricted Frequency Bands						
Customer	Lord Corporation						
Job Number	R-6265N-1						
Test Sample	Ruggedized Wireless Structural Health Monitoring Node						
Model Number	SHM-Link-201	SHM-Link-201					
Serial Number	6329-0150-00001						
Test Specification	FCC Part 15 Subpart C	Paragraph: 15.247(d)					
Operating Mode	Transmitting modulated signal at 2405 MHz, 2440 MHz and 2480 MHz consec	utively.					
Technician	M. Seamans						
Date	October 27 th , 2017						
Notes: Antenna Test D	istance: 3 meters Detector: Quasi-Peak <1GHz, Average >1GHz						

			TEST P	ARAMETERS	5		
Restricted Band	Measured Frequency	Meter Reading	Correction Factor	Corrected Reading		Converted Reading	Limit at 3M
MHz	MHz	dBuV	dB	dBuV/m		uV/m	uV/m
1435.00	-	-	-	-		-	500.00
	1500.00	32.91	-8.64	24.27	*	16.34	
1646.50	-	-	-	-		-	500.00
1660.00	-	-	-	-		-	500.00
	1680.00	32.68	-7.65	25.03	*	17.84	
1710.00	-	-	-	-		-	500.00
1718.80	-	-	-	-		-	500.00
	1720.00	32.37	-5.78	26.59	*	21.35	
1722.20	-	-	-	-		-	500.00
2200.00	-		-	-		-	500.00
	2250.00	32.19	-5.46	26.73	*	21.70	
2300.00	-	-	-	-		-	500.00
2310.00	_	_	_	-			500.00
2310.00	2360.00	31.19	-5.46	25.73	*	19.34	300.00
2390.00	-	-	-	-		-	500.00
2370.00							300.00
2483.50	-	-	-	-		-	500.00
	2490.00	32.10	-5.11	26.99	*	22.36	
2500.00	-	-	-	-		-	500.00

No EUT emissions within 10 dB of the specified test limit were observed at the specified test distance throughout the given frequency spectrum. * This emission is not from the EUT. It is a measurement of minimum measurement system sensitivity (Noise Floor).

Data Sheet 4 of 7



Retlif Testing Laboratories

RETLIF TESTING LABORATORIES						
	EMISSIONS TEST DATA SHEET					
Test Method	Unwanted Emissions into Restricted Frequency Bands					
Customer	Lord Corporation					
Job Number	R-6265N-1					
Test Sample	Ruggedized Wireless Structural Health Monitoring Node					
Model Number	SHM-Link-201	SHM-Link-201				
Serial Number	6329-0150-00001					
Test Specification	FCC Part 15 Subpart C	Paragraph: 15.247(d)				
Operating Mode	ing Mode Transmitting modulated signal at 2405 MHz, 2440 MHz and 2480 MHz consecutively.					
Technician	M. Seamans					
Date	October 27 th , 2017					

TEST PARAMETERS							
Restricted Band	Measured Frequency	Meter Reading	Correction Factor	Corrected Reading		Converted Reading	Limit at 3M
MHz	MHz	dBuV	dB	dBuV/m		uV/m	uV/m
2690.00	-	-	-	-		-	500.00
	-	-	-	-		-	
	2750.00	32.14	-4.45	27.69	*	24.23	
	-	-	-	-		-	
2900.00	-	-	-	-		-	500.00
3260.00	-	-	-	-		-	500.00
	3263.00	32.01	-2.88	29.13	*	28.60	
3267.00	-	-	-	-		-	500.00
3332.00	-	-	-	-		-	500.00
	3336.00	31.82	-2.62	29.20	*	28.84	
3339.00	-	-	-	-		-	500.00
3345.00	-	-	-	-		-	500.00
	3350.00	31.93	-2.57	29.36	*	29.37	
3358.00	-	-	-	-		-	500.00
3600.00	-	-	-	-		-	500.00
	-	-	-	-		-	
	3700.00	31.39	-1.40	29.99	*	31.58	
	-	-	-	-		-	

EUT emissions observed throughout the given frequency spectrum were recorded and evaluated. Emission levels closest to the limit are listed on this data sheet. * This emission is not from the EUT. It is a measurement of minimum measurement system sensitivity (Noise Floor).

Data Sheet 5 of 7



Retlif Testing Laboratories

RETLIF TESTING LABORATORIES						
	EMISSIONS TEST DATA SHEET					
Test Method	Unwanted Emissions into Restricted Frequency Bands					
Customer	Lord Corporation					
Job Number	R-6265N-1					
Test Sample	Ruggedized Wireless Structural Health Monitoring Node					
Model Number	SHM-Link-201					
Serial Number	6329-0150-00001					
Test Specification	FCC Part 15 Subpart C	Paragraph: 15.247(d)				
Operating Mode	ing Mode Transmitting modulated signal at 2405 MHz, 2440 MHz and 2480 MHz consecutively.					
Technician	M. Seamans					
Date	October 27 th , 2017					

			TEST P.	ARAMETERS	S		
Restricted Band	Measured Frequency	Meter Reading	Correction Factor	Corrected Reading		Converted Reading	Limit at 3M
MHz	MHz	dBuV	dB	dBuV/m		uV/m	uV/m
	-	-	-	-		-	
4400.00	-	-	-	-		-	500.00
4500.00	-	-	-	-		-	500.00
	4810.00	49.10	0.29	49.39		294.78	
	-	-	-	-		-	
5150.00	-	-	-	-		-	500.00
5350.00	-	-	-	-		-	500.00
	5400.00	30.80	0.92	31.72	*	38.54	
5460.00	-	-	-	-		-	500.00
7250.00	-	-	-	-		-	500.00
	7440.00	35.52	3.65	39.17	*	90.88	
7750.00	-	-	-	-		-	500.00
8025.00	-	-	-	-		-	500.00
	8300.00	32.75	4.43	37.18	*	72.27	
8500.00	-	-	-	-		-	500.00
9000.00	-	-	-	-		-	500.00
	9100.00	32.94	5.10	38.04	*	79.79	
9200.00	-	-	-	-		-	500.00

EUT emissions observed throughout the given frequency spectrum were recorded and evaluated. Emission levels closest to the limit are listed on this data sheet. * This emission is not from the EUT. It is a measurement of minimum measurement system sensitivity (Noise Floor).

Data Sheet 6 of 7



Retlif Testing Laboratories

RETLIF TESTING LABORATORIES						
	EMISSIONS TEST DATA SHEET					
Test Method	Unwanted Emissions into Restricted Frequency Bands					
Customer	Lord Corporation					
Job Number	R-6265N-1					
Test Sample	Ruggedized Wireless Structural Health Monitoring Node					
Model Number	SHM-Link-201	SHM-Link-201				
Serial Number	6329-0150-00001					
Test Specification	FCC Part 15 Subpart C	Paragraph: 15.247(d)				
Operating Mode	ing Mode Transmitting modulated signal at 2405 MHz, 2440 MHz and 2480 MHz consecutively.					
Technician	M. Seamans					
Date	October 27 th , 2017					

TEST PARAMETERS							
Restricted Band	Measured Frequency	Meter Reading	Correction Factor	Corrected Reading		Converted Reading	Limit at 3M
MHz	MHz	dBuV	dB	dBuV/m		uV/m	uV/m
9300.00	-	-	-	-		-	500.00
	9400.00	33.15	5.38	38.53	*	84.43	
9500.00	-	-	-	-		-	500.00
10,500,00							
10600.00	-	-	-	-		-	500.00
	12200.00	33.40	8.37	41.77	*	122.60	
12700.00	-	-	-	-		-	500.00
13250.00	-	-	-	-		-	500.00
	15800.00	34.60	8.84	43.44	*	148.59	
16200.00	-	-	-	-		-	500.00
17700.00	-	-	-	-		-	500.00
	19240.00	33.19	-6.52	26.67	*	21.55	
21400.00	-	-	-	-		-	500.00
22010.00	-	-	-	-		-	500.00
	22320.00	33.50	-5.30	28.20	*	25.70	
23120.00	-	-	-	-		-	500.00
23600.00	-	-	-	-		-	500.00
	23800.00	34.10	-4.17	29.93	*	31.36	
24000.00	-	-	1	-		-	500.00

EUT emissions observed throughout the given frequency spectrum were recorded and evaluated. Emission levels closest to the limit are listed on this data sheet. * This emission is not from the EUT. It is a measurement of minimum measurement system sensitivity (Noise Floor).

Data Sheet 7 of 7



Retlif Testing Laboratories


Test Photographs Power Density




Test Configuration



Retlif Testing Laboratories




EMISSIONS TEST DATA SHEET		
Method:	Power Spectral Density	
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (e)	
Job Number:	R-6265N-1	
Customer:	Lord Corporation	
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node	
Model Number:	SHM-Link-201	
Serial Number:	6329-0150-00001	
Operating Mode:	Transmitting modulated (LXRS) signal at 2.405GHz	
Technician:	M.Seamans	
Date(s):	October 18 th , 2017	
Temp/ Relative Humidity:	20.7 °C / 39.1 %	
Notes:	Power Spectral Density: 4.17dBm	






EMISSIONS TEST DATA SHEET		
Method:	Power Spectral Density	
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (e)	
Job Number:	R-6265N-1	
Customer:	Lord Corporation	
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node	
Model Number:	SHM-Link-201	
Serial Number:	6329-0150-00001	
Operating Mode:	Transmitting modulated (LXRS) signal at 2.440GHz	
Technician:	M.Seamans	
Date(s):	October 18th, 2017	
Temp/ Relative Humidity:	20.7 °C / 39.1 %	
Notes:	Power Spectral Density: 3.71dBm	






EMISSIONS TEST DATA SHEET		
Method:	Power Spectral Density	
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (e)	
Job Number:	R-6265N-1	
Customer:	Lord Corporation	
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node	
Model Number:	SHM-Link-201	
Serial Number:	6329-0150-00001	
Operating Mode:	Transmitting modulated (LXRS) signal at 2.480GHz	
Technician:	M.Seamans	
Date(s):	October 18th, 2017	
Temp/ Relative Humidity:	20.7 °C / 39.1 %	
Notes:	Power Spectral Density: 3.39dBm	






EMISSIONS TEST DATA SHEET		
Method:	Power Spectral Density	
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (e)	
Job Number:	R-6265N-1	
Customer:	Lord Corporation	
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node	
Model Number:	SHM-Link-201	
Serial Number:	6329-0150-00001	
Operating Mode:	Transmitting modulated (LXRS+) signal at 2.405GHz	
Technician:	M.Seamans	
Date(s):	October 18th, 2017	
Temp/ Relative Humidity:	20.7 °C / 39.1 %	
Notes:	Power Spectral Density: 5.28 dBm	





EMISSIONS TEST DATA SHEET		
Method:	Power Spectral Density	
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (e)	
Job Number:	R-6265N-1	
Customer:	Lord Corporation	
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node	
Model Number:	SHM-Link-201	
Serial Number:	6329-0150-00001	
Operating Mode:	Transmitting modulated (LXRS+) signal at 2.440GHz	
Technician:	M.Seamans	
Date(s):	October 18th, 2017	
Temp/ Relative Humidity:	20.7 °C / 39.1 %	
Notes:	Power Spectral Density: 4.86 dBm	





EMISSIONS TEST DATA SHEET		
Method:	Power Spectral Density	
Test Specification:	FCC Part 15, Subpart C Paragraph: 15.247 (e)	
Job Number:	R-6265N-1	
Customer:	Lord Corporation	
Test Sample:	Ruggedized Wireless Structural Health Monitoring Node	
Model Number:	SHM-Link-201	
Serial Number:	6329-0150-00001	
Operating Mode:	Transmitting modulated (LXRS+) signal at 2.480GHz	
Technician:	M.Seamans	
Date(s):	October 18 th , 2017	
Temp/ Relative Humidity:	20.7 °C / 39.1 %	
Notes:	Power Spectral Density: 4.51dBm	

