
OPERATIONAL DESCRIPTION

1.1. EUT description



CounterTop

iCT200_{series}

Security



The new Ingenico iCT200 series is universally EMV, APACS Common Criteria and PCI PED 2.0 certified, delivering security-as-standard and peace of mind for both the consumer and the merchant. Its 32-bit RISC crypto-processor provides a uniquely scalable and high-performance platform to support a host of new generation or reinforced security applications, with no impact on transaction speed or reliability.


Performance



Based on Telium 2 technology and utilising ARM9 and ARM7 microprocessor technology, the iCT200 series of countertop terminals combine innovation and performance – assuring a faster, more convenient and more reliable transaction every time.

Design/Ergonomics

With compact design and ergonomic styling, Ingenico's iCT200 series offers a huge range of functionality. Clear backlit graphic displays, white or colour screens allow easy reading and promotion of the merchant's brand, while the intuitively backlit designed keypad, with large keys, delivers ease of use for both merchant and consumer.



Equipped with an unparalleled array of communication technologies, such as fast modem, ethernet or GPRS, Ingenico's iCT200 series delivers any time, anywhere connectivity. A contactless EMV payment option supports card and mobile phone Near Field Communications (NFC) payment, already certified MasterCard PayPass and Visa payWave.

Software Development

Ingenico delivers incremental revenue today and future proofs the terminal investments of tomorrow. Uniquely, the iCT200 series is backwards compatible with most of all Ingenico services and applications (800+), while provides the rapid development environment on which to build a compelling portfolio of targeted, new generation services.

Field Services

To reduce total cost of ownership and enable merchants and banks to maximise their terminals investments, Ingenico provides a comprehensive range of terminal and software update and management services... both remotely and in the field. Fully certified professionals and local language helpdesk personnel operate in every one of our regions, ensuring Ingenico is on hand to support customers 24 hours a day, seven days a week, 365 days of the year.







NAME		iCT220	iCT250
D	ARM 9 & ARM 7	•	•
Processor	450 MIPS & 50 MIPS		0
Memory	RAM/Flash	8MB or 16MB/16MB	16MB/128MB
Removable Memory	µSD Card	optional	optional
Communication Mode	Dial-up Modem	•	۲
	Ethernet	optional	0
	GPRS	optional	optional
SAM	Î.	2	2
Card Readers	Smart Card	1 (+1 optional)	1 (+1 optional)
	Magstripe	Track 1/2/3	Track 1/2/3
	Contactless		optional
Display	Graphic 128 x 64		
	Backlit		0
	White		
	TFT Colour QVGA 320 x 240 pixels		
Keyboard	Number of keys	15	15
	Function/Navigation keys	4	4
	Backlit	0	0
Privacy Shield		optional	optional
Buzzer		•	
Thermal Printer	Lines/second	18 lps	18 lps
Connections on terminal	R\$232	1 (+1 optional)	1 (+1 optional)
	USB Host	1	1
	USB Slave	1	1
	Power supply connector	1	1
Power Supply	External Power supply	230V 50Hz	230V 50Hz
Magic Box		optional	optional
Connections on Magic Box	Power supply connector	1	1
	R\$232	1 (+1 optional)	1 (+1 optional)
	Line in	1	1
	Ethernet	1	1
Size (in mm)	Terminal	83 x 185 x 63	83 x 185 x 63
	Paper Roll (width/diameter)	58/Ø40	58/040
Weight (in gr)	Terminal (w/o paper roll nor cable)	325	325
	Lens	optional	optional
Customization	Printer cover flap	optional	optional
	Top Casing	optional	optional
Environment	Operating temperature	+5°C to +45°C	+5°C to +45°C
	Storage temperature	-20°C to +55°C	-20°C to +55°C
	Relative humidity, non condensing	85% HR at +40°C	
PCI PED 2.0	Online & offline	03% HK 8(+40 C	03%) HK 8(+40)

www.ingenico.com

Payment Solutions



1.2. Related Submittal(s) / Grant(s)

All host equipment used in the test configuration are FCC granted, when relevant.

1.3. Tested System Details

The FCC IDs for all equipment, plus description of all cables used in the tested system are:

The system was configured for testing in a typical fashion (as a customer would normally use it).

• Power supply:

- AC / DC Adaptor: INGENICO, Model PSM24W-080, P/N: 192020864
- Rating: 100-240VAC, 0.6A / 8.0VDC, 3.0A
- Frequency: 50-60Hz

During all the tests, EUT is supplied by this adaptor.

Inputs/outputs: Terminal

- 1 x USB Host, not used, not tested
- 1 x USB Slave, not used, not tested
- 1 x Jack power supply DC to magicbox
- 1 x COM0 to magicbox
- 1 x Ethernet to magicbox
- 1 x Line to magicbox
- 2 x SAM
- 2 x CAM
- 1 x Printer

• Inputs/outputs: Magicbox: 296105416

29/2012

- 1 x Jack power supply DC
- 1 x COM0
- 1 x Ethernet
- 1 x Line

<u>Cables:</u>

- 1 x Power supply cable, unshielded, length: 1.5m
- 1 x Line cable, unshielded, length: 2m
- 1 x Ethernet cable, unshielded, length: 2m
- 1 x Com cable, unshielded, length: 2m, with load
- 1 x Magicbox cable twisted, unshielded, length: 1.5m

<u>Auxiliaries equipment used during test:</u>

- 1 x Contact card
- 2 x SAM
- 1 x Laptop LENOVO with its power supply (Laptop of laboratory)
- 1 x TELTON Telephone line simulator TLS-5B-01, Sn: 014184

<u>Auxiliaries equipment used during test:</u>

- 1 x Laptop TOSHIBA SATELLITEPS141E-04YCsn : 13594938G- 1 x AC/DC Power supply adapterPHIHONG PSM36W-120TW, 100-240VAC / 1.5A / 50-60Hz, output12VDC / 3A

• Functions:

- 1 x SAM card reader
- 1 x Serial link communication (COM0 & COM2)
- 1 x µSD card reader (SAM1 & SAM2)

A generic program test is loaded on EUT, in order to perform in loop following functions:

- Reading / writing SAM card (SAM1 & SAM2)
- Reading / writing µSD card (MMC)
- Continous loop communication From RX/TX on Serial port (COM0 & COM2)
- Continous Ethernet communication is performed from EUT to Laptop (Ping)

1.4. Test Methodology

Both conducted and radiated testing were performed according to the procedures in ANSI C63.4-2003, FCC Part 15 Subpart B.

Radiated testing was performed at an antenna to EUT distance of 10 meters. During testing, all equipment's and cables were moved relative to each other in order to identify the worst case set-up.

1.5. Test facility

Tests have been performed from August 1st to 2nd, 2012.

This test facility has been fully described in a report and accepted by FCC as compliant with the radiated and AC line conducted test site criteria in ANSI C63.4-2003 in a letter dated March 25th, 2008 (registration number 94821).

This test facility has also been accredited by COFRAC (French accreditation authority for European Union test lab accreditation organization) according to NF EN ISO/IEC 17025, accreditation number 1-1633 as compliant with test site criteria and competence in 47 CFR Part 15/ANSI C63.4 and EN55022/CISPR22 norms for 89/336/EEC European EMC Directive application. All pertinent data for this test facility remains unchanged.