

### **Measurements at 3 and 30 metres**

The test site was free from underground metal objects.

The EUT was powered at its nominal voltage from its internal battery. The USB cable was inserted and connected to the AC to DC switching power supply. The AC to DC switching power supply was connected to a single phase supply. A power cable was run across the open field test site to the EUT and an RCD was fitted to the power source.

The EUT was placed on a plastic table at a height of 0.8 metres above ground level. All associated cables and support equipment were arranged according to ANSI C63.4-2014 Section 6.

The spectrum analyser used for measurements was located in a cabin at a distance of >10 metres from the magnetic loop antenna.

The test distance was from the centre of the mag loop antenna to the closest periphery of the EUT. This distance was maintained as the EUT was rotated.

The EUT was rotated through 360 degrees in 60 degree steps at both measurement distances. The mag loop antenna was rotated through 90 degrees in 30 degree steps at every position the EUT was moved to.