

## SAR Test exclusion documentation according to FCC KDB 447498, RSS-102 and EN 62479

Report identification number: 1-7857/19-01-95

Certification numbers and labeling requirements	
FCC ID	YGOHUF8423MS
IC number	4008C-HUF8423MS
HVIN (Hardware Version Identification Number)	HUF8423MS
PMN (Product Marketing Name)	HUF8423MS
FVIN (Firmware Version Identification Number)	-/-
HMN (Host Marketing Name)	-/-

This test report is electronically signed and valid without handwriting signature. For verification of the electronic signatures, the public keys can be requested at the testing laboratory.

**Document authorized:**

Thomas Vogler  
Lab Manager  
Radio Communications & EMC

**EUT technologies:**

Technologies:	Max. power: (AVG)	Max. EIRP (AVG):
434 MHz radio module	---	Fieldstrength: 76.9 dB $\mu$ V/m @ 3 m = - 18.44 dBm = 0.014 mW

Applied worst case averaged field strength see CTC advanced GmbH test report 1-7857/19-01-89 section 10.4.

**SAR test exclusion according to KDB447498 (General RF Exposure Guidance)**

Equations from Chapter 4.3.1: Standalone SAR test exclusion considerations page 11 and ff. and tables in Annex C

The table below gives the calculated maximal power that could be used for source based time averaged conducted or radiated power, adjusted for tune up tolerance. If this is at or below the calculated value the DUT is exempted from SAR evaluation.

f in [MHz]	d <sub>separation</sub> [mm]	Powerlimit [mW]	P <sub>max-declared</sub> [mW]	Exclusion
434.0	<b>5</b>	22.00	< 1 mW	yes

**SAR test exclusion according to RSS-102 Issue 5 Section 2.5.1/Table 1**

The table below gives the calculated maximal power that could be used for source based time averaged conducted or radiated power, adjusted for tune up tolerance. If this is at or below the calculated value the DUT is exempted from SAR evaluation.

f in [MHz]	d <sub>separation</sub> [mm]	tissue volume	Powerlimit [mW]	P <sub>max-declared</sub> [mW]	Exclusion
434.00	<b>5</b>	1 g	52.00	< 1 mW	yes

**SAR test exclusion according to EN 62479**

Compliance is given according to EN 62479 because the output power of the DUT is smaller than 20 mW.