

Test Laboratory: UL CCS SAR Lab C

System Validation

Communication System: CW; Frequency: 835 MHz; Duty Cycle: 1:1

Phantom section: RF Section

DASY5 Configuration:

- Probe: ER3DV6 - SN2339; ConvF(1, 1, 1); Calibrated: 1/20/2012

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn1239; Calibrated: 6/6/2012

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BB

- Measurement SW: DASY52, Version 52.8 (1); SEMCAD X Version 14.6.4 (4989)

CD835V3, E-Field/Measurement distance from the probe sensor center to Dipole = 10mm/Hearing Aid Compatibility Test (41x361x1): Measurement grid: dx=5mm, dy=5mm

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 114.3 V/m; Power Drift = -0.00 dB


PMR not calibrated. PMF = 1.000 is applied.

E-field emissions = 161.4 V/m

Near-field category: **M4 (AWF 0 dB)**

PMF scaled E-field

Grid 1 M4 158.0 V/m	Grid 2 M4 161.4 V/m	Grid 3 M4 155.5 V/m
Grid 4 M4 81.61 V/m	Grid 5 M4 83.31 V/m	Grid 6 M4 80.93 V/m
Grid 7 M4 146.3 V/m	Grid 8 M4 149.3 V/m	Grid 9 M4 145.4 V/m



0 dB = 161.4V/m = 44.16 dB V/m

Test Laboratory: UL CCS SAR Lab C

System Validation

Communication System: CW; Frequency: 1880 MHz; Duty Cycle: 1:1

Phantom section: RF Section

DASY5 Configuration:

- Probe: ER3DV6 - SN2339; ConvF(1, 1, 1); Calibrated: 1/20/2012
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn1239; Calibrated: 6/6/2012
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BB
- Measurement SW: DASY52, Version 52.8 (1); SEMCAD X Version 14.6.4 (4989)

CD1880V3, E-Field/Measurement distance from the probe sensor center to Dipole = 10mm/Hearing Aid Compatibility Test (41x181x1): Measurement grid: dx=5mm, dy=5mm

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 133.7 V/m; Power Drift = -0.01 dB


PMR not calibrated. PMF = 1.000 is applied.

E-field emissions = 138.6 V/m

Near-field category: **M2 (AWF 0 dB)**

PMF scaled E-field

Grid 1 M2 136.3 V/m	Grid 2 M2 138.6 V/m	Grid 3 M2 132.1 V/m
Grid 4 M3 88.95 V/m	Grid 5 M3 92.07 V/m	Grid 6 M3 90.20 V/m
Grid 7 M2 131.7 V/m	Grid 8 M2 133.7 V/m	Grid 9 M2 129.9 V/m



0 dB = 138.6V/m = 42.84 dB V/m

Test Laboratory: UL CCS SAR Lab C

System Validation

Communication System: CW; Frequency: 1880 MHz; Duty Cycle: 1:1

Phantom section: RF Section

DASY5 Configuration:

- Probe: ER3DV6 - SN2339; ConvF(1, 1, 1); Calibrated: 1/20/2012

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn1239; Calibrated: 6/6/2012

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BB

- Measurement SW: DASY52, Version 52.8 (1); SEMCAD X Version 14.6.4 (4989)

CD1730V3, E-Field/Measurement distance from the probe sensor center to Dipole = 10mm/Hearing Aid Compatibility Test (41x181x1): Measurement grid: dx=5mm, dy=5mm

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 151.3 V/m; Power Drift = -0.03 dB


PMR not calibrated. PMF = 1.000 is applied.

E-field emissions = 150.4 V/m

Near-field category: **M2 (AWF 0 dB)**

PMF scaled E-field

Grid 1 M2 147.6 V/m	Grid 2 M2 150.4 V/m	Grid 3 M2 143.2 V/m
Grid 4 M3 102.1 V/m	Grid 5 M3 105.5 V/m	Grid 6 M3 102.8 V/m
Grid 7 M2 147.6 V/m	Grid 8 M2 150.1 V/m	Grid 9 M2 145.7 V/m



0 dB = 150.4V/m = 43.54 dB V/m

Test Laboratory: UL CCS SAR Lab C

System Validation

Communication System: CW; Frequency: 835 MHz; Duty Cycle: 1:1

Phantom section: RF Section

DASY5 Configuration:

- Probe: H3DV6 - SN6157; ; Calibrated: 1/30/2012
- Sensor-Surface: (Fix Surface)
- Electronics: DAE4 Sn1239; Calibrated: 6/6/2012
- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BB
- Measurement SW: DASY52, Version 52.8 (1); SEMCAD X Version 14.6.4 (4989)

CD835V3, H-Field/Measurement distance from the probe sensor center to Dipole = 10mm/Hearing Aid Compatibility Test (41x361x1): Measurement grid: dx=5mm, dy=5mm

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 0.48 V/m; Power Drift = -0.01 dB


PMR not calibrated. PMF = 1.000 is applied.

H-field emissions = 0.45 A/m

Near-field category: **M4 (AWF 0 dB)**

PMF scaled H-field

Grid 1 M4 0.39 A/m	Grid 2 M4 0.41 A/m	Grid 3 M4 0.39 A/m
Grid 4 M4 0.43 A/m	Grid 5 M4 0.45 A/m	Grid 6 M4 0.43 A/m
Grid 7 M4 0.38 A/m	Grid 8 M4 0.40 A/m	Grid 9 M4 0.38 A/m



0 dB = 0.450A/m = -6.94 dB A/m

Test Laboratory: UL CCS SAR Lab C

System Validation

Communication System: CW; Frequency: 1880 MHz; Duty Cycle: 1:1

Phantom section: RF Section

DASY5 Configuration:

- Probe: H3DV6 - SN6157; ; Calibrated: 1/30/2012

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn1239; Calibrated: 6/6/2012

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BB

- Measurement SW: DASY52, Version 52.8 (1); SEMCAD X Version 14.6.4 (4989)

CD1880V3, H-Field/Measurement distance from the probe sensor center to Dipole = 10mm/Hearing Aid Compatibility Test (41x181x1): Measurement grid: dx=5mm, dy=5mm

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 0.47 V/m; Power Drift = 0.00 dB


PMR not calibrated. PMF = 1.000 is applied.

H-field emissions = 0.44 A/m

Near-field category: **M2 (AWF 0 dB)**

PMF scaled H-field

Grid 1 M2 0.39 A/m	Grid 2 M2 0.41 A/m	Grid 3 M2 0.39 A/m
Grid 4 M2 0.43 A/m	Grid 5 M2 0.44 A/m	Grid 6 M2 0.43 A/m
Grid 7 M2 0.38 A/m	Grid 8 M2 0.40 A/m	Grid 9 M2 0.39 A/m



0 dB = 0.440A/m = -7.13 dB A/m

System Validation

Communication System: CW; Frequency: 1880 MHz; Duty Cycle: 1:1

Phantom section: RF Section

DASY5 Configuration:

- Probe: H3DV6 - SN6157; ; Calibrated: 1/30/2012

- Sensor-Surface: (Fix Surface)

- Electronics: DAE4 Sn1239; Calibrated: 6/6/2012

- Phantom: HAC Test Arch with AMCC; Type: SD HAC P01 BB

- Measurement SW: DASY52, Version 52.8 (1); SEMCAD X Version 14.6.4 (4989)

CD1730V3, H-Field /Measurement distance from the probe sensor center to Dipole = 10mm/Hearing Aid Compatibility Test (41x181x1): Measurement grid: dx=5mm, dy=5mm

Device Reference Point: 0, 0, -6.3 mm

Reference Value = 0.49 V/m; Power Drift = 0.00 dB


PMR not calibrated. PMF = 1.000 is applied.

H-field emissions = 0.46 A/m

Near-field category: **M2 (AWF 0 dB)**

PMF scaled H-field

Grid 1 M2 0.39 A/m	Grid 2 M2 0.41 A/m	Grid 3 M2 0.39 A/m
Grid 4 M2 0.44 A/m	Grid 5 M2 0.46 A/m	Grid 6 M2 0.44 A/m
Grid 7 M2 0.39 A/m	Grid 8 M2 0.40 A/m	Grid 9 M2 0.39 A/m



0 dB = 0.460A/m = -6.74 dB A/m