

APPENDIX B: SYSTEM VERIFICATION

PCTEST

DUT: Dipole 750.0 MHz; Type: D750V3 - SN1161

Communication System: UID: 0, CW; Frequency: 750.0 MHz
Medium: 750 Head; Medium parameters used:
f = 750.0 MHz; cond = 0.894 S/m; perm = 40.2; density = 1000 kg/m³
Phantom Section: Flat; Space: 15 mm

Test Date: 09/07/2021; Ambient Temp: 22.6°C; Tissue Temp: 21.6°C

Probe: EX3DV4 - SN7406; ConvF:(10.08,10.08,10.08); Calibrated: 2021-07-20
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1676; Calibrated: 2021-06-21
Phantom: Twin-SAM V8.0; Serial: 2058
Measurement SW: cDASY6 Module SAR V16.0.0.65

750.0 MHz System Verification at 23.0 dBm


Area Scan (40.0 x 90.0): Measurement grid: dx=10.0 mm, dy=15.0 mm

Zoom Scan (30.0 x 30.0 x 30.0): Measurement grid: dx=6.0 mm, dy=6.0 mm, dz=1.5 mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 2.70 W/kg

SAR(1 g) = 1.70 W/kg

Deviation (1 g) = 5.85%



PCTEST

DUT: Dipole 835.0 MHz; Type: D835V2 - SN4d132

Communication System: UID: 0, CW; Frequency: 835.0 MHz
Medium: 835 Head; Medium parameters used:
f = 835.0 MHz; cond = 0.896 S/m; perm = 41.1; density = 1000 kg/m³
Phantom Section: Flat; Space: 15 mm

Test Date: 09/01/2021; Ambient Temp: 23.0°C; Tissue Temp: 22.7°C

Probe: EX3DV4 - SN7571; ConvF:(9.76,9.76,9.76); Calibrated: 2020-12-11
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1533; Calibrated: 2020-12-07
Phantom: Twin-SAM V5.0; Serial: 1648
Measurement SW: cDASY6 Module SAR V16.0.0.116

835.0 MHz System Verification at 23.0 dBm


Area Scan (40.0 x 90.0): Measurement grid: dx=10.0 mm, dy=15.0 mm

Zoom Scan (30.0 x 30.0 x 30.0): Measurement grid: dx=6.0 mm, dy=6.0 mm, dz=1.5 mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 3.14 W/kg

SAR(1 g) = 2.07 W/kg

Deviation (1 g) = 7.14%



PCTEST

DUT: Dipole 835.0 MHz; Type: D835V2 - SN4d132

Communication System: UID: 0, CW; Frequency: 835.0 MHz
Medium: 835 Head; Medium parameters used:
f = 835.0 MHz; cond = 0.939 S/m; perm = 40.0; density = 1000 kg/m³
Phantom Section: Flat; Space: 15 mm

Test Date: 09/04/2021; Ambient Temp: 22.5°C; Tissue Temp: 21.0°C

Probe: EX3DV4 - SN7571; ConvF:(9.76,9.76,9.76); Calibrated: 2020-12-11
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1533; Calibrated: 2020-12-07
Phantom: Twin-SAM V5.0; Serial: 1648
Measurement SW: cDASY6 Module SAR V16.0.0.116

835.0 MHz System Verification at 23.0 dBm


Area Scan (40.0 x 90.0): Measurement grid: dx=10.0 mm, dy=15.0 mm

Zoom Scan (30.0 x 30.0 x 30.0): Measurement grid: dx=6.0 mm, dy=6.0 mm, dz=1.5 mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 3.2 W/kg

SAR(1 g) = 2.07 W/kg

Deviation (1 g) = 7.14%



PCTEST

DUT: Dipole 1750.0 MHz; Type: D1750V2 - SN1150

Communication System: UID: 0, CW; Frequency: 1750.0 MHz
Medium: 1750 Head; Medium parameters used:
f = 1750.0 MHz; cond = 1.36 S/m; perm = 39.0; density = 1000 kg/m³
Phantom Section: Flat; Space: 10 mm

Test Date: 08/31/2021; Ambient Temp: 24.3°C; Tissue Temp: 20.9°C

Probe: EX3DV4 - SN7406; ConvF:(8.26,8.26,8.26); Calibrated: 2021-07-20
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1676; Calibrated: 2021-06-21
Phantom: Twin-SAM V8.0; Serial: 2058
Measurement SW: cDASY6 Module SAR V16.0.0.65

1750.0 MHz System Verification at 20.0 dBm


Area Scan (40.0 x 90.0): Measurement grid: dx=10.0 mm, dy=15.0 mm

Zoom Scan (30.0 x 30.0 x 30.0): Measurement grid: dx=6.0 mm, dy=6.0 mm, dz=1.5 mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 7.43 W/kg

SAR(1 g) = 3.80 W/kg

Deviation (1 g) = 4.11%



PCTEST

DUT: Dipole 1900.0 MHz; Type: D1900V2 - SN5d080

Communication System: UID: 0, CW; Frequency: 1900.0 MHz
Medium: 1900 Head; Medium parameters used:
f = 1900.0 MHz; cond = 1.45 S/m; perm = 39.3; density = 1000 kg/m³
Phantom Section: Flat; Space: 10 mm

Test Date: 08/22/2021; Ambient Temp: 24.3°C; Tissue Temp: 22.1°C

Probe: EX3DV4 - SN7660; ConvF:(9.06,9.06,9.06); Calibrated: 2021-06-28
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1677; Calibrated: 2021-06-22
Phantom: Twin-SAM V8.0; Serial: 2056
Measurement SW: cDASY6 Module SAR V16.0.0.116

1900.0 MHz System Verification at 20.0 dBm


Area Scan (40.0 x 90.0): Measurement grid: dx=10.0mm, dy=15.0mm

Zoom Scan (30.0 x 30.0 x 30.0): Measurement grid: dx=6.0mm, dy=6.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 8.17 W/kg

SAR(1 g) = 4.11 W/kg

Deviation (1 g) = 3.27%



PCTEST

DUT: Dipole 1900.0 MHz; Type: D1900V2 - SN5d080

Communication System: UID: 0, CW; Frequency: 1900.0 MHz
Medium: 1900 Head; Medium parameters used:
f = 1900.0 MHz; cond = 1.44 S/m; perm = 38.9; density = 1000 kg/m³
Phantom Section: Flat; Space: 10 mm

Test Date: 09/19/2021; Ambient Temp: 22.9°C; Tissue Temp: 22.7°C

Probe: EX3DV4 - SN7406; ConvF:(7.98,7.98,7.98); Calibrated: 2021-07-20
Sensor-Surface: 1.4mm (All points)
Electronics: DAE4 Sn1676; Calibrated: 2021-06-21
Phantom: Twin-SAM V8.0; Serial: 2058
Measurement SW: cDASY6 Module SAR V16.0.0.65

1900.0 MHz System Verification at 20.0 dBm


Area Scan (40.0 x 90.0): Measurement grid: dx=10.0 mm, dy=15.0 mm

Zoom Scan (30.0 x 30.0 x 30.0): Measurement grid: dx=6.0 mm, dy=6.0 mm, dz=1.5 mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 8.55 W/kg

SAR(1 g) = 4.27 W/kg

Deviation (1 g) = 7.29%



PCTEST

DUT: Dipole 2450.0 MHz; Type: D2450V2 - SN981

Communication System: UID: 0, CW; Frequency: 2450.0 MHz
Medium: 2450 Head; Medium parameters used:
f = 2450.0 MHz; cond = 1.87 S/m; perm = 38.6; density = 1000 kg/m³
Phantom Section: Flat; Space: 10 mm

Test Date: 08/16/2021; Ambient Temp: 24.0°C; Tissue Temp: 22.5°C

Probe: EX3DV4 - SN7660; ConvF:(8.49,8.49,8.49); Calibrated: 2021-06-28
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1677; Calibrated: 2021-06-22
Phantom: Twin-SAM V8.0; Serial: 2056
Measurement SW: cDASY6 Module SAR V16.0.0.65

2450.0 MHz System Verification at 20.0 dBm


Area Scan (40.0 x 80.0): Measurement grid: dx=10.0 mm, dy=10.0 mm

Zoom Scan (30.0 x 30.0 x 30.0): Measurement grid: dx=5.0 mm, dy=5.0 mm, dz=1.5 mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 11 W/kg

SAR(1 g) = 5.11 W/kg

Deviation (1 g) = -2.29%



PCTEST

DUT: Dipole 2450.0 MHz; Type: D2450V2 - SN797

Communication System: UID: 0, CW; Frequency: 2450.0 MHz
Medium: 2450 Head; Medium parameters used:
f = 2450.0 MHz; cond = 1.84 S/m; perm = 38.0; density = 1000 kg/m³
Phantom Section: Flat; Space: 10 mm

Test Date: 08/26/2021; Ambient Temp: 24.0°C; Tissue Temp: 21.9°C

Probe: EX3DV4 - SN7660; ConvF:(8.49,8.49,8.49); Calibrated: 2021-06-28
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1677; Calibrated: 2021-06-22
Phantom: Twin-SAM V8.0; Serial: 2056
Measurement SW: cDASY6 Module SAR V16.0.0.65

2450.0 MHz System Verification at 20.0 dBm


Area Scan (40.0 x 80.0): Measurement grid: dx=10.0 mm, dy=10.0 mm

Zoom Scan (30.0 x 30.0 x 30.0): Measurement grid: dx=5.0 mm, dy=5.0 mm, dz=1.5 mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 11.2 W/kg

SAR(1 g) = 5.06 W/kg

Deviation (1 g) = -3.44%



PCTEST

DUT: Dipole 2600.0 MHz; Type: D2600V2 - SN1064

Communication System: UID: 0, CW; Frequency: 2600.0 MHz
Medium: 2450 Head; Medium parameters used:
f = 2600.0 MHz; cond = 1.96 S/m; perm = 37.8; density = 1000 kg/m³
Phantom Section: Flat; Space: 10 mm

Test Date: 08/26/2021; Ambient Temp: 24.0°C; Tissue Temp: 21.9°C

Probe: EX3DV4 - SN7660; ConvF:(8.26,8.26,8.26); Calibrated: 2021-06-28
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1677; Calibrated: 2021-06-22
Phantom: Twin-SAM V8.0; Serial: 2056
Measurement SW: cDASY6 Module SAR V16.0.0.65

2600.0 MHz System Verification at 20.0 dBm


Area Scan (40.0 x 80.0): Measurement grid: dx=10.0 mm, dy=10.0 mm

Zoom Scan (30.0 x 30.0 x 30.0): Measurement grid: dx=5.0 mm, dy=5.0 mm, dz=1.5 mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 12.7 W/kg

SAR(1 g) = 5.71 W/kg

Deviation (1 g) = -1.72%



PCTEST

DUT: Dipole 5250.0 MHz; Type: D5GHzV2 - SN1057

Communication System: UID: 0, CW; Frequency: 5250.0 MHz
Medium: 5200-5800 Head; Medium parameters used:
f = 5250.0 MHz; cond = 4.55 S/m; perm = 34.6; density = 1000 kg/m³
Phantom Section: Flat; Space: 10 mm

Test Date: 08/24/2021; Ambient Temp: 22.4°C; Tissue Temp: 21.4°C

Probe: EX3DV4 - SN7538; ConvF:(5.29,5.29,5.29); Calibrated: 2020-11-23
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1449; Calibrated: 2020-09-10
Phantom: Twin-SAM V5.0 (Left); Serial: 1873
Measurement SW: cDASY6 Module SAR V16.0.0.116

5250.0 MHz System Verification at 17.0 dBm


Area Scan (40.0 x 80.0): Measurement grid: dx=10.0mm, dy=10.0mm

Zoom Scan (22.0 x 22.0 x 22.0): Measurement grid: dx=4.0mm, dy=4.0mm, dz=1.4mm; Graded Ratio: 1.4

Peak SAR (extrapolated) = 14.8 W/kg

SAR(1 g) = 3.92 W/kg

Deviation (1 g) = -1.63%



PCTEST

DUT: Dipole 5600.0 MHz; Type: D5GHzV2 - SN1057

Communication System: UID: 0, CW; Frequency: 5600.0 MHz
Medium: 5200-5800 Head; Medium parameters used:
f = 5600.0 MHz; cond = 4.95 S/m; perm = 34.1; density = 1000 kg/m³
Phantom Section: Flat; Space: 10 mm

Test Date: 08/24/2021; Ambient Temp: 22.4°C; Tissue Temp: 21.4°C

Probe: EX3DV4 - SN7538; ConvF:(4.63,4.63,4.63); Calibrated: 2020-11-23
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1449; Calibrated: 2020-09-10
Phantom: Twin-SAM V5.0 (Left); Serial: 1873
Measurement SW: cDASY6 Module SAR V16.0.0.116

5600.0 MHz System Verification at 17.0 dBm


Area Scan (40.0 x 80.0): Measurement grid: dx=10.0mm, dy=10.0mm

Zoom Scan (22.0 x 22.0 x 22.0): Measurement grid: dx=4.0mm, dy=4.0mm, dz=1.4mm; Graded Ratio: 1.4

Peak SAR (extrapolated) = 16.7 W/kg

SAR(1 g) = 4.09 W/kg

Deviation (1 g) = -2.39%



PCTEST

DUT: Dipole 5750.0 MHz; Type: D5GHzV2 - SN1057

Communication System: UID: 0, CW; Frequency: 5750.0 MHz
Medium: 5200-5800 Head; Medium parameters used:
f = 5750.0 MHz; cond = 5.12 S/m; perm = 33.8; density = 1000 kg/m³
Phantom Section: Flat; Space: 10 mm

Test Date: 08/24/2021; Ambient Temp: 22.4°C; Tissue Temp: 21.4°C

Probe: EX3DV4 - SN7538; ConvF:(4.78,4.78,4.78); Calibrated: 2020-11-23
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1449; Calibrated: 2020-09-10
Phantom: Twin-SAM V5.0 (Left); Serial: 1873
Measurement SW: cDASY6 Module SAR V16.0.0.116

5750.0 MHz System Verification at 17.0 dBm


Area Scan (40.0 x 80.0): Measurement grid: dx=10.0mm, dy=10.0mm

Zoom Scan (22.0 x 22.0 x 22.0): Measurement grid: dx=4.0mm, dy=4.0mm, dz=1.4mm; Graded Ratio: 1.4

Peak SAR (extrapolated) = 17.6 W/kg

SAR(1 g) = 4.19 W/kg

Deviation (1 g) = 4.62%



PCTEST

DUT: Dipole 750 MHz; Type: D750V3; Serial: 1003

Communication System: UID 0, CW; Frequency: 750 MHz; Duty Cycle: 1:1

Medium: 750 Body Medium parameters used:

$f = 750 \text{ MHz}$; $\sigma = 0.978 \text{ S/m}$; $\epsilon_r = 53.026$; $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Medium Notes: Test Date: 08/20/2021; Ambient Temp: 23.4°C; Tissue Temp: 21.7°C

Probe: EX3DV4 - SN7357; ConvF(10.29, 10.29, 10.29) @ 750 MHz; Calibrated: 4/19/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1407; Calibrated: 4/7/2021

Phantom: Twin-SAM V5.0 Front (20); Type: QD 000 P40 CD; Serial: 1686

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

750 MHz System Verification at 23.0 dBm (200 mW)


Area Scan (7x15x1): Measurement grid: dx=15mm, dy=15mm

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.80 W/kg

SAR(1 g) = 1.8 W/kg

Deviation(1 g) = 4.53%



0 dB = 2.45 W/kg = 3.89 dBW/kg

PCTEST

DUT: Dipole 750.0 MHz; Type: D750V3 - SN1161

Communication System: UID: 0, CW; Frequency: 750.0 MHz
Medium: 750 Body; Medium parameters used:
f = 750.0 MHz; cond = 0.971 S/m; perm = 53.7; density = 1000 kg/m³
Phantom Section: Flat; Space: 15 mm

Test Date: 08/23/2021; Ambient Temp: 20.5°C; Tissue Temp: 21.8°C

Probe: EX3DV4 - SN7571; ConvF:(10.24,10.24,10.24); Calibrated: 2020-12-11
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1533; Calibrated: 2020-12-07
Phantom: Twin-SAM V5.0; Serial: 1648
Measurement SW: cDASY6 Module SAR V16.0.0.116

750.0 MHz System Verification at 23.0 dBm


Area Scan (40.0 x 90.0): Measurement grid: dx=10.0 mm, dy=15.0 mm

Zoom Scan (30.0 x 30.0 x 30.0): Measurement grid: dx=6.0 mm, dy=6.0 mm, dz=1.5 mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 2.86 W/kg

SAR(1 g) = 1.81 W/kg

Deviation (1 g) = 7.35%



PCTEST

DUT: Dipole 750.0 MHz; Type: D750V3 - SN1161

Communication System: UID: 0, CW; Frequency: 750.0 MHz
Medium: 750 Body; Medium parameters used:
f = 750.0 MHz; cond = 0.963 S/m; perm = 53.6; density = 1000 kg/m³
Phantom Section: Flat; Space: 15 mm

Test Date: 08/30/2021; Ambient Temp: 23.5°C; Tissue Temp: 21.7°C

Probe: EX3DV4 - SN7571; ConvF:(10.24,10.24,10.24); Calibrated: 2020-12-11
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1533; Calibrated: 2020-12-07
Phantom: Twin-SAM V5.0; Serial: 1648
Measurement SW: cDASY6 Module SAR V16.0.0.116

750.0 MHz System Verification at 23.0 dBm


Area Scan (40.0 x 90.0): Measurement grid: dx=10.0 mm, dy=15.0 mm

Zoom Scan (30.0 x 30.0 x 30.0): Measurement grid: dx=6.0 mm, dy=6.0 mm, dz=1.5 mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 2.78 W/kg

SAR(1 g) = 1.78 W/kg

Deviation (1 g) = 5.58%



PCTEST

DUT: Dipole 835 MHz; Type: D835V2; Serial: 4d133

Communication System: UID 0, CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: 835 Body Medium parameters used:

$f = 835 \text{ MHz}$; $\sigma = 0.943 \text{ S/m}$; $\epsilon_r = 52.956$; $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 08/23/2021; Ambient Temp: 22.5°C; Tissue Temp: 21.7°C

Probe: EX3DV4 - SN7409; ConvF(9.66, 9.66, 9.66) @ 835 MHz; Calibrated: 6/21/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1334; Calibrated: 6/15/2021

Phantom: Twin-SAM V5.0 Front (20); Type: QD 000 P40 CD; Serial: 1759

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7495)

835 MHz System Verification at 23.0 dBm (200 mW)


Area Scan (7x14x1): Measurement grid: dx=15mm, dy=15mm

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 3.04 W/kg

SAR(1 g) = 1.99 W/kg

Deviation(1 g) = 2.05%



PCTEST

DUT: Dipole 835 MHz; Type: D835V2; Serial: 4d133

Communication System: UID 0, CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: 835 Body Medium parameters used:

$f = 835 \text{ MHz}$; $\sigma = 0.943 \text{ S/m}$; $\epsilon_r = 53.258$; $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 08/25/2021; Ambient Temp: 23.4°C; Tissue Temp: 22.5°C

Probe: EX3DV4 - SN7409; ConvF(9.66, 9.66, 9.66) @ 835 MHz; Calibrated: 6/21/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1334; Calibrated: 6/15/2021

Phantom: Twin-SAM V5.0 Front (20); Type: QD 000 P40 CD; Serial: 1759

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7495)

835 MHz System Verification at 23.0 dBm (200 mW)


Area Scan (7x14x1): Measurement grid: dx=15mm, dy=15mm

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 3.06 W/kg

SAR(1 g) = 2 W/kg

Deviation(1 g) = 2.56%



PCTEST

DUT: Dipole 835 MHz; Type: D835V2; Serial: 4d133

Communication System: UID 0, CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: 835 Body Medium parameters used:

$f = 835 \text{ MHz}$; $\sigma = 0.943 \text{ S/m}$; $\epsilon_r = 53.569$; $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 08/27/2021; Ambient Temp: 23.5°C; Tissue Temp: 22.2°C

Probe: EX3DV4 - SN7409; ConvF(9.66, 9.66, 9.66) @ 835 MHz; Calibrated: 6/21/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1334; Calibrated: 6/15/2021

Phantom: Twin-SAM V5.0 Front (20); Type: QD 000 P40 CD; Serial: 1759

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7495)

835 MHz System Verification at 23.0 dBm (200 mW)


Area Scan (7x14x1): Measurement grid: dx=15mm, dy=15mm

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.97 W/kg

SAR(1 g) = 1.95 W/kg

Deviation(1 g) = 0.00%



0 dB = 2.60 W/kg = 4.15 dBW/kg

PCTEST

DUT: Dipole 835 MHz; Type: D835V2; Serial: 4d133

Communication System: UID 0, CW; Frequency: 835 MHz; Duty Cycle: 1:1

Medium: 835 Body Medium parameters used:

$f = 835 \text{ MHz}$; $\sigma = 0.943 \text{ S/m}$; $\epsilon_r = 53.266$; $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.5 cm

Test Date: 08/31/2021; Ambient Temp: 23.2°C; Tissue Temp: 22.6°C

Probe: EX3DV4 - SN7409; ConvF(9.66, 9.66, 9.66) @ 835 MHz; Calibrated: 6/21/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1334; Calibrated: 6/15/2021

Phantom: Twin-SAM V5.0 Front (20); Type: QD 000 P40 CD; Serial: 1759

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7495)

835 MHz System Verification at 23.0 dBm (200 mW)


Area Scan (7x14x1): Measurement grid: dx=15mm, dy=15mm

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 2.97 W/kg

SAR(1 g) = 1.9 W/kg

Deviation(1 g) = -2.56%



0 dB = 2.58 W/kg = 4.12 dBW/kg

PCTEST

DUT: Dipole 1750 MHz; Type: D1750V2; Serial: 1148

Communication System: UID 0, CW; Frequency: 1750 MHz; Duty Cycle: 1:1

Medium: 1750 Body Medium parameters used:

$f = 1750$ MHz; $\sigma = 1.458$ S/m; $\epsilon_r = 51.121$; $\rho = 1000$ kg/m³

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 08/19/2021; Ambient Temp: 23.0°C; Tissue Temp: 23.7°C

Probe: EX3DV4 - SN3589; ConvF(7, 7, 7) @ 1750 MHz; Calibrated: 1/20/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1558; Calibrated: 1/13/2021

Phantom: Twin-SAM V5.0 front (30); Type: QD 000 P40 CD; Serial: 1646

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7483)

1750 MHz System Verification at 20.0 dBm (100 mW)


Area Scan (7x9x1): Measurement grid: dx=15mm, dy=15mm

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 6.37 W/kg

SAR(1 g) = 3.56 W/kg

Deviation(1 g) = -1.93%



0 dB = 4.62 W/kg = 6.64 dBW/kg

PCTEST

DUT: Dipole 1750 MHz; Type: D1750V2; Serial: 1148

Communication System: UID 0, CW; Frequency: 1750 MHz; Duty Cycle: 1:1

Medium: 1750 Body Medium parameters used:

$f = 1750$ MHz; $\sigma = 1.488$ S/m; $\epsilon_r = 51.324$; $\rho = 1000$ kg/m³

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 08/27/2021; Ambient Temp: 22.0°C; Tissue Temp: 22.4°C

Probe: EX3DV4 - SN7357; ConvF(8.12, 8.12, 8.12) @ 1750 MHz; Calibrated: 4/19/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1407; Calibrated: 4/7/2021

Phantom: Twin-SAM V5.0 Front (20); Type: QD 000 P40 CD; Serial: 1686

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7495)

1750 MHz System Verification at 20.0 dBm (100 mW)


Area Scan (7x9x1): Measurement grid: dx=15mm, dy=15mm

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 7.09 W/kg

SAR(1 g) = 3.86 W/kg

Deviation(1 g) = 6.34%



PCTEST

DUT: Dipole 1750 MHz; Type: D1750V2; Serial: 1150

Communication System: UID 0, CW; Frequency: 1750 MHz; Duty Cycle: 1:1

Medium: 1750 Body Medium parameters used:

$f = 1750 \text{ MHz}$; $\sigma = 1.526 \text{ S/m}$; $\epsilon_r = 51.124$; $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 08/29/2021; Ambient Temp: 22.6°C; Tissue Temp: 20.9°C

Probe: EX3DV4 - SN7357; ConvF(8.12, 8.12, 8.12) @ 1750 MHz; Calibrated: 4/19/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1407; Calibrated: 4/7/2021

Phantom: Twin-SAM V5.0 Front (20); Type: QD 000 P40 CD; Serial: 1686

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7495)

1750 MHz System Verification at 20.0 dBm (100 mW)


Area Scan (7x9x1): Measurement grid: dx=15mm, dy=15mm

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 6.98 W/kg

SAR(10 g) = 2.01 W/kg

Deviation(10 g) = 3.61%



0 dB = 5.85 W/kg = 7.67 dBW/kg

PCTEST

DUT: Dipole 1750 MHz; Type: D1750V2; Serial: 1150

Communication System: UID 0, CW; Frequency: 1750 MHz; Duty Cycle: 1:1

Medium: 1750 Body Medium parameters used:

$f = 1750 \text{ MHz}$; $\sigma = 1.528 \text{ S/m}$; $\epsilon_r = 52.005$; $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 09/05/2021; Ambient Temp: 21.7°C; Tissue Temp: 21.4°C

Probe: EX3DV4 - SN7357; ConvF(8.12, 8.12, 8.12) @ 1750 MHz; Calibrated: 4/19/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1407; Calibrated: 4/7/2021

Phantom: Twin-SAM V5.0 Front (20); Type: QD 000 P40 CD; Serial: 1686

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7495)

1750 MHz System Verification at 20.0 dBm (100 mW)


Area Scan (7x9x1): Measurement grid: dx=15mm, dy=15mm

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 7.06 W/kg

SAR(1 g) = 3.9 W/kg; SAR(10 g) = 2.06 W/kg

Deviation(1 g) = 6.56%; Deviation(10 g) = 6.19%



0 dB = 5.94 W/kg = 7.74 dBW/kg

PCTEST

DUT: Dipole 1750 MHz; Type: D1750V2; Serial: 1150

Communication System: UID 0, CW; Frequency: 1750 MHz; Duty Cycle: 1:1

Medium: 1750 Body Medium parameters used:

$f = 1750 \text{ MHz}$; $\sigma = 1.544 \text{ S/m}$; $\epsilon_r = 51.47$; $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 09/07/2021; Ambient Temp: 23.3°C; Tissue Temp: 21.4°C

Probe: EX3DV4 - SN7357; ConvF(8.12, 8.12, 8.12) @ 1750 MHz; Calibrated: 4/19/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1407; Calibrated: 4/7/2021

Phantom: Twin-SAM V5.0 Front (20); Type: QD 000 P40 CD; Serial: 1686

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7495)

1750 MHz System Verification at 20.0 dBm (100 mW)


Area Scan (7x9x1): Measurement grid: dx=15mm, dy=15mm

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 7.28 W/kg

SAR(1 g) = 4.02 W/kg

Deviation(1 g) = 9.84%



0 dB = 6.17 W/kg = 7.90 dBW/kg

PCTEST

DUT: Dipole 1900 MHz; Type: D1900V2; Serial: 5d149

Communication System: UID 0, CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: 1900 Body Medium parameters used:

$f = 1900$ MHz; $\sigma = 1.583$ S/m; $\epsilon_r = 51.276$; $\rho = 1000$ kg/m³

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 08/25/2021; Ambient Temp: 21.6°C; Tissue Temp: 21.3°C

Probe: EX3DV4 - SN7410; ConvF(7.7, 7.7, 7.7) @ 1900 MHz; Calibrated: 7/20/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1583; Calibrated: 7/13/2021

Phantom: Twin-SAM V5.0 (Front); Type: QD 000 P40 CD; Serial: 1792

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7495)

1900 MHz System Verification at 20.0 dBm (100 mW)


Area Scan (7x11x1): Measurement grid: dx=15mm, dy=15mm

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 7.93 W/kg

SAR(1 g) = 4.25 W/kg; SAR(10 g) = 2.17 W/kg

Deviation(1 g) = 7.87%; Deviation(10 g) = 4.83%



0 dB = 6.67 W/kg = 8.24 dBW/kg

PCTEST

DUT: Dipole 1900 MHz; Type: D1900V2; Serial: 5d148

Communication System: UID 0, CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: 1900 Body Medium parameters used:

$f = 1900 \text{ MHz}$; $\sigma = 1.581 \text{ S/m}$; $\epsilon_r = 51.04$; $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 08/27/2021; Ambient Temp: 21.6°C; Tissue Temp: 21.5°C

Probe: EX3DV4 - SN7410; ConvF(7.7, 7.7, 7.7) @ 1900 MHz; Calibrated: 7/20/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1583; Calibrated: 7/13/2021

Phantom: Twin-SAM V5.0 (Front); Type: QD 000 P40 CD; Serial: 1792

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7495)

1900 MHz System Verification at 20.0 dBm (100 mW)


Area Scan (7x11x1): Measurement grid: dx=15mm, dy=15mm

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 7.71 W/kg

SAR(1 g) = 4.17 W/kg

Deviation(1 g) = 6.65%



0 dB = 6.50 W/kg = 8.13 dBW/kg

PCTEST

DUT: Dipole 1900 MHz; Type: D1900V2; Serial: 5d148

Communication System: UID 0, CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: 1900 Body Medium parameters used:

$f = 1900 \text{ MHz}$; $\sigma = 1.572 \text{ S/m}$; $\epsilon_r = 50.717$; $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 08/30/2021; Ambient Temp: 21.2°C; Tissue Temp: 21.3°C

Probe: EX3DV4 - SN7410; ConvF(7.7, 7.7, 7.7) @ 1900 MHz; Calibrated: 7/20/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1583; Calibrated: 7/13/2021

Phantom: Twin-SAM V5.0 (Front); Type: QD 000 P40 CD; Serial: 1792

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7495)

1900 MHz System Verification at 20.0 dBm (100 mW)


Area Scan (7x11x1): Measurement grid: dx=15mm, dy=15mm

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 7.45 W/kg

SAR(10 g) = 2.02 W/kg

Deviation(10 g) = -1.46%



0 dB = 6.29 W/kg = 7.99 dBW/kg

PCTEST

DUT: Dipole 1900 MHz; Type: D1900V2; Serial: 5d149

Communication System: UID 0, CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: 1900 Body Medium parameters used:

$f = 1900$ MHz; $\sigma = 1.517$ S/m; $\epsilon_r = 51.674$; $\rho = 1000$ kg/m³

Phantom section: Flat Section; Space: 1.0 cm

Test Date: 09/03/2021; Ambient Temp: 24.0 C; Tissue Temp: 23.5°C

Probe: EX3DV4 - SN7409; ConvF(7.68, 7.68, 7.68) @ 1900 MHz; Calibrated: 6/21/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1334; Calibrated: 6/15/2021

Phantom: Twin-SAM V5.0 Front (20); Type: QD 000 P40 CD; Serial: 1759

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7495)

1900 MHz System Verification at 20.0 dBm (100 mW)


Area Scan (7x11x1): Measurement grid: dx=15mm, dy=15mm

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 8.05 W/kg

SAR(10 g) = 2.19 W/kg

Deviation(10 g) = 5.80%



0 dB = 6.60 W/kg = 8.20 dBW/kg

PCTEST

DUT: Dipole 1900 MHz; Type: D1900V2; Serial: 5d148


Communication System: UID 0, CW; Frequency: 1900 MHz; Duty Cycle: 1:1
Medium: 1900 Body Medium parameters used:
 $f = 1900 \text{ MHz}$; $\sigma = 1.52 \text{ S/m}$; $\epsilon_r = 52.069$; $\rho = 1000 \text{ kg/m}^3$
Phantom section: Flat Section; Space: 1.0 cm

Test Date: 09/08/2021; Ambient Temp: 24.3°C; Tissue Temp: 23.0°C

Probe: EX3DV4 - SN7410; ConvF(7.7, 7.7, 7.7) @ 1900 MHz; Calibrated: 7/20/2021
Sensor-Surface: 1.4mm (Mechanical Surface Detection)
Electronics: DAE4 Sn1583; Calibrated: 7/13/2021
Phantom: Twin-SAM V5.0 (Front); Type: QD 000 P40 CD; Serial: 1792
Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7495)

1900 MHz System Verification at 20.0 dBm (100 mW)

Area Scan (7x11x1): Measurement grid: dx=15mm, dy=15mm
Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm
Reference Value = 53.84 V/m; Power Drift = -0.01 dB
Peak SAR (extrapolated) = 7.42 W/kg
SAR(1 g) = 4.02
Deviation(1 g) = 2.81%



0 dB = 6.21 W/kg = 7.93 dBW/kg

PCTEST

DUT: Dipole 1900 MHz; Type: D1900V2; Serial: 5d148

Communication System: UID 0, CW; Frequency: 1900 MHz; Duty Cycle: 1:1

Medium: 1900 Body Medium parameters used:

$f = 1900$ MHz; $\sigma = 1.569$ S/m; $\epsilon_r = 51.951$; $\rho = 1000$ kg/m³

Phantom section: Flat Section ; Space: 1.0 cm

Test Date: 09/13/2021; Ambient Temp: 21.3°C; Tissue Temp: 21.4°C

Probe: EX3DV4 - SN7410; ConvF(7.7, 7.7, 7.7) @ 1900 MHz; Calibrated: 7/20/2021

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn1583; Calibrated: 7/13/2021

Phantom: Twin-SAM V5.0 (Front); Type: QD 000 P40 CD; Serial: 1792

Measurement SW: DASY52, Version 52.10 (4);SEMCAD X Version 14.6.14 (7495)

1900 MHz System Verification at 20.0 dBm (100 mW)


Area Scan (7x11x1): Measurement grid: dx=15mm, dy=15mm

Zoom Scan (5x5x7)/Cube 0: Measurement grid: dx=8mm, dy=8mm, dz=5mm

Peak SAR (extrapolated) = 7.69 W/kg

SAR(1 g) = 4.17 W/kg

Deviation(1 g) = 6.65%



0 dB = 6.46 W/kg = 8.10 dBW/kg

PCTEST

DUT: Dipole 2450.0 MHz; Type: D2450V2 - SN981

Communication System: UID: 0--, CW; Frequency: 2450.0 MHz
Medium: 2450 Body; Medium parameters used:
f = 2450.0 MHz; cond = 2.02 S/m; perm = 51.3; density = 1000 kg/m³
Phantom Section: Flat; Space: 10 mm

Test Date: 08/19/2021; Ambient Temp: 21.5°C; Tissue Temp: 22.9°C

Probe: EX3DV4 - SN7526; ConvF:(7.24,7.24,7.24); Calibrated: 2021-03-16
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1272; Calibrated: 2021-03-18
Phantom: Twin-SAM V5.0; Serial: 1758
Measurement SW: cDASY6 Module SAR V16.0.0.116

2450.0 MHz System Verification at 20.0 dBm


Area Scan (40.0 x 80.0): Measurement grid: dx=10.0mm, dy=10.0mm

Zoom Scan (30.0 x 30.0 x 30.0): Measurement grid: dx=5.0mm, dy=5.0mm, dz=1.5mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 10.8 W/kg

SAR(1 g) = 5.02 W/kg

Deviation (1 g) = 0.20%



PCTEST

DUT: Dipole 2450.0 MHz; Type: D2450V2 - SN981

Communication System: UID: 0, CW; Frequency: 2450.0 MHz
Medium: 2450 Body; Medium parameters used:
f = 2450.0 MHz; cond = 2.00 S/m; perm = 51.0; density = 1000 kg/m³
Phantom Section: Flat; Space: 10 mm

Test Date: 08/22/2021; Ambient Temp: 21.5°C; Tissue Temp: 21.8°C

Probe: EX3DV4 - SN7526; ConvF:(7.24,7.24,7.24); Calibrated: 2021-03-16
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1272; Calibrated: 2021-03-18
Phantom: Twin-SAM V5.0; Serial: 1758
Measurement SW: DASY Module SAR V16.0.0.116

2450 MHz System Verification at 20.0 dBm


Area Scan (40.0 x 80.0): Measurement grid: dx=10.0 mm, dy=10.0 mm

Zoom Scan (30.0 x 30.0 x 30.0): Measurement grid: dx=5.0 mm, dy=5.0 mm, dz=1.5 mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 10.8 W/kg

SAR(1 g) = 4.91 W/kg

Deviation (1 g) = -2.00%



PCTEST

DUT: Dipole 2450.0 MHz; Type: D2450V2 - SN981

Communication System: UID: 0, CW; Frequency: 2450.0 MHz
Medium: 2450 Body; Medium parameters used:
f = 2450.0 MHz; cond = 1.99 S/m; perm = 51.8; density = 1000 kg/m³
Phantom Section: Flat; Space: 10 mm

Test Date: 08/23/2021; Ambient Temp: 21.5°C; Tissue Temp: 21.8°C

Probe: EX3DV4 - SN7526; ConvF:(7.24,7.24,7.24); Calibrated: 2021-03-16
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1272; Calibrated: 2021-03-18
Phantom: Twin-SAM V5.0; Serial: 1758
Measurement SW: cDASY6 Module SAR V16.0.0.116

2450.0 MHz System Verification at 20.0 dBm


Area Scan (40.0 x 80.0): Measurement grid: dx=10.0 mm, dy=10.0 mm

Zoom Scan (30.0 x 30.0 x 30.0): Measurement grid: dx=5.0 mm, dy=5.0 mm, dz=1.5 mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 10.8 W/kg

SAR(1 g) = 4.99 W/kg; SAR(10 g) = 2.28 W/kg

Deviation (1 g) = -0.40 %; Deviation (10 g) = -3.80 %



PCTEST

DUT: Dipole 2450.0 MHz; Type: D2450V2 - SN981

Communication System: UID: 0, CW; Frequency: 2450.0 MHz
Medium: 2450 Body; Medium parameters used:
f = 2450.0 MHz; cond = 1.95 S/m; perm = 54.8; density = 1000 kg/m³
Phantom Section: Flat; Space: 10 mm

Test Date: 08/27/2021; Ambient Temp: 23.1°C; Tissue Temp: 23.6°C

Probe: EX3DV4 - SN7539; ConvF:(7.62,7.62,7.62); Calibrated: 2020-10-20
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10
Phantom: Twin-SAM V8.0; Serial: 1966
Measurement SW: cDASY6 Module SAR V16.0.0.116

2450.0 MHz System Verification at 20.0 dBm


Area Scan (40.0 x 80.0): Measurement grid: dx=10.0 mm, dy=10.0 mm

Zoom Scan (30.0 x 30.0 x 30.0): Measurement grid: dx=5.0 mm, dy=5.0 mm, dz=1.5 mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 10.3 W/kg

SAR(1 g) = 5.07 W/kg

Deviation (1 g) = 1.2%



PCTEST

DUT: Dipole 2600.0 MHz; Type: D2600V2 - SN1004

Communication System: UID: 0, CW; Frequency: 2600.0 MHz
Medium: 2450 Body; Medium parameters used:
f = 2600.0 MHz; cond = 2.20 S/m; perm = 51.2; density = 1000 kg/m³
Phantom Section: Flat; Space: 10 mm

Test Date: 08/23/2021; Ambient Temp: 21.5°C; Tissue Temp: 21.8°C

Probe: EX3DV4 - SN7526; ConvF:(7.11,7.11,7.11); Calibrated: 2021-03-16
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1272; Calibrated: 2021-03-18
Phantom: Twin-SAM V5.0; Serial: 1758
Measurement SW: cDASY6 Module SAR V16.0.0.116

2600.0 MHz System Verification at 20.0 dBm


Area Scan (40.0 x 80.0): Measurement grid: dx=10.0 mm, dy=10.0 mm

Zoom Scan (30.0 x 30.0 x 30.0): Measurement grid: dx=5.0 mm, dy=5.0 mm, dz=1.5 mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 12.9 W/kg

SAR(1 g) = 5.47 W/kg; SAR(10 g) = 2.39 W/kg

Deviation (1 g) = -1.26 %; Deviation (10 g) = -3.63%



PCTEST

DUT: Dipole 2600.0 MHz; Type: D2600V2 - SN1004

Communication System: UID: 0, CW; Frequency: 2600.0 MHz
Medium: 2450 Body; Medium parameters used:
f = 2600.0 MHz; cond = 2.15 S/m; perm = 54.2; density = 1000 kg/m³
Phantom Section: Flat; Space: 10 mm

Test Date: 08/27/2021; Ambient Temp: 23.1°C; Tissue Temp: 23.6°C

Probe: EX3DV4 - SN7539; ConvF:(7.55,7.55,7.55); Calibrated: 2020-10-20
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1415; Calibrated: 2021-03-10
Phantom: Twin-SAM V8.0; Serial: 1966
Measurement SW: cDASY6 Module SAR V16.0.0.116

2600.0 MHz System Verification at 20.0 dBm


Area Scan (40.0 x 80.0): Measurement grid: dx=10.0 mm, dy=10.0 mm

Zoom Scan (30.0 x 30.0 x 30.0): Measurement grid: dx=5.0 mm, dy=5.0 mm, dz=1.5 mm; Graded Ratio: 1.5

Peak SAR (extrapolated) = 11.2 W/kg

SAR(1 g) = 5.28 W/kg

Deviation (1 g) = -4.69%



PCTEST

DUT: Dipole 5250.0 MHz; Type: D5GHzV2 - SN1191

Communication System: UID: 0, CW; Frequency: 5250.0 MHz
Medium: 5200-5800 Body; Medium parameters used:
f = 5250.0 MHz; cond = 5.37 S/m; perm = 47.8; density = 1000 kg/m³
Phantom Section: Flat; Space: 10 mm

Test Date: 08/14/2021; Ambient Temp: 21.1°C; Tissue Temp: 22.5°C

Probe: EX3DV4 - SN7526; ConvF:(4.55,4.55,4.55); Calibrated: 2021-03-16
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1272; Calibrated: 2021-03-18
Phantom: Twin-SAM V5.0; Serial: 1758
Measurement SW: cDASY6 Module SAR V16.0.0.116

5250.0 MHz System Verification at 17.0 dBm


Area Scan (40.0 x 80.0): Measurement grid: dx=10.0mm, dy=10.0mm

Zoom Scan (22.0 x 22.0 x 22.0): Measurement grid: dx=4.0mm, dy=4.0mm, dz=1.4mm; Graded Ratio: 1.4

Peak SAR (extrapolated) = 13.9 W/kg

SAR(1 g) = 3.45 W/kg; SAR(10 g) = 0.986 W/kg

Deviation (1 g) = -7.51%; Deviation (10 g) = -6.10%



PCTEST

DUT: Dipole 5600.0 MHz; Type: D5GHzV2 - SN1191

Communication System: UID: 0, CW; Frequency: 5600.0 MHz
Medium: 5200-5800 Body; Medium parameters used:
f = 5600.0 MHz; cond = 5.88 S/m; perm = 47.3; density = 1000 kg/m³
Phantom Section: Flat; Space: 10 mm

Test Date: 08/14/2021; Ambient Temp: 21.1°C; Tissue Temp: 22.5°C

Probe: EX3DV4 - SN7526; ConvF:(4.16,4.16,4.16); Calibrated: 2021-03-16
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1272; Calibrated: 2021-03-18
Phantom: Twin-SAM V5.0; Serial: 1758
Measurement SW: cDASY6 Module SAR V16.0.0.116

5600.0 MHz System Verification at 17.0 dBm


Area Scan (40.0 x 80.0): Measurement grid: dx=10.0mm, dy=10.0mm

Zoom Scan (22.0 x 22.0 x 22.0): Measurement grid: dx=4.0mm, dy=4.0mm, dz=1.4mm; Graded Ratio: 1.4

Peak SAR (extrapolated) = 16.3 W/kg

SAR(1 g) = 3.76 W/kg; SAR(10 g) = 1.06 W/kg

Deviation (1 g) = -3.71%; Deviation (10 g) = -2.30%



PCTEST

DUT: Dipole 5750.0 MHz; Type: D5GHzV2 - SN1191

Communication System: UID: 0, CW; Frequency: 5750.0 MHz
Medium: 5200-5800 Body; Medium parameters used:
f = 5750.0 MHz; cond = 6.09 S/m; perm = 47.0; density = 1000 kg/m³
Phantom Section: Flat; Space: 10 mm

Test Date: 08/14/2021; Ambient Temp: 21.1°C; Tissue Temp: 22.5°C

Probe: EX3DV4 - SN7526; ConvF:(4.18,4.18,4.18); Calibrated: 2021-03-16
Sensor-Surface: 1.4mm (VMS + 6p)
Electronics: DAE4 Sn1272; Calibrated: 2021-03-18
Phantom: Twin-SAM V5.0; Serial: 1758
Measurement SW: cDASY6 Module SAR V16.0.0.116

5750.0 MHz System Verification at 17.0 dBm

Area Scan (40.0 x 80.0): Measurement grid: dx=10.0mm, dy=10.0mm

Zoom Scan (22.0 x 22.0 x 22.0): Measurement grid: dx=4.0mm, dy=4.0mm, dz=1.4mm; Graded Ratio: 1.4

Peak SAR (extrapolated) = 15.5 W/kg

SAR(1 g) = 3.48 W/kg; SAR(10 g) = 0.992 W/kg

Deviation (1 g) = -7.08%; Deviation (10 g) = -4.62%

