



## 5. ATTESTATION STATEMENT

### SUMMARY:

All tests per CFR 47, FCC Part 2, Paragraphs 2.1046; 2.1047(a);(b); 2.1049; 2.1051; 2.1053; 2.1055; Part 74, Paragraph 74.861(e)(1); (e)(3); (e)(5); and (e)(6) were

■ - Performed

The Equipment Under Test

■ - **Fulfills** the requirements of CFR 47, FCC Part 2, Paragraphs 2.1046; 2.1047(a);(b); 2.1049; 2.1051; 2.1053; 2.1055; Part 74, Paragraph 74.861(e)(1); (e)(3); (e)(5); and (e)(6).

- TÜV PRODUCT SERVICE, INC. -

Responsible Engineer:

A handwritten signature in black ink, appearing to read 'Jim Owen', written in a cursive style.

Jim Owen  
(EMC Engineer)

4/12/01

**Q700 MASTER STATION FREQUENCY STABILITY TEST  
VERSUS POWER SUPPLY VARIATIONS****Unit # 102 Master Station TX12**

Nominal Operating Frequency = 725.000000 MHz

Tolerance is .005% = .00005 = +/-36.25kHz

85%	97 VAC	724.999817 MHz
100% Nominal Voltage	115 VAC	724.999862 MHz
115%	132 VAC	724.999769 MHz

**UNIT #103 Master Station TX8**

Nominal operating frequency= 605.000000 MHz

Tolerance is .005% = .00005 = +/-30.25kHz

85%	97VAC	605.001613 MHz
100% Nominal Voltage	115 VAC	605.001683 MHz
115%	132 VAC	605.001575 MHz

**UNIT #104 Master Station TX4**


Nominal operating frequency= 485.000000 MHz

Tolerance is .005% = .00005 = +/-24.25kHz

85%	97 VAC	485.000213 MHz
100%	115 VAC	485.000143 MHz
115%	132 VAC	485.000102 MHz

I certify that the above frequency measurements were made on the Master Stations with a calibrated HP53131A Frequency Counter.

James E. Pigg



Director of Engineering

VEGA Holdings, Inc.

File: FCC\_FREQ.002