

# Schmid & Partner Engineering AG

Zeughausstrasse 43, 8004 Zurich, Switzerland, Phone +41 1 245 97 00, Fax +41 1 245 97 79

## Calibration Certificate

### Dosimetric E-Field Probe

Type:

ET3DV6

Serial Number:

1503

Place of Calibration:

Zurich

Date of Calibration:

November 20, 2002

Calibration Interval:

12 months

Schmid & Partner Engineering AG hereby certifies, that this device has been calibrated on the date indicated above. The calibration was performed in accordance with specifications and procedures of Schmid & Partner Engineering AG.

Wherever applicable, the standards used in the calibration process are traceable to international standards. In all other cases the standards of the Laboratory for EMF and Microwave Electronics at the Swiss Federal Institute of Technology (ETH) in Zurich, Switzerland have been applied.

Calibrated by:

D. Vella

Approved by:

Alain Käfer

# Probe ET3DV6

**SN:1503**

<b>Manufactured:</b>	<b>October 24, 1999</b>
<b>Last calibration:</b>	<b>November 16, 2001</b>
<b>Recalibrated:</b>	<b>November 20, 2002</b>

**Calibrated for DASY Systems**

**(Note: non-compatible with DASY2 system!)**

**DASY - Parameters of Probe: ET3DV6 SN:1503****Sensitivity in Free Space**

NormX	<b>2.21</b> $\mu\text{V}/(\text{V}/\text{m})^2$
NormY	<b>2.09</b> $\mu\text{V}/(\text{V}/\text{m})^2$
NormZ	<b>1.91</b> $\mu\text{V}/(\text{V}/\text{m})^2$

**Diode Compression**

DCP X	<b>92</b>	mV
DCP Y	<b>92</b>	mV
DCP Z	<b>92</b>	mV

**Sensitivity in Tissue Simulating Liquid**

Head	<b>900 MHz</b>	$\epsilon_r = 41.5 \pm 5\%$	$\sigma = 0.97 \pm 5\%$ mho/m
Head	<b>835 MHz</b>	$\epsilon_r = 41.5 \pm 5\%$	$\sigma = 0.90 \pm 5\%$ mho/m
ConvF X	<b>6.5</b> $\pm 9.5\%$ (k=2)		Boundary effect:
ConvF Y	<b>6.5</b> $\pm 9.5\%$ (k=2)		Alpha <b>0.49</b>
ConvF Z	<b>6.5</b> $\pm 9.5\%$ (k=2)		Depth <b>2.11</b>
Head	<b>1800 MHz</b>	$\epsilon_r = 40.0 \pm 5\%$	$\sigma = 1.40 \pm 5\%$ mho/m
Head	<b>1900 MHz</b>	$\epsilon_r = 40.0 \pm 5\%$	$\sigma = 1.40 \pm 5\%$ mho/m
ConvF X	<b>5.3</b> $\pm 9.5\%$ (k=2)		Boundary effect:
ConvF Y	<b>5.3</b> $\pm 9.5\%$ (k=2)		Alpha <b>0.54</b>
ConvF Z	<b>5.3</b> $\pm 9.5\%$ (k=2)		Depth <b>2.47</b>


**Boundary Effect**


Head	<b>900 MHz</b>	<b>Typical SAR gradient: 5 % per mm</b>	
	Probe Tip to Boundary	<b>1 mm</b>	<b>2 mm</b>
	SAR <sub>90</sub> [%] Without Correction Algorithm	<b>9.5</b>	<b>5.2</b>
	SAR <sub>90</sub> [%] With Correction Algorithm	<b>0.2</b>	<b>0.4</b>
Head	<b>1800 MHz</b>	<b>Typical SAR gradient: 10 % per mm</b>	
	Probe Tip to Boundary	<b>1 mm</b>	<b>2 mm</b>
	SAR <sub>90</sub> [%] Without Correction Algorithm	<b>13.4</b>	<b>8.9</b>
	SAR <sub>90</sub> [%] With Correction Algorithm	<b>0.2</b>	<b>0.2</b>

**Sensor Offset**


Probe Tip to Sensor Center	<b>2.7</b>	mm
Optical Surface Detection	<b>1.3 <math>\pm</math> 0.2</b>	mm

### Receiving Pattern ( $\phi$ ), $\theta = 0^\circ$






**Isotropy Error ( $\phi$ ),  $\theta = 0^\circ$**





# Frequency Response of E-Field


( TEM-Cell:ifi110, Waveguide R22)



### Dynamic Range f(SAR<sub>brain</sub>) ( Waveguide R22 )




## Conversion Factor Assessment




Head	900 MHz	$\epsilon_r = 41.5 \pm 5\%$	$\sigma = 0.97 \pm 5\%$ mho/m	
Head	835 MHz	$\epsilon_r = 41.5 \pm 5\%$	$\sigma = 0.90 \pm 5\%$ mho/m	
	ConvF X	$6.5 \pm 9.5\%$ (k=2)	Boundary effect:	
	ConvF Y	$6.5 \pm 9.5\%$ (k=2)	Alpha	<b>0.49</b>
	ConvF Z	$6.5 \pm 9.5\%$ (k=2)	Depth	<b>2.11</b>
Head	1800 MHz	$\epsilon_r = 40.0 \pm 5\%$	$\sigma = 1.40 \pm 5\%$ mho/m	
Head	1900 MHz	$\epsilon_r = 40.0 \pm 5\%$	$\sigma = 1.40 \pm 5\%$ mho/m	
	ConvF X	$5.3 \pm 9.5\%$ (k=2)	Boundary effect:	
	ConvF Y	$5.3 \pm 9.5\%$ (k=2)	Alpha	<b>0.54</b>
	ConvF Z	$5.3 \pm 9.5\%$ (k=2)	Depth	<b>2.47</b>

### Conversion Factor Assessment



<b>Body</b>	<b>900 MHz</b>	$\epsilon_r = 55.0 \pm 5\%$	$\sigma = 1.05 \pm 5\% \text{ mho/m}$
<b>Body</b>	<b>835 MHz</b>	$\epsilon_r = 55.2 \pm 5\%$	$\sigma = 0.97 \pm 5\% \text{ mho/m}$
	<b>ConvF X</b>	<b>6.2 ± 9.5% (k=2)</b>	<b>Boundary effect:</b>
	<b>ConvF Y</b>	<b>6.2 ± 9.5% (k=2)</b>	<b>Alpha 0.47</b>
	<b>ConvF Z</b>	<b>6.2 ± 9.5% (k=2)</b>	<b>Depth 2.30</b>
<b>Body</b>	<b>1800 MHz</b>	$\epsilon_r = 53.3 \pm 5\%$	$\sigma = 1.52 \pm 5\% \text{ mho/m}$
<b>Body</b>	<b>1900 MHz</b>	$\epsilon_r = 53.3 \pm 5\%$	$\sigma = 1.52 \pm 5\% \text{ mho/m}$
	<b>ConvF X</b>	<b>5.0 ± 9.5% (k=2)</b>	<b>Boundary effect:</b>
	<b>ConvF Y</b>	<b>5.0 ± 9.5% (k=2)</b>	<b>Alpha 0.66</b>
	<b>ConvF Z</b>	<b>5.0 ± 9.5% (k=2)</b>	<b>Depth 2.21</b>

## Conversion Factor Assessment



<b>1950</b>	<b>Head</b>	<b>MHz</b>	$\epsilon_r = 40.0 \pm 5\%$	$\sigma = 1.40 \pm 5\% \text{ mho/m}$
	ConvF X		<b>5.1</b> $\pm 8.9\%$ (k=2)	Boundary effect:
	ConvF Y		<b>5.1</b> $\pm 8.9\%$ (k=2)	Alpha <b>0.61</b>
	ConvF Z		<b>5.1</b> $\pm 8.9\%$ (k=2)	Depth <b>2.25</b>
<b>1950</b>	<b>Body</b>	<b>MHz</b>	$\epsilon_r = 53.3 \pm 5\%$	$\sigma = 1.52 \pm 5\% \text{ mho/m}$
	ConvF X		<b>4.6</b> $\pm 8.9\%$ (k=2)	Boundary effect:
	ConvF Y		<b>4.6</b> $\pm 8.9\%$ (k=2)	Alpha <b>0.89</b>
	ConvF Z		<b>4.6</b> $\pm 8.9\%$ (k=2)	Depth <b>1.88</b>

# Deviation from Isotropy in HSL

Error ( $\theta, \phi$ ),  $f = 900$  MHz

